

Actual Supply & Power Position of Date: 22.05.2026

| Actual Power Availability | | | Energy (MU) | Actual Rostering on dated: 22-05-2026 | |
|---------------------------|---|--|-------------|---------------------------------------|------|
| 1 | State Generation | | 19.20 | AREA | HRS. |
| 2 | Central Share to Uttarakhand & V.P. Share | | 23.41 | Rural of Haridwar & U.S. Nagar Distt. | Nil |
| Total from firm sources | | | 42.61 | Small Towns | Nil |
| 3 | Power from other sources | a) Power Purchase/Return Banking | 19.17 | Other Towns | Nil |
| | | b) Net IEX/PXIL Drawl | 0.20 | Hills | Nil |
| | | c) Grid Overdrawl (+) / Underdrawl (-) | - 1.28 | Steel Furnaces | Nil |
| Total from other sources | | | 18.09 | Non Continuous Industries | Nil |
| 4 | Total Availability | | 60.70 | | |
| 5 | Rostering | | 0.00 | | |
| 6 | Actual Demand | | 60.70 | | |

AVAILABILITY FROM CSGS VS ACTUAL DRAWL



| TRANSMISSION CONSTRAINTS / CONTINGENCY | | |
|--|------|--|
| Substation | Hrs. | Reason |
| 40 MVA T/F – 3 Majra | 0:16 | Due to tripping of 132 KV Kulhal-Majra line. |
| 132 KV Laltappr | 0:29 | Due to overload of 160 MVA T/F at Rishikesh. |

| | |
|----------------------|--|
| Small Towns : | Landhora Town, Manglore Town, Laksar Town, Bahadrabad Town, Dhakrani, Selaqui, Sahaspur, Vikasnagar, Doiwala, Kotdwar, Jwalapur, Jaspur Town, Kichha Town, Khatima Town, Ramnagar Town, Gadarpur Town & Bazpur Town. |
| Other Towns : | Rudrapur, Kashipur, Haldwani, Sitarganj & Roorkee Town. |