

MAXIMUM LOAD IN MVA ON TRANSFORMER OF DIFFERENT 400/220/132KV S/s UNDER THE JURIDICATION OF O&M, KUMAON ZONE, PTCUL FOR THE MONTH OF 05/2023

S. No	Name of S/S	Name of T/F & Voltage	Apr 23	May 23	Jun 23	Jul 23	Aug 23	Sep 23	Oct 23	Nov 23	Dec 23	Jan 24	Feb 24	Mar 24
1	400KV S/s Kashipur	315MVA 400/220KV T/F-I	163	260										
		315MVA 400/220KV T/F-II	163	260										
		160MVA 220/132KV T/F-I	90	101										
		160MVA 220/132KV T/F-II	90	101										
		160MVA 220/132KV T/F-III	90	101										
2	220KV S/s Mahaukhera ganj	100MVA 220/132KV T/F-I	55.63	56.01										
		100MVA 220/132KV T/F-II	55.63	56.01										
		80MVA 132/33KV T/F-I	26.97	26.97										
		80MVA 132/33KV T/F-II	26.97	26.97										
3	132KV S/s Jaspur	40MVA 132/33KV T/F-I	36	34										
		40MVA 132/33KV T/F-II	33	34										
		40MVA 132/33KV T/F-III	12	16										
4	132KV S/s Kashipur	40MVA 132/33KV T/F-I	23.9	30.9										
		40MVA 132/33KV T/F-II	23	32										
		40MVA 132/33KV T/F-III	23	32										
5	132KV S/s Bazpur	40MVA 132/33KV T/F	29.1	32.5										
		80MVA 132/33KV T/F	67.5	68.9										
6	132KV S/s Ramnagar	40MVA 132/33KV T/F	24.3	36.8										
		20MVA 132/33KV T/F	15.6	18.8										
7	220KV S/s Pantnagar	160MVA 220/132KV T/F-I	103	108										
		160MVA 220/132KV T/F-II	103	129										
		80MVA 132/33KV T/F-I	52	53										
		80MVA 132/33KV T/F-II	52	53										
		50MVA 220/33KV T/F-I	29	28										
		50MVA 220/33KV T/F-II	29	28										
8	132KV S/s Rudrapur	40MVA 132/33KV T/F-I	23	30										
		40MVA 132/33KV T/F-II	23	30										
		20MVA 132/33KV T/F	9	9										
9	132KV S/s Kichha	40MVA 132/33KV T/F-I	26.83	29.825										
		40MVA 132/33KV T/F-II	26.83	29.825										
		40MVA 132/33KV T/F-III	18.5	22.98										
10	220KV S/s Jafarpur	50MVA 220/33KV T/F-I	16	18										
		50MVA 220/33KV T/F-II	16	19										
11	132KV S/s Sitraganj	40MVA 132/33KV T/F-I	22.37	20										
		40MVA 132/33KV T/F-II	22.37	20										
12	132KV S/s ELDECO Sitraganj	40MVA 132/33KV T/F-I	14.29	14.6										
		40MVA 132/33KV T/F-II	14.29	14.6										
		40MVA 132/33KV T/F-III	14.29	14.6										
13	220KV S/s Haldwani	100MVA 220/132KV T/F-I	46.43	67.08										
		100MVA 220/132KV T/F-II	46.43	67.08										
		40MVA 132/33KV T/F-I	18.64	20.98										
		40MVA 132/33KV T/F-II	19.79	24.22										
		40MVA 132/33KV T/F-III	18.64	20.98										
14	132KV S/s Haldwani	40MVA 132/33KV T/F-I	26.96	28.6										
		40MVA 132/33KV T/F-II	27.28	30.82										
15	132KV S/s Bhowali	20MVA 132/33 T/F-I	14.2	12.02										
		3x5MVA 132/33KV T/F-II	8.52	8.09										
		20MVA 132/33 T/F-III	14.05	12.01										
16	132KV S/s Almora	20MVA 132/33KV T/F-II	15.78	10.52										
		20MVA 132/33KV T/F-III	16.23	10.75										
17	132KV S/s Pithoragarh	3x5MVA 132/33KV T/F-I	10.29	8.46										
		3x5MVA 132/33KV T/F-II	10.29	8.46										
		20MVA 132/33KV T/F-I	17.15	16.23										
		20MVA 132/33KV T/F-II	17.15	16.23										
18	132KV S/s Ranikhet	15MVA 132/33KV T/F-I	9.14	8.92										
		15MVA 132/33KV T/F-II	9.14	8.92										
		20MVA 132/33KV T/F	11.2	12.12										
19	132KV S/s Bageshwar	3x7MVA 132/33KV T/F-I	6.17	6.86										
		3x7MVA 132/33KV T/F-II	6.17	6.86										


 (H.S. HYANKI)
 CHIEF ENGINEER (O&M)