

MAXIMUM LOAD IN MVA ON TRANSFORMER OF DIFFERENT 400/220/132KV S/s UNDER THE JURIDICITION OF O&M, KUMAON ZONE, PTCUL FOR THE MONTH OF 03/2022

	Name of S/s	Name of T/F & Voltage	Apr 21	May 21	Jun 21	Jul 21	Aug 21	Sep 21	Oct 21	Nov 21	Dec 21	Jan 22	Feb 22	Mar 22
1	400KV S/s Kashipur	315MVA 400/220KV T/F-I	187	163	157	210	173.0	154	266	157	226	198	206	194
		315MVA 400/220KV T/F-II	187	163	157	210	173.0	154	266	157	226	198	206	194
		160MVA 220/132KV T/F-I	105	93	123	125	136.0	116	108	93	91	80	106	90
		160MVA 220/132KV T/F-II	105	93	123	125	136.0	116	108	93	91	80	106	90
2	220KV S/s Mahaulkherag enj	100MVA 220/132KV T/F-I	57.53	46.48	57.91	60.96	60.2	55.63	46.86	36.96	36.96	42.67	42.67	36.96
		100MVA 220/132KV T/F-II	57.53	46.48	57.91	60.96	60.2	55.63	46.86	36.96	36.96	42.67	42.67	36.96
		80MVA 132/33KV T/F-I	22.4	21.03	22.86	30.17	29.5	32.23	28.12	19.66	20.8	21.94	23.77	24.46
		80MVA 132/33KV T/F-II	22.4	21.03	22.86	27.20	29.5	29.03	28.12	33.83	20.8	21.94	23.77	40.92
3	132KV S/s Jaspur	40MVA 132/33KV T/F-I	27	28.7	35.58	35.74	34.5	33.2	30.53	25.92	26.6	29.27	32	33
		40MVA 132/33KV T/F-II	27.1	26.72	35.68	35.84	35.0	32.1	30.53	24.86	26.7	29.76	32	30
		40MVA 132/33KV T/F-III	-	-	-	-	-	-	3.16	3.58	9.24	4.63	14	16
4	132KV S/s Kashipur	40MVA 132/33KV T/F-I	20.7	22.7	28.4	30.90	28.0	25	20.5	16.8	21.8	21.1	23.2	19.8
		40MVA 132/33KV T/F-II	19.3	19.3	25	29.50	27.5	27.7	24.8	18	20.2	23.4	20	20
		40MVA 132/33KV T/F-III	19.3	19.3	25	29.50	27.5	27.7	24.8	18	27.3	23.4	20	20
5	132KV S/s Bazpur	40MVA 132/33KV T/F	28.8	27.2	32.3	37.30	32.5	30.2	27.5	21.5	26.8	27.7	27.9	25.5
		80MVA 132/33KV T/F	58.1	55.1	65.4	74.80	65.2	60.9	52.4	44.2	54.9	54.7	57.4	51.7
6	132KV S/s Ramnagar	40MVA 132/33KV T/F	21.3	19	24.4	29.70	39.4	25.9	26.1	20.1	24.3	26.3	24.3	24.3
		20MVA 132/33KV T/F	13.3	12.6	19.7	18.10	16.9	15.8	16.2	13	14.9	15.8	14.6	15.8
7	220KV S/s Pantnagar	160MVA 220/132KV T/F-I	124	66.68	88.93	105.09	102.6	102.6	110.4	76.63	93	103.2	91.64	78.78
		160MVA 220/132KV T/F-II	124	66.68	88.93	105.09	102.6	102.6	110.4	76.63	90.02	103.2	109.8	78.78
		80MVA 132/33KV T/F-I	52	44.41	50.48	57.09	64.2	64.17	65.52	53.56	45.75	62.21	50.09	49.35
		80MVA 132/33KV T/F-II	52	44.41	50.48	57.09	64.2	64.17	65.52	53.56	45.75	62.21	50.09	49.35
		50MVA 220/33KV T/F-I	26	21.21	23.95	27.70	28.1	28.11	37.12	24.06	24.23	24.82	25.41	28.03
		50MVA 220/33KV T/F-II	26	26.7	23.95	27.70	28.1	28.11	41.67	24.06	24.23	24.82	25.41	28.03
8	132KV S/s Rudrapur	40MVA 132/33KV T/F-I	25	23	34	34.00	26.0	31	21	14	20	28	21	22
		40MVA 132/33KV T/F-II	25	23	34	34.00	26.0	31	21	14	20	28	21	22
		20MVA 132/33KV T/F	9	8	10	10.00	9.0	9	9	7.4	8	9	9	9
9	132KV S/s Kichha	40MVA 132/33KV T/F-I	29.27	27.26	30.92	33.11	32.0	32.47	30.79	26.92	33.96	34.85	31.17	32.54
		40MVA 132/33KV T/F-II	29.27	27.26	30.92	33.11	32.0	32.47	30.79	26.92	33.96	34.85	31.17	27.91
		40MVA 132/33KV T/F-III	12.6	14.19	16.32	17.61	16.2	15.27	14.95	12.28	16.61	14.73	14.81	34.1
10	220KV S/s Jafarpur	50MVA 220/33KV T/F-I	-	6.86	8.05	21.00	22.0	11	11	9	12.67	13.68	12.96	15.4
		50MVA 220/33KV T/F-II	-	6.86	8.15	21.00	22.0	11	11	9	12.38	13.23	12.78	15.13
11	132KV S/s Sitraganj	40MVA 132/33KV T/F-I	15.7	16	20.18	24.14	23.7	30.21	24.8	12.89	14	15.76	19	21.65
		40MVA 132/33KV T/F-II	15.7	16	20.18	24.14	23.7	20.6	29.19	12.89	14	23.55	19	23.82
12	132KV S/s ELDECO Sitraganj	40MVA 132/33KV T/F-I	19	19.51	25.66	21.22	21.7	22.24	21.49	17.7	17.73	19.44	19.21	21
		40MVA 132/33KV T/F-II	19	19.51	20.02	21.22	21.7	22.24	21.49	17.7	17.73	19.44	19.21	21
13	220KV S/s Haldwani	100MVA 220/132KV T/F-I	48.44	43.39	45.48	43.98	38.9	38.32	44.67	44.43	46.28	49.24	47.96	53.31
		100MVA 220/132KV T/F-II	49.25	43.39	48.27	43.98	38.9	38.32	44.67	44.43	62.8	49.24	47.96	47.39
		40MVA 132/33KV T/F-I	32.7	27.4	32.63	34.27	29.2	32.63	33.34	33.54	36.6	36.03	29	24.15
		40MVA 132/33KV T/F-II	33.13	27.4	32.63	34.27	29.2	32.63	31.51	33.54	36.6	36.03	25.64	26.09
		40MVA 132/33KV T/F-III	-	-	-	-	-	-	-	-	-	28.34	29	24.16
14	132KV S/s Haldwani	40MVA 132/33KV T/F-I	34.14	18.26	28.15	27.28	23.1	22	20.68	19.2	17.74	18.26	23.1	23.42
		40MVA 132/33KV T/F-II	32.4	19.36	25.51	28.6	29.1	23.54	22.22	20.57	18.62	19.8	26	24.99
15	132KV S/s Bhowali	3x5MVA 132/33KV T/F-I	6.9	6.7	9.9	9.9	8.8	11.2	7.9	9.67	11.3	11.78	11.9	10.03
		3x5MVA 132/33KV T/F-II	7.3	7.18	9.2	9.2	9.5	12.25	8.9	10.5	12.2	12.8	12.8	10.9
		20MVA 132/33 T/F	7.8	7.9	8.5	8.5	9.6	8.8	9.5	12.28	16.1	17	13.9	14.1
16	132KV S/s Almora	20MVA 132/33KV T/F-II	12.57	12.12	12.57	16.23	14.0	13.72	13.72	18.52	18.29	16.69	17.15	17.15
		20MVA 132/33KV T/F-III	13.72	11.89	12.57	16.23	14.0	13.49	13.72	18.75	18.52	16.92	17.15	17.38
17	132KV S/s Pithoragarh	3x5MVA 132/33KV T/F-I	9.1	8.5	8.6	8.60	10.5	7.8	8.5	9.5	13	12.8	12.4	11.4
		3x5MVA 132/33KV T/F-II	9.1	8.5	8.6	8.60	11.3	7.8	8.5	9.5	13	12.8	12.4	11.4
		20MVA 132/33KV T/F-I	14.4	13	12.5	12.50	14.0	13.2	13	16	18.5	19	18.8	18.5
		20MVA 132/33KV T/F-II	15.6	13	12.5	12.50	14.0	15.4	13	16	18.5	19	18.8	18.5
18	132KV S/s Ranikhet	15MVA 132/33KV T/F-I	6.86	6.63	6.17	6.17	6.9	6.17	9.83	6.86	7.32	7.32	12.57	6.63
		15MVA 132/33KV T/F-II	6.86	6.63	6.17	6.17	6.9	6.17	6.4	6.86	7.32	7.32	7.09	6.63
		20MVA 132/33KV T/F	10.97	9.6	11.45	11.43	9.6	9.83	10.29	9.83	11.2	11.66	9.83	10.52
19	132KV S/s Bageshwar	3x7MVA 132/33KV T/F-I	3.3	4.8	8.3	8.30	8.3	8.3	9.5	9.1	4.7	6.4	5.6	4.3
		3x7MVA 132/33KV T/F-II	3.6	4.8	8.3	8.30	8.3	8.3	9.5	9.1	4.7	6.4	5.6	4.3

**MAXIMUM LOAD IN AMPERE ON DIFFERENT 400/220/132KV FEEDERS UNDER THE
JURISDICTION OF O&M, Kumaon Zone, PTCUL, FOR THE MONTH OF 03/2022**

Name of S/s	Name of Line	Apr 21	May 21	Jun 21	Jul 21	Aug 21	Sep 21	Oct 21	Nov 21	Dec 21	Jan 22	Feb 22	Mar 22
1	400KV S/s Kashipur												
	400KV Moradabad-Kashipur Line	198	211	190	258	146	0	224	244	307	302	247	195
	400KV Nainital-Kashipur Line	370	325	336	327	278	0	332	437	449	415	541	363
	400KV Roorkee Ist Ckt	457	419	421	348	488	406	530	633	665	572	624	465
	400KV Roorkee IInd Ckt	457	420	421	351	488	407	530	649	665	606	636	465
	400KV Bareilly Ist Ckt	699	659	590	510	672	540	724	914	960	936	885	716
	400KV Bareilly IInd Ckt	690	570	590	599	668	540	724	914	960	900	885	716
	220KV Jafarpur	319	259	262	349	385	450	373	140	314	190	178	322
	220KV Pantnagar Line-II ckt	364	331	355	393	391	361	414	152	344	210	192	287
	220KV Mahuakheraganj Line-II ckt	326	299	270	368	265	282	135	116	116	131	129	115
	220KV M/s SEPL Line	327	302	281	480	264	440	101	87	87	97	97	139
	132KV Ramnagar Line	190	198	314	376	190	303	277	241	231	350	206	186
	132KV Kashipur-I Line	224	279	243	340	348	278	296	251	308	307	342	323
	132KV Kashipur-II Line	155	187	197	260	298	231	226	202	247	248	265	352
	132KV Bazpur Line	272	247	284	310	282	291	311	228	289	304	294	308
	132KV Jaspur Line	301	325	371	333	318	299	276	229	253	4	291	4
2	220KV S/s Mahuakheraganj												
	220KV M/s SEPL Line	258	240	252	384	350	355	209	135	84	96	96	132
	220KV M/s GIPL Line	264	255	262	280	269	262	0	0	0	0	0	0
	220KV (400KV) Kashipur Line	327	293	275	351	275	280	142	112	112	128	128	112
	132KV Kashipur Line	347	310	352	402	331	382	242	220	222	235	252	232
3	132KV S/s Jaspur												
	132KV Thakurdwara Line	4	4	4	4	4	4	4	4	4	4	4	4
4	132KV S/s Kashipur												
	132KV Kashipur-Jaspur Line	311	334	386	334	322	307	286	226	254	0	285	0
	132KV Kalagarh-Jaspur Line	141	237	217	8	0	0	340	245	259	291	322	274
	400KV-132KV S/s Kashipur Line-I	223	283	259	359	361	286	303	258	327	333	344	326
	400KV-132KV S/s Kashipur Line-II	170	191	196	290	285	212	234	210	263	269	249	327
	132KV Mahuakheraganj Line	354	311	369	422	324	382	246	233	219	240	251	253
	132KV Kashipur-Bazpur Line	281	186	270	232	296	320	320	142	200	202	250	214
5	132KV S/s Bazpur												
	132KV KVS Line	171	164	171	171	175	179	175	171	181	172	174	172
	132KV IGL Line	81	83	82	84	87	85	92	85	91	78	75	86
	132KV Kashipur-Bazpur Line	235	202	300	244	300	245	302	151	217	210	233	235
	400KV Kashipur-132KV Bazpur Line	275	252	300	302	277	290	313	221	307	312	282	300
6	132KV S/s Ramnagar												
	132KV Haldwani-Bazpur Line	179	293	179	360	172	205	256	102	228	176	232	223
7	220KV S/s Pantnagar												
	132KV Polyplex Line	36	38	39	41	40	39	39	39	39	36	39	39
	132KV Kalagarh-Ramnagar Line	215	200	187	206	164	158	192	157	270	294	316	268
	132KV Ramnagar-400KV S/s Line	310	203	314	393	193	297	273	247	226	355	219	201
	220KV Baikunthapur-Pantnagar Line	473	385	483	476	550	465	569	568	592	643	620	478
	220KV Pantnagar-Haldwani Line	230	227	231	319	209	208	242	248	242	272	260	250
	220KV Pantnagar-Jafarpur	326	266	233	333	341	430	335	122	267	181	153	294
	220KV Pantnagar-Kashipur Line	384	345	316	406	409	427	427	196	350	226	208	312
8	132KV S/s Rudrapur												
	220KV TATA Line	18	14	18	20	21	21	20	18	15	16	6	16
	132KV Pantnagar-Rudrapur Line	552	223	447	612	535	316	392	299	423	531	412	291
	132KV Pantnagar-Haldwani Line	264	142	101	163	145	105	185	164	163	196	121	146
9	132KV S/s Kichha												
	132KV Hindustan Zinc Line	44	42	42	43	42	41	43	42	54	39	40	39
	132KV Rudrapur-Kichha Line	312	225	450	296	532	499	421	307	420	655	428	231
	132KV Rudrapur-Kichha Line	547	0	288	584	335	302	293	220	280	374	314	64
9	132KV S/s Kichha												
	132KV Rudrapur-Kichha Line	320	0	281	286	350	302	287	233	282	350	322	59
	132KV C.P.P Line	46	46	33	32	51	47	45	42	47	46	46	36
9	132KV S/s Kichha												
	132KV Sitarganj Line	337	328	372	401	412	394	366	300	336	360	328	344
9	132KV S/s Kichha												
	132KV Richha Line	6	6	6	6	6	6	6	40	6	6	6	6

S. No	Name of S/s	Name of Line	Apr 21	May 21	Jun 21	Jul 21	Aug 21	Sep 21	Oct 21	Nov 21	Dec 21	Jan 22	Feb 22	Mar 22
10	220KV S/s Jafarpur	220KV Kashipur-Jafarpur Line	-	253	248	332	347	443	371	148	305	200	195	315
		220KV Jafarpur-Pantnagar Line	-	238	230	303	319	417	333	123	257	190	146	261
11	132KV S/s Sitarganj	132KV Pilibhit Line	230	178	194	182	172	147	134	117	198	179	203	195
		132KV Kichha Line	326	318	340	362	408	365	349	287	312	333	310	333
		132KV PGCIL Ist	192	185	225	244	264	264	224	188	172	323	174	155
		132KV PGCIL IInd	118	109	158	167	159	159	276	117	105	205	106	98
		132KV Khatima Line	170	163	156	190	176	167	143	90	138	116	157	157
12	132KV S/s ELDECO Sitarganj	132KV PGCIL Line	244	238	250	272	272	270	282	232	226	260	246	270
		132KV Balaji Action	80	80	84	88	90	85	90	86	82	86	86	90
13	132KV LHPH	132KV Lohiahead Pilibhit line	258	258	234	221	221	200	173	178	210	211	206	209
14	220KV S/s Haldwani	220KV Pantnagar-Haldwani Line	224	228	248	330	212	208	238	240	250	268	264	258
		132KV Haldwani-Bezpur Line	186	289	187	343	158	191	275	104	266	168	193	208
15	132KV S/s Haldwani	132KV Pantnagar Line	262	98	121	182	120	104	186	142	173	164	163	143
		132KV Kamalaganja-Haldwani Lin	309	323	279	250	249	233	326	205	289	328	308	328
16	132KV S/s Bhowali	132KV Haldwani-Bhowali Line	236	206	238	185	231	210	217	226	279	356	226	264
		132KV Bhowali-Almora Line	154	195	240	238	281	266	251	186	136	236	167	182
17	132KV S/s Almora	132KV Bhowali-Almora Line	144	197	245	230	284	265	230	187	132	240	163	143
		132KV Almora-Ranikhet Line	97	100	92	85	78	81	105	104	130	148	129	126
		132KV Almora-Pithoragarh-Chanda	308	250	293	306	330	317	301	302	357	334	325	273
18	132KV S/s Pithoragarh	132KV Almora-Pithoragarh Line	0	0	137	137	0	0	18	109	0	74	0	0
		132KV PGCIL Chandak Line	189	188	163	163	184	177	174	222	269	275	271	267
19	132KV S/s Ranikhet	132KV Almora-Ranikhet Line	102	100	97	84	79	65	107	82	135	162	142	138
		132KV Ranikhet-Bageshwar Line	32	43	75	82	61	65	89	102	45	62	44	41
20	132KV S/s Bageshwar	132KV Ranikhet-Bageshwar Line	30	40	73	78	78	78	82	78	46	62	52	42

(D. C. PANDE)
CHIEF ENGINEER (O&M)

MAXIMUM LOAD IN MVA ON TRANSFORMER OF DIFFERENT 400/220/132KV S/s UNDER THE JURISDICTION OF O&M, KUMAON ZONE, PTCUL FOR THE MONTH OF 05/2022

S. No	Name of S/s	Name of T/F & Voltage	Apr 22	May 22	Jun 22	Jul 22	Aug 22	Sep 22	Oct 22	Nov 22	Dec 22	Jan 23	Feb 23	Mar 23
1	400KV S/s Kashipur	315MVA 400/220KV T/F-I	277	253										
		315MVA 400/220KV T/F-II	277	253										
		160MVA 220/132KV T/F-I	10	118										
		160MVA 220/132KV T/F-II	105	116										
2	220KV S/s Mahaukherag anj	100MVA 220/132KV T/F-I	41.53	48.39										
		100MVA 220/132KV T/F-II	41.53	48.39										
		80MVA 132/33KV T/F-I	24	41.15										
		80MVA 132/33KV T/F-II	24	29.49										
3	132KV S/s Jaspur	40MVA 132/33KV T/F-I	32	31										
		40MVA 132/33KV T/F-II	32	33										
		40MVA 132/33KV T/F-III	14	16										
4	132KV S/s Kashipur	40MVA 132/33KV T/F-I	29.8	30.7										
		40MVA 132/33KV T/F-II	22	28.4										
		40MVA 132/33KV T/F-III	22	28.4										
5	132KV S/s Bazpur	40MVA 132/33KV T/F	29.3	30.4										
		80MVA 132/33KV T/F	58.8	62.2										
6	132KV S/s Ramnagar	40MVA 132/33KV T/F	28.8	28.4										
		20MVA 132/33KV T/F	17.8	18.3										
7	220KV S/s Pantnagar	160MVA 220/132KV T/F-I	107.5	106.5										
		160MVA 220/132KV T/F-II	107.5	106.5										
		80MVA 132/33KV T/F-I	54.06	61.13										
		80MVA 132/33KV T/F-II	64.43	61.13										
		50MVA 220/33KV T/F-I	35.77	30.5										
		50MVA 220/33KV T/F-II	29.34	30.5										
8	132KV S/s Rudrapur	40MVA 132/33KV T/F-I	29	33										
		40MVA 132/33KV T/F-II	29	33										
		20MVA 132/33KV T/F	10	10										
9	132KV S/s Kichha	40MVA 132/33KV T/F-I	32.54	32.96										
		40MVA 132/33KV T/F-II	27.91	32.96										
		40MVA 132/33KV T/F-III	34.01	28.14										
10	220KV S/s Jafarpur	50MVA 220/33KV T/F-I	16.57	16.3										
		50MVA 220/33KV T/F-II	17.02	16.48										
11	132KV S/s Sitraganj	40MVA 132/33KV T/F-I	19.46	24.69										
		40MVA 132/33KV T/F-II	19.46	24.69										
12	132KV S/s ELDECO Sitragani	40MVA 132/33KV T/F-I	22.88	23.94										
		40MVA 132/33KV T/F-II	22.88	23.94										
13	220KV S/s Haldwani	100MVA 220/132KV T/F-I	44.12	63.88										
		100MVA 220/132KV T/F-II	44.12	63.88										
		40MVA 132/33KV T/F-I	22.44	29.01										
		40MVA 132/33KV T/F-II	25.96	25.96										
		40MVA 132/33KV T/F-III	22.44	25.95										
14	132KV S/s Haldwani	40MVA 132/33KV T/F-I	27.98	30.43										
		40MVA 132/33KV T/F-II	30.15	32.54										
15	132KV S/s Bhowali	3x5MVA 132/33KV T/F-I	9.6	10										
		3x5MVA 132/33KV T/F-II	9.6	9.8										
		20MVA 132/33 T/F	11.4	10.5										
16	132KV S/s Almora	20MVA 132/33KV T/F-II	12.57	14.17										
		20MVA 132/33KV T/F-III	12.57	13.72										
17	132KV S/s Pithoragarh	3x5MVA 132/33KV T/F-I	8.23	8										
		3x5MVA 132/33KV T/F-II	8.23	8										
		20MVA 132/33KV T/F-I	13.49	16.23										
		20MVA 132/33KV T/F-II	13.49	15.55										
18	132KV S/s Ranikhet	15MVA 132/33KV T/F-I	5.72	6.17										
		15MVA 132/33KV T/F-II	6.4	6.17										
		20MVA 132/33KV T/F	9.14	11.89										
19	132KV S/s Bageshwar	3x7MVA 132/33KV T/F-I	11	2.97										
		3x7MVA 132/33KV T/F-II	11	2.97										

(D.C. PANDE)
CHIEF ENGINEER (O&M)

JURISDICTION OF O&M, Kumaon Zone, PTCUL, FOR THE MONTH OF 05/2022

S. No	Name of S/s	Name of Line	Apr 22	May 22	Jun 22	Jul 22	Aug 22	Sep 22	Oct 22	Nov 22	Dec 22	Jan 23	Feb 23	Mar 23
1	400KV S/s Kashipur	400KV Moradabad-Kashipur Line	187	190										
		400KV Nehtaur-Kashipur Line	448	396										
		400KV Roorkee Ist Ckt	408	467										
		400KV Roorkee IInd Ckt	408	467										
		400KV Bareilly Ist Ckt	783	736										
		400KV Bareilly IInd Ckt	767	736										
		220KV Jafarpur	359	331										
		220KV Pantnagar Line-II ckt	386	363										
		220KV Mahuakheraganj Line-II ckt	128	199										
		220KV M/s SEPL Line	96	111										
		132KV Ramnagar Line	188	327										
		132KV Kashipur-I Line	371	4										
		132KV Kashipur-II Line	280	283										
		132KV Bazpur Line	310	354										
		132KV Jaspur Line	4	340										
2	220KV S/s Mahuakheraganj	220KV M/s SEPL Line	92	106										
		220KV M/s GIPL Line	0	0										
		220KV (400KV) Kashipur Line	126	195										
		132KV Kashipur Line	212	268										
		132KV Thakurdwara Line	4	4										
3	132KV S/s Jaspur	132KV Kashipur-Jaspur Line	0	345										
		132KV Kalagarh-Jaspur Line	337	346										
4	132KV S/s Kashipur	400KV-132KV S/s Kashipur Line-I	386	383										
		400KV-132KV S/s Kashipur Line-II	385	288										
		132KV Mahuakheraganj Line	211	270										
		132KV Kashipur-Bazpur Line	203	270										
		132KV KVS Line	176	176										
		132KV IGL Line	87	95										
5	132KV S/s Bazpur	132KV Kashipur-Bazpur Line	231	294										
		400KV Kashipur-132KV Bazpur Line	307	342										
		132KV Haldwani-Bazpur Line	203	368										
		132KV Polyplex Line	32	43										
6	132KV S/s Ramnagar	132KV Kalagarh-Ramnagar Line	262	284										
		132KV Ramnagar-400KV S/s Line	184	332										
7	220KV S/s Pantnagar	220KV Baikunthapur-Pantnagar Line	598	617										
		220KV Pantnagar-Haldwani Line	252	370										
		220KV Pantnagar-Jafarpur	314	340										
		220KV Pantnagar-Kashipur Line	408	390										
		220KV TATA Line	19	19										
		132KV Pantnagar-Rudrapur Line	532	532										
		132KV Pantnagar-Haldwani Line	123	123										
		132KV Hindustan Zinc Line	41	41										
8	132KV S/s Rudrapur	132KV Pantnagar-Rudrapur Line	534	573										
		132KV Rudrapur-Kichha Line	336	362										
9	132KV S/s Kichha	132KV Rudrapur-Kichha Line	336	368										
		132KV C.P.P Line	46	46										
		132KV Sitarganj Line	344	355										
		132KV Richha Line	6	6										

S. No	Name of S/s	Name of Line	Apr 22	May 22	Jun 22	Jul 22	Aug 22	Sep 22	Oct 22	Nov 22	Dec 22	Jan 23	Feb 23	Mar 23
10	220KV S/s Jafarpur	220KV Kashipur-Jafarpur Line	323	347										
		220KV Jafarpur-PantnagarLine	289	321										
11	132KV S/s Sitarganj	132KV Pilibhit Line	215	191										
		132KV Kichha Line	333	341										
		132KV PGCIL Ist	170	186										
		132KV PGCIL Iind	110	122										
		132KV Khatima Line	178	200										
12	132KV S/s ELDECO Sitarganj	132KV PGCIL Line	282	300										
		132KV Balaji Action	90	90										
13	132KV LHPH	132KV Lohiahead Pilibhit line	248	200										
14	220KV S/s Haldwani	220KV Pantnagar-Haldwani Line	250	362										
		132KV Haldwani-Bazpur Line	205	362										
15	132KV S/s Haldwani	132KV Pantnagar Line	132	158										
		132KV Kamaluaganja-Haldwani Lin	367	383										
16	132KV S/s Bhowali	132KV Haldwani-Bhowali Line	201	244										
		132KV Bhowali-Almora Line	238	254										
17	132KV S/s Almora	132KV Bhowali-Almora Line	240	271										
		132KV Almora-Ranikhet Line	88	95										
		132KV Almora-Pithoragarh-Chanda	306	345										
18	132KV S/s Pithoragarh	132KV Almora-Pithoragarh Line	19	88										
		132KV PGCIL Chandak Line	161	168										
19	132KV S/s Ranikhet	132KV Almora-Ranikhet Line	96	103										
		132KV Ranikhet-Bageshwar Line	24	26										
20	132KV S/s Bageshwar	132KV Ranikhet-Bageshwar Line	22	26										

(D.C. PANDE)
CHIEF ENGINEER (O&M)