

MAXIMUM LOAD IN MVA ON TRANSFORMER OF DIFFERENT 400/220/132KV S/s UNDER THE JURIDICITION OF O&M, KUMAON ZONE, PTCUL FOR THE MONTH OF 06/2023

S. No	Name of S/S	Name of T/F & Voltage	Apr 23	May 23	Jun 23	Jul 23	Aug 23	Sep 23	Oct 23	Nov 23	Dec 23	Jan 24	Feb 24	Mar 24
1	400KV S/s Kashipur	315MVA 400/220KV T/F-I	163	260	222									
		315MVA 400/220KV T/F-II	163	260	222									
		160MVA 220/132KV T/F-I	90	101	106									
		160MVA 220/132KV T/F-II	90	101	106									
		160MVA 220/132KV T/F-III	90	101	106									
2	220KV S/s Mahaukhera ganj	100MVA 220/132KV T/F-I	55.63	56.01	61.34									
		100MVA 220/132KV T/F-II	55.63	56.01	61.34									
		80MVA 132/33KV T/F-I	26.97	26.97	29.72									
		80MVA 132/33KV T/F-II	26.97	26.97	29.72									
3	132KV S/s Jaspur	40MVA 132/33KV T/F-I	36	34	36									
		40MVA 132/33KV T/F-II	33	34	36									
		40MVA 132/33KV T/F-III	12	16	19									
4	132KV S/s Kashipur	40MVA 132/33KV T/F-I	23.9	30.9	33.2									
		40MVA 132/33KV T/F-II	23	32	31.8									
		40MVA 132/33KV T/F-III	23	32	31.8									
5	132KV S/s Bazpur	40MVA 132/33KV T/F	29.1	32.5	36.2									
		80MVA 132/33KV T/F	67.5	68.9	73.7									
6	132KV S/s Ramnagar	40MVA 132/33KV T/F	24.3	36.8	40.7									
		20MVA 132/33KV T/F	15.6	18.8	19									
7	220KV S/s Pantnagar	160MVA 220/132KV T/F-I	103	108	115									
		160MVA 220/132KV T/F-II	103	129	115									
		80MVA 132/33KV T/F-I	52	53	55									
		80MVA 132/33KV T/F-II	52	53	55									
		50MVA 220/33KV T/F-I	29	28	40									
		50MVA 220/33KV T/F-II	29	28	31									
8	132KV S/s Rudrapur	40MVA 132/33KV T/F-I	23	30	29									
		40MVA 132/33KV T/F-II	23	30	29									
		20MVA 132/33KV T/F	9	9	10									
9	132KV S/s Kichha	40MVA 132/33KV T/F-I	26.83	29.825	29.83									
		40MVA 132/33KV T/F-II	26.83	29.825	29.83									
		40MVA 132/33KV T/F-III	18.5	22.98	22.98									
10	220KV S/s Jafarpur	50MVA 220/33KV T/F-I	16	18	20									
		50MVA 220/33KV T/F-II	16	19	21									
11	132KV S/s Sitraganj	40MVA 132/33KV T/F-I	22.37	20	25									
		40MVA 132/33KV T/F-II	22.37	20	25									
12	132KV S/s ELDECO Sitraganj	40MVA 132/33KV T/F-I	14.29	14.6	15.19									
		40MVA 132/33KV T/F-II	14.29	14.6	15.19									
		40MVA 132/33KV T/F-III	14.29	14.6	15.19									
13	220KV S/s Haldwani	100MVA 220/132KV T/F-I	46.43	67.08	59.51									
		100MVA 220/132KV T/F-II	46.43	67.08	64.05									
		40MVA 132/33KV T/F-I	18.64	20.98	32.39									
		40MVA 132/33KV T/F-II	19.79	24.22	26.8									
		40MVA 132/33KV T/F-III	18.64	20.98	32.39									
14	132KV S/s Haldwani	40MVA 132/33KV T/F-I	26.96	28.6	30									
		40MVA 132/33KV T/F-II	27.28	30.82	32.12									
15	132KV S/s Bhowali	20MVA 132/33 T/F-I	14.2	12.02	13.16									
		3x5MVA 132/33KV T/F-II	8.52	8.09	7.24									
		20MVA 132/33 T/F-III	14.05	12.01	13.16									
16	132KV S/s Almora	20MVA 132/33KV T/F-II	15.78	10.52	10.75									
		20MVA 132/33KV T/F-III	16.23	10.75	10.75									
17	132KV S/s Pithoragarh	3x5MVA 132/33KV T/F-I	10.29	8.46	8									
		3x5MVA 132/33KV T/F-II	10.29	8.46	8									
		20MVA 132/33KV T/F-I	17.15	16.23	13.72									
		20MVA 132/33KV T/F-II	17.15	16.23	13.72									
18	132KV S/s Ranikhet	15MVA 132/33KV T/F-I	9.14	8.92	8.23									
		15MVA 132/33KV T/F-II	9.14	8.92	8.23									
		20MVA 132/33KV T/F	11.2	12.12	10.97									
19	132KV S/s Bageshwar	3x7MVA 132/33KV T/F-I	6.17	6.86	6.17									
		3x7MVA 132/33KV T/F-II	6.17	6.86	6.17									


 (H.S. HYANKI)
 CHIEF ENGINEER (O&M)