

## Daily Generation Report of 28 July- 2025

Reporting Date 29 July - 2025

| SL NO                                                                                                                                                                                         | Name Of Power Station | CAPACITY (MW)  | GENERATION OF THE DAY (MU) |        |        |        |        | Cumulative Gen. of the month till date (MU) | Cumulative Gen. in FY till date (MU) | LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU) |                                 |                                     |                      |                |                         |       | Declared Capacity (MW)/ Peak Load | PAF of the Day | Av PAF of the month | Generation in M/E Peaking hrs (MU) | Remarks                                        |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------|----------------|----------------------------|--------|--------|--------|--------|---------------------------------------------|--------------------------------------|---------------------------------------------------------------------------------|---------------------------------|-------------------------------------|----------------------|----------------|-------------------------|-------|-----------------------------------|----------------|---------------------|------------------------------------|------------------------------------------------|
|                                                                                                                                                                                               |                       |                | Unit-1                     | Unit-2 | Unit-3 | Unit-4 | Total  |                                             |                                      | B/D of Equipment                                                                | System Condition & Grid Failure | Flushing & choking / High Head Loss | Flood Pass/ High PPM | Planned Outage | Unusual & Other Reasons | Total |                                   |                |                     |                                    |                                                |
| 1                                                                                                                                                                                             | CHIBRO                | 4x60=240       | 1.293                      | 1.258  | 1.066  | 1.208  | 4.825  | 126.105                                     | 300.831                              |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 200                               | 84             | 84                  | 0.600                              |                                                |
| 2                                                                                                                                                                                             | KHODRI                | 4x 30 = 120    | 0.550                      | 0.538  | 0.559  | 0.525  | 2.172  | 57.029                                      | 143.933                              |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 90                                | 76             | 75                  | 0.270                              |                                                |
| 3                                                                                                                                                                                             | DHAKRANI              | 3x11.25=33.75  | 0.292                      | RMU    | 0.244  |        | 0.536  | 12.913                                      | 44.365                               |                                                                                 |                                 |                                     |                      | 0.192          |                         | 0.192 | 22                                | 66             | 64                  | 0.066                              | Unit 2 is in RMU since 15.03.2025              |
| 4                                                                                                                                                                                             | DHALIPUR              | 3x17 = 51      | 0.401                      | 0.398  | 0.396  |        | 1.196  | 28.242                                      | 78.550                               |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 50                                | 99             | 99                  | 0.150                              |                                                |
| 5                                                                                                                                                                                             | KULHAL                | 3x 10= 30      | 0.242                      | 0.230  | 0.236  |        | 0.708  | 17.078                                      | 49.380                               |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 29.5                              | 99             | 99                  | 0.089                              |                                                |
| 6                                                                                                                                                                                             | TILOTH (MB-I)         | 3x30=90        | 0.724                      | 0.725  | 0.621  |        | 2.070  | 49.190                                      | 216.241                              |                                                                                 |                                 |                                     | 0.090                |                |                         | 0.090 | 94.5                              | 106            | 93                  | 0.284                              | Due to High PPM                                |
| 7                                                                                                                                                                                             | DHARASU (MB-II)       | 4x 76 = 304    | 1.785                      | 1.659  | 1.702  | 1.462  | 6.608  | 187.972                                     | 589.042                              | 0.140                                                                           |                                 |                                     | 0.245                |                |                         | 0.385 | 294                               | 98             | 100                 | 0.882                              | Due to TGB vibration high in Unit 4 & High PPM |
| 8                                                                                                                                                                                             | CHILLA                | 4x 36 = 144    | 0.629                      | 0.837  | 0.725  | RMU    | 2.191  | 58.834                                      | 239.721                              |                                                                                 |                                 |                                     |                      | 0.720          |                         | 0.720 | 90                                | 63             | 65                  | 0.270                              | Unit 4 is in RMU since 07.11.2024              |
| 9                                                                                                                                                                                             | RAMGANGA              | 3x 66 = 198    | RO                         | RO     | RO     |        | 0.000  | 0.000                                       | 119.341                              |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 0                                 | 0              | 0                   | 0.000                              |                                                |
| 10                                                                                                                                                                                            | KHATIMA               | 3x 13.8 =41.40 | 0.172                      | 0.082  | 0.121  |        | 0.375  | 23.151                                      | 79.333                               |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 37                                | 90             | 92                  | 0.111                              |                                                |
| 11                                                                                                                                                                                            | VYASI                 | 2x60=120       | 1.454                      | 1.471  |        |        | 2.925  | 64.261                                      | 98.408                               |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 120                               | 101            | 97                  | 0.360                              |                                                |
| 12                                                                                                                                                                                            | PATHRI                | 3x8.8=20.4     | 0.128                      | 0.115  | 0.127  |        | 0.371  | 9.090                                       | 42.814                               |                                                                                 | 0.009                           |                                     |                      |                |                         | 0.009 | 20.4                              |                |                     | 0.061                              | Due to Grid disturbance                        |
| 13                                                                                                                                                                                            | MOHD. PUR             | 3x 3.1 =9.30   | 0.056                      | 0.054  | 0.057  |        | 0.167  | 4.440                                       | 17.794                               | 0.005                                                                           |                                 |                                     |                      |                |                         | 0.005 | 7.6                               |                |                     | 0.023                              | Due to Excitation problem in Unit 2            |
| 14                                                                                                                                                                                            | GALOGI                | 3X1+0.5 = 3.5  | RO                         | 0.008  | 0.003  | 0.022  | 0.034  | 0.690                                       | 2.123                                |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 1.0                               |                |                     | 0.006                              |                                                |
| 15                                                                                                                                                                                            | DUNAO                 | 2x.75=1.5      | 0.005                      | 0.011  |        |        | 0.017  | 0.377                                       | 1.02                                 |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 0.8                               |                |                     | 0.004                              |                                                |
| 16                                                                                                                                                                                            | PILANG GAD            | 2x1.125=2.25   | 0.002                      | 0.002  |        |        | 0.004  | 0.119                                       | 1.603                                |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 1.2                               |                |                     | 0.000                              |                                                |
| 17                                                                                                                                                                                            | URGAM                 | 2x1.5=3.00     | 0.011                      | 0.002  |        |        | 0.013  | 0.631                                       | 2.900                                |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 1.5                               |                |                     | 0.003                              |                                                |
| 18                                                                                                                                                                                            | KALIGANGA-I           | 2x2=4.00       | 0.021                      | RO     |        |        | 0.021  | 0.482                                       | 2.676                                |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 1.2                               |                |                     | 0.005                              |                                                |
| 19                                                                                                                                                                                            | KALIGANGA-II          | 2x2.25=4.5     | 0.010                      | 0.026  |        |        | 0.035  | 0.957                                       | 3.237                                |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 4.2                               |                |                     | 0.014                              |                                                |
| 20                                                                                                                                                                                            | SURINGAD-II           | 2x2.5=5        | 0.045                      | 0.040  |        |        | 0.086  | 1.574                                       | 3.662                                |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 4.1                               |                |                     | 0.031                              |                                                |
| 21                                                                                                                                                                                            | MADHYAMAHESHWAR       | 3x5=15         | 0.040                      | 0.010  | RO     |        | 0.050  | 2.427                                       | 13.858                               |                                                                                 |                                 |                                     |                      |                |                         | 0.000 | 6.0                               |                |                     | 0.010                              |                                                |
| TOTAL                                                                                                                                                                                         |                       | 1440.60        |                            |        |        |        | 24.403 | 645.562                                     | 2050.832                             | 0.145                                                                           | 0.009                           | 0.000                               | 0.335                | 0.912          | 0.000                   | 1.401 | 1075.00                           |                |                     | 3.238                              |                                                |
| AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning |                       |                |                            |        |        |        |        |                                             |                                      |                                                                                 |                                 |                                     |                      |                |                         |       |                                   |                |                     |                                    |                                                |

Distributed to:-

Chairman /Principal Secretary(Energy) Govt of Uttarakhand.

MD UJVNL/MD UPCL

Director(Operation) /Director(Project)/Director(Finance)/ Director(HR)

Dy. General Manager (Technical)