

Reporting Date 30 October - 2025

Reporting Date 30 October - 2025																					
SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. in FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total					
1	CHIBRO	4x60=240	0.606	0.199	1.182	PO	1.987	74.710	622.689							0.000	158	67	77	0.474	Unit 4 is in AM since 24.10.2025
2	KHODRI	4x 30 = 120	0.511	0.096	0.423	PO	1.029	37.614	293.857							0.000	75	63	72	0.225	Unit 4 is in AM since 24.10.2025
3	DHAKRANI	3x11.25=33.75	0.251	0.186	0.055		0.492	18.961	91.765							0.000	33	98	99	0.099	
4	DHALIPUR	3x17 = 51	0.281	0.366	0.089		0.735	28.786	165.853							0.000	51	100	100	0.152	
5	KULHAL	3x 10= 30	0.203	0.119	0.202		0.523	18.125	104.014							0.000	29	97	99	0.087	
6	TILOTH (MB-I)	3x30=90	0.160	0.131	0.584		0.875	44.693	374.109							0.000	93	104	105	0.279	
7	DHARASU (MB-II)	4x 76 = 304	PO	1.407	0.390	0.271	2.068	95.303	1065.731							0.000	228	76	93	0.684	Unit 1 is in AM since 29.10.2025
8	CHILLA	4x 36 = 144	0.359	0.503	0.702	RMU	1.564	59.993	398.282							0.000	70	49	62	0.210	Unit 4 is in RMU since 07.11.2024
9	RAMGANGA	3x 66 = 198	RO	RO	FO		0.000	8.056	166.694							0.000	0	0	8	0.000	Unit 3 is in FO due to Generator problem since 21.10.2025
10	KHATIMA	3x 13.8 =41.40	0.320	0.317	0.079		0.716	18.615	144.080							0.000	33	81	71	0.099	
11	VYASI	2x60=120	0.596	0.189			0.785	36.8090	295.894							0.000	114	96	96	0.342	
12	PATHRI	3x6.8=20.4	RO	RO	0.142		0.142	1.962	58.263							0.000	6.8			0.020	
13	MOHD. PUR	3x 3.1 =9.30	0.046	RO	0.022		0.068	0.880	25.125			0.002				0.002	4.0			0.012	Due to Heavy Chocking
14	GALOGI	3X1+0.5 = 3.5	RO	0.010	RO	0.024	0.034	0.844	4.666							0.000	1.4			0.003	
15	DUNAO	2x.75=1.5	0.006	RO			0.006	0.286	1.79							0.000	0.7			0.007	
16	PILANG GAD	2x1.125=2.25	RO	RO			0.000	0.567	2.829							0.000	0.0			0.000	
17	URGAM	2x1.5=3.00	0.024	RO			0.024	0.232	3.232							0.000	1.2			0.001	
18	KALIGANGA-I	2x2=4.00	RO	0.030			0.030	1.068	5.190							0.000	2.0			0.012	
19	KALIGANGA-II	2x2.25=4.5	0.020	0.018			0.038	1.526	7.258							0.000	2.3			0.011	
20	SURINGAD-II	2x2.5=5	0.024	RO			0.024	1.718	8.891							0.000	2.2			0.011	
21	MADHYAMAHESHWAR	3x5=15	0.051	0.033	RO		0.084	2.160	19.760							0.000	5.0			0.028	
TOTAL		1440.60					11.225	452.907	3859.972	0.000	0.000	0.002	0.000	0.000	0.000	0.002	909.12			2.756	
AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning																					