

Daily Generation Report of 20 February 2026

Reporting Date 21 February 2026

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. in FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks	
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total						
1	CHIBRO	4x60=240	PO	RO	0.417	0.407	0.824	19.223	761.576							0.000	108	46	46	0.324	Unit 1 is in Capital Maintenance since 27.01.2026	
2	KHODRI	4x 30 = 120	PO	PO	0.198	0.224	0.422	9.867	364.910							0.000	55	23	23	0.165	Unit 1 is in Capital Maintenance since 28.01.2026 Unit 2 is in AM since 28.01.2026	
3	DHAKRANI	3x11.25=33.75	PO	0.155	RMU		0.155	0.239	117.913					0.028		0.028	12	5	1	0.036	Unit 3 is in RMU Since 30.10.2025 Unit 1 is in PO due to common S/D for RMU since 29.01.2026	
4	DHALIPUR	3x17 = 51	PO	0.158	0.116		0.274	6.211	214.520							0.000	33	14	14	0.099	Unit 1 is in AM since 13.02.2026	
5	KULHAL	3x 10= 30	0.019	0.153	0.035		0.207	4.610	138.725							0.000	20	8	8	0.060		
6	TILOTH (MB-I)	3x30=90	PO	PO	PO		0.000	6.663	459.266						0.642	0.642	0	0	21	0.000	Plant closure since 14.02.2026	
7	DHARASU (MB-II)	4x 76 = 304	0.721	PO	0.236	0.193	1.150	20.813	1222.324							0.000	192	81	78	0.576	Unit 2 is in AM since 03.02.2026	
8	CHILLA	4x 36 = 144	0.743	0.806	PO	RMU	1.549	31.440	581.356				0.248			0.248	65	27	28	0.195	Unit 3 is in AM since 26.01.2026 Unit 4 is in RMU since 07.11.2024	
9	RAMGANGA	3x 66 = 198	0.768	0.960	1.005		2.733	31.543	277.281							0.000	114	48	29	0.342		
10	KHATIMA	3x 13.8 =41.40	FO	PO	0.346		0.346	6.487	181.855	0.043						0.043	15	6	8	0.045	Unit 2 is in AM since 02.02.2026. Unit 1 is in FO since 18.02.2026 due to High Vibration	
11	VYASI	2x60=120	0.246	PO			0.246	5.092	339.266							0.000	60	25	25	0.180	Unit 2 is in AM since 27.01.2026	
12	PATHRI	3x6.8=20.4	0.025	0.160	0.160		0.346	5.499	90.108				0.033			0.033	16.3			0.049	Unit 1 is in Capital Maintenance since 20.02.2026	
13	MOHD. PUR	3x 3.1 =9.30	0.057	0.063	PO		0.120	2.382	40.516					0.008		0.008	5.6			0.017	Unit 3 is in Capital Maintenance since 02.02.2026	
14	GALOGI	3X1+0.5 = 3.5	RO	RO	RO	0.015	0.015	0.515	7.572							0.000	0.8			0.002		
15	DUNAO	2x.75=1.5	0.005	0.006			0.011	0.196	2.80							0.000	0.5			0.004		
16	PILANG GAD	2x1.125=2.25	0.016	0.018			0.034	0.658	5.456							0.000	1.5			0.009		
17	URGAM	2x1.5=3.00	0.036	RO			0.036	0.662	6.632							0.000	1.5			0.009		
18	KALIGANGA-I	2x2=4.00	RO	0.003			0.003	0.098	8.061							0.000	0.7			0.003		
19	KALIGANGA-II	2x2.25=4.5	0.012	0.018			0.030	0.574	11.096							0.000	1.3			0.007		
20	SURINGAD-II	2x2.5=5	0.020	RO			0.020	0.298	11.922							0.000	0.9			0.005		
21	MADHYAMAHESHWAR	3x5=15	RO	RO	0.084		0.084	1.610	30.899							0.000	5.0			0.038		
<b>TOTAL</b>		<b>1440.60</b>					<b>8.605</b>	<b>154.679</b>	<b>4874.052</b>	<b>0.043</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.317</b>	<b>0.642</b>	<b>1.003</b>	<b>708.07</b>				<b>2.163</b>	

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-  
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.  
 MD LUVNL/MD UPCL  
 Director(Operation) /Director(Project)/Director(Finance)/ Director(HR)

Dy. General Manager (Technical)