

Daily Generation Report of 04 February 2026

Reporting Date 05 February 2026

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. in FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW) Peak Load	PAF of the Day	Av PAF of the month	Generation In M/E Peaking hrs (MU)	Remarks
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total					
1	CHIBRO	4x60=240	PO	0.226	0.341	0.426	0.994	4.057	746.410							0.000	108	46	46	0.324	Unit 1 is in Capital Maintenance since 27.01.2026
2	KHODRI	4x 30 = 120	PO	PO	0.258	0.251	0.509	2.083	357.127							0.000	55	46	46	0.165	Unit 1 is in Capital Maintenance since 28.01.2026 Unit 2 is in AM since 28.01.2026
3	DHAKRANI	3x11.25=33.75	PO	PO	RMU		0.000	0.000	117.674					0.242		0.242	0	0	0	0.000	Unit 3 is in RMU Since 30.10.2025 Unit 1 & Unit 2 is in PO due to common S/D for RMU since 29.01.2026
4	DHALIPUR	3x17 = 51	0.208	0.155	RO		0.363	1.412	209.721							0.000	33	65	65	0.099	
5	KULHAL	3x 10= 30	PO	0.165	0.100		0.264	1.051	135.165							0.000	20	67	67	0.060	Unit 1 is in AM since 14.01.2026
6	TILOTH (MB-I)	3x30=90	0.097	0.145	0.251		0.493	2.087	454.690							0.000	80	90	90	0.240	
7	DHARASU (MB-II)	4x 76 = 304	0.613	PO	0.295	0.206	1.114	4.408	1205.919							0.000	212	70	67	0.636	Unit 2 is in AM since 03.02.2026
8	CHILLA	4x 36 = 144	0.765	0.819	PO	RMU	1.584	6.364	556.280					0.189		0.189	66	46	46	0.198	Unit 3 is in AM since 26.01.2026 Unit 4 is in RMU since 07.11.2024,
9	RAMGANGA	3x 66 = 198	RO	RO	FO		0.000	0.000	245.738							0.000	0	0	0	0.000	Unit 3 is in FO due to Generator problem since 21.10.2025
10	KHATIMA	3x 13.8 =41.40	0.300	PO	0.005		0.305	1.038	176.406							0.000	15	37	34	0.045	Unit 2 is in AM since 02.02.2026
11	VYASI	2x60=120	0.335	PO			0.335	1.312	335.486							0.000	60	51	51	0.180	Unit 2 is in AM since 27.01.2026
12	PATHRI	3x6.8=20.4	RO	0.127	0.132		0.259	0.972	85.581							0.000	12.0			0.036	
13	MOHD. PUR	3x 3.1 =9.30	0.061	0.064	PO		0.124	0.479	38.613							0.000	5.7			0.017	Unit 3 is in Capital Maintenance since 02.02.2026
14	GALOGI	3X1+0.5 = 3.5	RO	RO	PO	0.021	0.021	0.084	7.141							0.000	0.9			0.002	Unit 3 is in AM since 16.01.2026
15	DUNAO	2x.75=1.5	0.009	RO			0.009	0.040	2.64							0.000	0.5			0.003	
16	PILANG GAD	2x1.125=2.25	0.015	0.018			0.033	0.136	4.935							0.000	1.5			0.008	
17	URGAM	2x1.5=3.00	0.036	RO			0.036	0.129	6.100							0.000	1.5			0.009	
18	KALIGANGA-I	2x2=4.00	RO	0.008			0.008	0.040	8.002							0.000	0.8			0.005	
19	KALIGANGA-II	2x2.25=4.5	0.018	0.009			0.026	0.085	10.607							0.000	1.6			0.009	
20	SURINGAD-II	2x2.5=5	0.007	0.007			0.014	0.048	11.672							0.000	0.6			0.004	
21	MADHYAMAHESHWAR	3x5=15	RO	0.076	0.031		0.107	0.241	29.529							0.000	0.6			0.047	
TOTAL		1440.60					6.600	26.065	4745.438	0.000	0.000	0.000	0.000	0.431	0.000	0.431	674.73			2.086	
AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning																					

Distributed to:-
Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
MD UJVNL/MD UPCL
Director(Operation) /Director(Project)/Director(Finance)/ Director(HR)

Dy. General Manager (Technical)