

Daily Generation Report of 28 February 2026

Reporting Date 01 March 2026

| SL NO | Name Of Power Station | CAPACITY (MW) | GENERATION OF THE DAY (MU) | | | | | Cumulative Gen. of the month till date (MU) | Cumulative Gen. in FY till date (MU) | LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU) | | | | | | | Declared Capacity (MW)/ Peak Load | PAF of the Day | Av PAF of the month | Generation in M/E Peaking hrs (MU) | Remarks | |
|--------------|-----------------------|----------------|----------------------------|--------|--------|--------|--------------|---|--------------------------------------|---|---------------------------------|-------------------------------------|----------------------|----------------|-------------------------|--------------|-----------------------------------|----------------|---------------------|------------------------------------|---|--|
| | | | Unit-1 | Unit-2 | Unit-3 | Unit-4 | Total | | | B/D of Equipment | System Condition & Grid Failure | Flushing & choking / High Head Loss | Flood Pass/ High PPM | Planned Outage | Unusual & Other Reasons | Total | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | |
| 1 | CHIBRO | 4x60=240 | PO | 0.413 | 0.089 | 0.339 | 0.841 | 26.399 | 768.752 | | | | | | | 0.000 | 108 | 46 | 46 | 0.324 | Unit 1 is in Capital Maintenance since 27.01.2026 | |
| 2 | KHODRI | 4x 30 = 120 | PO | PO | 0.253 | 0.179 | 0.432 | 13.562 | 368.605 | | | | | | | 0.000 | 55 | 23 | 23 | 0.165 | Unit 1 is in Capital Maintenance since 28.01.2026 Unit 2 is in AM since 28.01.2026 | |
| 3 | DHAKRANI | 3x11.25=33.75 | 0.040 | 0.110 | RMU | | 0.150 | 1.556 | 119.231 | | | | | 0.035 | 0.035 | 12 | 5 | 2 | 0.036 | Unit 3 is in RMU Since 30.10.2025 | | |
| 4 | DHALIPUR | 3x17 = 51 | PO | 0.204 | 0.056 | | 0.260 | 8.454 | 216.763 | | | | | | | 0.000 | 33 | 14 | 14 | 0.099 | Unit 1 is in AM since 13.02.2026 | |
| 5 | KULHAL | 3x 10= 30 | 0.040 | 0.149 | RO | | 0.189 | 6.290 | 140.404 | | | | | | | 0.000 | 20 | 8 | 8 | 0.060 | | |
| 6 | TILOTH (MB-I) | 3x30=90 | PO | 0.121 | 0.380 | | 0.501 | 9.730 | 462.333 | | | | | | | 0.000 | 57 | 24 | 20 | 0.171 | Unit 1 is in AM since 14.02.2026 | |
| 7 | DHARASU (MB-II) | 4x 76 = 304 | 0.538 | PO | 0.269 | 0.214 | 1.021 | 29.013 | 1230.524 | | | | | | | 0.000 | 212 | 89 | 80 | 0.636 | Unit 2 is in AM since 03.02.2026 | |
| 8 | CHILLA | 4x 36 = 144 | 0.690 | 0.738 | 0.411 | RMU | 1.839 | 46.530 | 596.446 | 0.155 | | | | | | 0.155 | 90 | 38 | 31 | 0.270 | Unit 4 is in RMU since 07.11.2024 Loss due to leakage from Gland seal Unit 3 | |
| 9 | RAMGANGA | 3x 66 = 198 | 0.768 | 0.960 | 1.005 | | 2.733 | 53.118 | 298.856 | | | | | | | 0.000 | 114 | 48 | 35 | 0.342 | | |
| 10 | KHATIMA | 3x 13.8 =41.40 | 0.190 | PO | 0.153 | | 0.343 | 9.234 | 184.602 | | | | | | | 0.000 | 21 | 9 | 8 | 0.063 | Unit 2 is in AM since 02.02.2026, | |
| 11 | VYASI | 2x60=120 | 0.137 | PO | | | 0.137 | 6.662 | 340.836 | | | | | | | 0.000 | 45 | 19 | 25 | 0.135 | Unit 2 is in AM since 27.01.2026 | |
| 12 | PATHRI | 3x6.8=20.4 | PO | 0.143 | 0.159 | | 0.302 | 7.890 | 92.499 | | 0.002 | | | 0.096 | 0.098 | 13.6 | | | | 0.041 | Unit 1 is in Capital Maintenance since 20.02.2026 & Grid disturbance | |
| 13 | MOHD. PUR | 3x 3.1 =9.30 | 0.059 | 0.063 | PO | | 0.122 | 3.326 | 41.460 | | | | | 0.007 | 0.007 | 5.5 | | | | 0.017 | Unit 3 is in Capital Maintenance since 02.02.2026 | |
| 14 | GALOGI | 3X1+0.5 = 3.5 | RO | RO | RO | 0.018 | 0.018 | 0.522 | 7.579 | | | | | | | 0.000 | 0.8 | | | 0.002 | | |
| 15 | DUNAO | 2x.75=1.5 | 0.000 | 0.007 | | | 0.007 | 0.250 | 2.85 | | | | | | | 0.000 | 0.4 | | | 0.002 | | |
| 16 | PILANG GAD | 2x1.125=2.25 | 0.015 | 0.019 | | | 0.034 | 0.933 | 5.73 | | | | | | | 0.000 | 1.4 | | | 0.008 | | |
| 17 | URGAM | 2x1.5=3.00 | 0.032 | RO | | | 0.032 | 0.935 | 6.905 | | | | | | | 0.000 | 1.5 | | | 0.009 | | |
| 18 | KALIGANGA-I | 2x2=4.00 | RO | 0.002 | | | 0.002 | 0.116 | 8.078 | | | | | | | 0.000 | 0.7 | | | 0.003 | | |
| 19 | KALIGANGA-II | 2x2.25=4.5 | 0.031 | RO | | | 0.031 | 0.808 | 11.330 | | | | | | | 0.000 | 1.4 | | | 0.008 | | |
| 20 | SURINGAD-II | 2x2.5=5 | 0.022 | RO | | | 0.022 | 0.488 | 12.112 | | | | | | | 0.000 | 1.0 | | | 0.006 | | |
| 21 | MADHYAMAHESHWAR | 3x5=15 | RO | RO | 0.077 | | 0.077 | 2.239 | 31.527 | | | | | | | 0.000 | 5.0 | | | 0.034 | | |
| TOTAL | | | | | | | 9.094 | 228.053 | 4947.426 | 0.155 | 0.002 | 0.000 | 0.000 | 0.138 | 0.000 | 0.295 | 798.37 | | | | 2.430 | |

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
 MD LUVNL/MD UPCL
 Director(Operation) /Director(Project)/Director(Finance)/ Director(HR)

Dy. General Manager (Technical)