

Daily Generation Report of 07 March 2026

Reporting Date 08 March 2026

| SL NO | Name Of Power Station | CAPACITY (MW) | GENERATION OF THE DAY (MU) | | | | | Cumulative Gen. of the month till date (MU) | Cumulative Gen. in FY till date (MU) | LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU) | | | | | | | Declared Capacity (MW)/ Peak Load | PAF of the Day | Av PAF of the month | Generation in M/E Peaking hrs (MU) | Remarks |
|--------------|-----------------------|----------------|----------------------------|--------|--------|--------|--------------|---|--------------------------------------|---|---------------------------------|-------------------------------------|----------------------|----------------|-------------------------|--------------|-----------------------------------|----------------|---------------------|------------------------------------|---|
| | | | Unit-1 | Unit-2 | Unit-3 | Unit-4 | Total | | | BD of Equipment | System Condition & Grid Failure | Flushing & choking / High Head Loss | Flood Pass/ High PPM | Planned Outage | Unusual & Other Reasons | Total | | | | | |
| | | | | | | | | | | | | | | | | | | | | | |
| 1 | CHIBRO | 4x60=240 | PO | 0.422 | RO | 0.383 | 0.805 | 5.776 | 774.528 | | | | | | | 0.000 | 108 | 46 | 46 | 0.324 | Unit 1 is in Capital Maintenance since 27.01.2026 |
| 2 | KHODRI | 4x 30 = 120 | PO | PO | 0.201 | 0.206 | 0.408 | 2.966 | 371.571 | | | | | | | 0.000 | 55 | 23 | 23 | 0.165 | Unit 1 is in Capital Maintenance since 28.01.2026 Unit 2 is in AM since 28.01.2026 |
| 3 | DHAKRANI | 3x11.25=33.75 | 0.041 | 0.142 | RMU | | 0.183 | 1.223 | 120.454 | | | | | | | 0.000 | 22 | 9 | 9 | 0.066 | Unit 3 is in RMU Since 30.10.2025 |
| 4 | DHALIPUR | 3x17 = 51 | 0.013 | 0.180 | 0.056 | | 0.249 | 1.744 | 218.507 | | | | | | | 0.000 | 33 | 14 | 14 | 0.099 | |
| 5 | KULHAL | 3x 10= 30 | 0.095 | 0.085 | RO | | 0.180 | 1.316 | 141.720 | | | | | | | 0.000 | 20 | 8 | 8 | 0.060 | |
| 6 | TILOTH (MB-I) | 3x30=90 | PO | 0.173 | 0.536 | | 0.709 | 3.942 | 466.275 | | | | | | | 0.000 | 57 | 24 | 24 | 0.171 | Unit 1 is in AM since 14.02.2026 |
| 7 | DHARASU (MB-II) | 4x 76 = 304 | 0.765 | PO | 0.331 | 0.223 | 1.319 | 7.905 | 1238.429 | | | | | | | 0.000 | 216 | 91 | 90 | 0.648 | Unit 2 is in AM since 03.02.2026 |
| 8 | CHILLA | 4x 36 = 144 | 0.642 | 0.688 | 0.718 | RMU | 2.048 | 13.715 | 610.161 | | | | | 0.027 | | 0.027 | 92 | 39 | 38 | 0.276 | Unit 4 is in RMU since 07.11.2024 |
| 9 | RAMGANGA | 3x 66 = 198 | 0.768 | 0.840 | 0.859 | | 2.467 | 17.626 | 316.482 | | | | | | | 0.000 | 103 | 43 | 44 | 0.309 | |
| 10 | KHATIMA | 3x 13.8 =41.40 | PO | PO | 0.353 | | 0.353 | 2.413 | 187.015 | | | | | | | 0.000 | 15 | 6 | 6 | 0.045 | Unit 2 is in AM since 02.02.2026, Unit 1 is in AM since 06.03.2026, |
| 11 | VYASI | 2x60=120 | 0.186 | PO | | | 0.186 | 1.025 | 341.861 | | | | | | | 0.000 | 45 | 19 | 19 | 0.135 | Unit 2 is in AM since 27.01.2026 |
| 12 | PATHRI | 3x6.8=20.4 | PO | 0.145 | 0.159 | | 0.304 | 2.186 | 94.685 | | | | | 0.144 | | 0.144 | 13.7 | | | 0.041 | Unit 1 is in Capital Maintenance since 20.02.2026 |
| 13 | MOHD. PUR | 3x 3.1 =9.30 | 0.058 | 0.062 | PO | | 0.121 | 0.814 | 42.274 | | | | | | | 0.000 | 5.4 | | | 0.016 | Unit 3 is in Capital Maintenance since 02.02.2026 |
| 14 | GALOGI | 3X1+0.5 = 3.5 | 0.001 | RO | RO | 0.014 | 0.015 | 0.117 | 7.696 | | | | | | | 0.000 | 0.8 | | | 0.001 | |
| 15 | DUNAO | 2x.75=1.5 | 0.006 | RO | | | 0.006 | 0.040 | 2.89 | | | | | | | 0.000 | 0.3 | | | 0.002 | |
| 16 | PILANG GAD | 2x1.125=2.25 | 0.017 | 0.020 | | | 0.037 | 0.231 | 5.96 | | | | | | | 0.000 | 1.6 | | | 0.009 | |
| 17 | URGAM | 2x1.5=3.00 | 0.025 | 0.010 | | | 0.035 | 0.239 | 7.144 | | | | | | | 0.000 | 1.5 | | | 0.009 | |
| 18 | KALIGANGA-I | 2x2=4.00 | RO | 0.002 | | | 0.002 | 0.011 | 8.089 | | | | | | | 0.000 | 1.0 | | | 0.001 | |
| 19 | KALIGANGA-II | 2x2.25=4.5 | 0.043 | RO | | | 0.043 | 0.229 | 11.560 | | | | | | | 0.000 | 2.1 | | | 0.011 | |
| 20 | SURINGAD-II | 2x2.5=5 | 0.021 | RO | | | 0.021 | 0.150 | 12.261 | | | | | | | 0.000 | 1.0 | | | 0.006 | |
| 21 | MADHYAMAHESHWAR | 3x5=15 | RO | 0.069 | RO | | 0.069 | 0.458 | 31.985 | | | | | | | 0.000 | 5.0 | | | 0.036 | |
| TOTAL | | | | | | | 9.560 | 64.125 | 5011.551 | 0.000 | 0.000 | 0.000 | 0.000 | 0.171 | 0.000 | 0.171 | 798.42 | | | 2.431 | |

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
 MD LJVNL/MD UPCL
 Director(Operation) /Director(Project)/Director(Finance) / Director(HR)

Dy. General Manager (Technical)