

Daily Generation Report of 17 March 2026

Reporting Date 18 March 2026

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. in FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks	
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total						
1	CHIBRO	4x60=240	PO	0.351	0.002	0.421	0.774	14.610	783.362							0.000	105	44	45	0.315	Unit 1 is in Capital Maintenance since 27.01.2026	
2	KHODRI	4x 30 = 120	PO	PO	0.183	0.217	0.399	7.496	376.101							0.000	56	24	23	0.168	Unit 1 is in Capital Maintenance since 28.01.2026 Unit 2 is in AM since 28.01.2026	
3	DHAKRANI	3x11.25=33.75	0.097	0.091	RMU		0.188	3.213	122.444							0.000	22	9	9	0.066	Unit 3 is in RMU Since 30.10.2025	
4	DHALIPUR	3x17 = 51	0.148	0.123	PO		0.271	4.564	221.326							0.000	34	14	14	0.102	Unit 3 is in AM since 14.03.2026	
5	KULHAL	3x 10= 30	0.073	PO	0.124		0.197	3.396	143.800							0.000	20	8	8	0.060	Unit 2 is in AM since 07.03.2026	
6	TILOTH (MB-I)	3x30=90	PO	0.122	0.430		0.552	10.057	472.390							0.000	57	24	24	0.171	Unit 1 is in AM since 14.02.2026	
7	DHARASU (MB-II)	4x 76 = 304	0.531	PO	0.272	0.193	0.996	18.992	1249.516							0.000	216	91	91	0.648	Unit 2 is in AM since 03.02.2026	
8	CHILLA	4x 36 = 144	0.732	PO	0.715	RMU	1.447	28.998	625.444					0.331		0.331	60	25	32	0.180	Unit 2 is in AM since 09.03.2026, Unit 4 RMU since 07.11.2024	
9	RAMGANGA	3x 66 = 198	RO	RO	RO		0.000	27.871	326.727							0.000	0	0	30	0.000		
10	KHATIMA	3x 13.8 =41.40	PO	0.307	0.131		0.438	6.667	191.269							0.000	30	13	9	0.090	Unit 1 is in AM since 06.03.2026	
11	VYASI	2x60=120	0.198	PO			0.198	3.254	344.090							0.000	60	25	22	0.180	Unit 2 is in AM since 27.01.2026	
12	PATHRI	3x6.8=20.4	PO	0.082	0.146		0.228	4.833	97.332							0.000	11.0			0.033	Unit 1 is in Capital Maintenance since 20.02.2026	
13	MOHD. PUR	3x 3.1 =9.30	0.062	0.069	PO		0.131	2.025	43.485							0.000	5.7			0.017	Unit 3 is in Capital Maintenance since 02.02.2026	
14	GALOGI	3X1+0.5 = 3.5	RO	RO	RO	0.017	0.017	0.291	7.870							0.000	0.7			0.001		
15	DUNAO	2x.75=1.5	0.007	RO			0.007	0.071	2.92							0.000	0.5			0.003		
16	PILANG GAD	2x1.125=2.25	0.016	0.020			0.036	0.612	6.34							0.000	1.5			0.009		
17	URGAM	2x1.5=3.00	0.016	0.019			0.035	0.503	7.408							0.000	1.5			0.009		
18	KALIGANGA-I	2x2=4.00	RO	RO			0.000	0.032	8.111							0.000	0.0			0.000		
19	KALIGANGA-II	2x2.25=4.5	RO	RO			0.000	0.568	11.899							0.000	0.0			0.000		
20	SURINGAD-II	2x2.5=5	0.022	RO			0.022	0.370	12.482							0.000	1.1			0.006		
21	MADHYAMAHESHWAR	3x5=15	0.032	0.062	RO		0.093	1.097	32.625							0.000	5.0			0.040		
TOTAL							6.030	139.520	5086.946	0.000	0.000	0.000	0.000	0.331	0.000	0.331	687.05				2.098	

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
 MD UJVNL/MD UPCL
 Director(Operation) /Director(Project)/Director(Finance) Director(HR)

Dy. General Manager (Technical)