

Daily Generation Report of 24 March 2026

Reporting Date 25 March 2026

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. in FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks	
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total						
1	CHIBRO	4x60=240	PO	0.424	0.722	RO	1.146	23.263	792.015							0.000	105	44	45	0.315	Unit 1 is in Capital Maintenance since 27.01.2026	
2	KHODRI	4x 30 = 120	PO	PO	0.230	0.370	0.600	11.968	380.573							0.000	55	23	23	0.165	Unit 1 is in Capital Maintenance since 28.01.2026 Unit 2 is in AM since 28.01.2026	
3	DHAKRANI	3x11.25=33.75	0.092	0.149	RMU		0.241	5.117	124.348							0.000	22	9	9	0.066	Unit 3 is in RMU Since 30.10.2025	
4	DHALIPUR	3x17 = 51	0.157	0.191	PO		0.347	7.275	224.038							0.000	33	14	14	0.099	Unit 3 is in AM since 14.03.2026	
5	KULHAL	3x 10= 30	0.093	PO	0.174		0.267	5.328	145.732							0.000	20	8	8	0.060	Unit 2 is in AM since 07.03.2026	
6	TILOTH (MB-I)	3x30=90	PO	0.217	0.521		0.738	14.874	477.207							0.000	57	24	24	0.171	Unit 1 is in AM since 14.02.2026	
7	DHARASU (MB-II)	4x 76 = 304	0.595	PO	0.645	0.195	1.435	28.260	1258.784							0.000	216	91	91	0.648	Unit 2 is in AM since 03.02.2026	
8	CHILLA	4x 36 = 144	0.764	PO	0.722	RMU	1.486	38.602	635.048					0.408		0.408	62	26	30	0.186	Unit 2 is in AM since 09.03.2026, Unit 4 is in RMU since 07.11.2024	
9	RAMGANGA	3x 66 = 198	RO	RO	RO		0.000	27.871	326.727							0.000	0	0	21	0.000		
10	KHATIMA	3x 13.8 =41.40	PO	RO	0.229		0.229	8.902	193.504							0.000	15	6	10	0.045	Unit 1 is in AM since 06.03.2026	
11	VYASI	2x60=120	0.323	PO			0.323	5.611	346.447							0.000	60	25	23	0.180	Unit 2 is in AM since 27.01.2026	
12	PATHRI	3x6.8=20.4	PO	RO	0.122		0.122	5.962	98.462							0.000	6.8			0.020	Unit 1 is in Capital Maintenance since 20.02.2026	
13	MOHD. PUR	3x 3.1 =9.30	0.067	RO	PO		0.067	2.634	44.093							0.000	3.0			0.009	Unit 3 is in Capital Maintenance since 02.02.2026	
14	GALOGI	3X1+0.5 = 3.5	RO	RO	RO	0.017	0.017	0.407	7.986							0.000	0.7			0.001		
15	DUNAO	2x.75=1.5	0.001	0.005			0.006	0.114	2.97							0.000	0.7			0.002		
16	PILANG GAD	2x1.125=2.25	0.023	0.025			0.047	0.899	6.63							0.000	2.0			0.012		
17	URGAM	2x1.5=3.00	RO	0.009			0.009	0.623	7.529							0.000	1.5			0.002		
18	KALIGANGA-I	2x2=4.00	RO	0.011			0.011	0.095	8.174							0.000	0.9			0.005		
19	KALIGANGA-II	2x2.25=4.5	0.027	RO			0.027	0.751	12.081							0.000	2.3			0.009		
20	SURINGAD-II	2x2.5=5	0.027	RO			0.027	0.515	12.627							0.000	1.2			0.007		
21	MADHYAMAHESHWAR	3x5=15	0.046	0.048	RO		0.094	1.620	33.147							0.000	6.0			0.036		
<b>TOTAL</b>							<b>7.239</b>	<b>190.693</b>	<b>5138.119</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.408</b>	<b>0.000</b>	<b>0.408</b>	<b>670.04</b>				<b>2.038</b>	

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-  
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.  
 MD UJVNL/MD UPCL  
 Director(Operation) /Director(Project)/Director(Finance) Director(HR)

Dy. General Manager (Technical)