

Daily Generation Report of 25 March 2026

Reporting Date 26 March 2026

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. in FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks	
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total						
1	CHIBRO	4x60=240	PO	0.201	0.381	0.567	1.149	24.413	793.165							0.000	105	44	45	0.315	Unit 1 is in Capital Maintenance since 27.01.2026	
2	KHODRI	4x 30 = 120	PO	PO	0.178	0.418	0.596	12.564	381.169							0.000	54	23	23	0.162	Unit 1 is in Capital Maintenance since 28.01.2026 Unit 2 is in AM since 28.01.2026	
3	DHAKRANI	3x11.25=33.75	0.093	0.167	RMU		0.261	5.378	124.609							0.000	22	9	9	0.066	Unit 3 is in RMU Since 30.10.2025	
4	DHALIPUR	3x17 = 51	0.241	0.134	PO		0.375	7.650	224.413							0.000	33	14	14	0.099	Unit 3 is in AM since 14.03.2026	
5	KULHAL	3x 10= 30	0.080	PO	0.175		0.255	5.583	145.987							0.000	20	8	8	0.060	Unit 2 is in AM since 07.03.2026	
6	TILOTH (MB-I)	3x30=90	PO	0.120	0.527		0.647	15.522	477.855							0.000	57	24	24	0.171	Unit 1 is in AM since 14.02.2026	
7	DHARASU (MB-II)	4x 76 = 304	0.792	PO	0.273	0.193	1.258	29.518	1260.042							0.000	216	91	91	0.648	Unit 2 is in AM since 03.02.2026	
8	CHILLA	4x 36 = 144	0.755	PO	0.724	RMU	1.479	40.081	636.527					0.261		0.261	61	26	30	0.183	Unit 2 is in AM since 09.03.2026, Unit 4 is in RMU since 07.11.2024	
9	RAMGANGA	3x 66 = 198	RO	RO	RO		0.000	27.871	326.727							0.000	0	0	20	0.000		
10	KHATIMA	3x 13.8 =41.40	PO	0.123	0.123		0.246	9.148	193.750							0.000	15	6	9	0.045	Unit 1 is in AM since 06.03.2026	
11	VYASI	2x60=120	0.368	PO			0.368	5.979	346.815							0.000	60	25	23	0.180	Unit 2 is in AM since 27.01.2026	
12	PATHRI	3x6.8=20.4	PO	0.113	0.020		0.133	6.095	98.595							0.000	8.5			0.026	Unit 1 is in Capital Maintenance since 20.02.2026	
13	MOHD. PUR	3x 3.1 =9.30	0.043	0.026	PO		0.069	2.703	44.163							0.000	4.1			0.012	Unit 3 is in Capital Maintenance since 02.02.2026	
14	GALOGI	3X1+0.5 = 3.5	RO	RO	RO	0.017	0.017	0.425	8.003							0.000	0.7			0.001		
15	DUNAO	2x.75=1.5	0.005	0.003			0.008	0.122	2.98							0.000	0.6			0.003		
16	PILANG GAD	2x1.125=2.25	0.016	0.016			0.032	0.931	6.66							0.000	2.0			0.012		
17	URGAM	2x1.5=3.00	RO	0.015			0.015	0.638	7.543							0.000	1.5			0.002		
18	KALIGANGA-I	2x2=4.00	RO	0.006			0.006	0.101	8.179							0.000	0.9			0.004		
19	KALIGANGA-II	2x2.25=4.5	0.013	RO			0.013	0.763	12.094							0.000	2.3			0.010		
20	SURINGAD-II	2x2.5=5	0.027	RO			0.027	0.542	12.654							0.000	1.2			0.007		
21	MADHYAMAHESHWAR	3x5=15	0.024	0.086	RO		0.109	1.729	33.257							0.000	6.9			0.032		
<b>TOTAL</b>			<b>1440.60</b>				<b>7.064</b>	<b>197.757</b>	<b>5145.183</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.261</b>	<b>0.000</b>	<b>0.261</b>	<b>671.64</b>				<b>2.038</b>	

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-  
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.  
 MD UJVNL/MD UPCL  
 Director(Operation) /Director(Project)/Director(Finance) Director(HR)

Dy. General Manager (Technical)