

Daily Generation Report of 27 March 2026

Reporting Date 28 March 2026

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. in FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks	
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total						
1	CHIBRO	4x60=240	PO	0.411	0.476	0.194	1.081	26.591	795.343							0.000	105	44	45	0.315	Unit 1 is in Capital Maintenance since 27.01.2026	
2	KHODRI	4x 30 = 120	PO	PO	0.373	0.194	0.567	13.702	382.307							0.000	54	23	23	0.162	Unit 1 is in Capital Maintenance since 28.01.2026 Unit 2 is in AM since 28.01.2026	
3	DHAKRANI	3x11.25=33.75	0.083	0.167	RMU		0.250	5.896	125.126							0.000	22	9	9	0.066	Unit 3 is in RMU Since 30.10.2025	
4	DHALIPUR	3x17 = 51	0.126	0.227	PO		0.353	8.389	225.152							0.000	33	14	14	0.099	Unit 3 is in AM since 14.03.2026	
5	KULHAL	3x 10= 30	0.083	PO	0.176		0.259	6.119	146.523							0.000	20	8	8	0.060	Unit 2 is in AM since 07.03.2026	
6	TILOTH (MB-I)	3x30=90	PO	0.207	0.528		0.735	16.909	479.242							0.000	57	24	24	0.171	Unit 1 is in AM since 14.02.2026	
7	DHARASU (MB-II)	4x 76 = 304	1.201	PO	0.288	PO	1.489	32.335	1262.859							0.000	156	66	90	0.468	Unit 2 is in AM since 03.02.2026. Unit 4 is in AM since 26.03.2026	
8	CHILLA	4x 36 = 144	0.744	PO	0.717	RMU	1.461	43.009	639.455					0.307		0.307	60	25	30	0.180	Unit 2 is in AM since 09.03.2026, Unit 4 is in RMU since 07.11.2024	
9	RAMGANGA	3x 66 = 198	RO	RO	RO		0.000	27.871	326.727							0.000	0	0	19	0.000		
10	KHATIMA	3x 13.8 =41.40	PO	0.286	0.019		0.305	9.717	194.319							0.000	20	8	9	0.060	Unit 1 is in AM since 06.03.2026	
11	VYASI	2x60=120	0.307	PO			0.307	6.599	347.435							0.000	60	25	23	0.180	Unit 2 is in AM since 27.01.2026	
12	PATHRI	3x6.8=20.4	PO	0.092	0.053		0.145	6.397	98.896							0.000	12.2			0.037	Unit 1 is in Capital Maintenance since 20.02.2026	
13	MOHD. PUR	3x 3.1 =9.30	0.032	0.056	PO		0.088	2.884	44.343							0.000	6.0			0.018	Unit 3 is in Capital Maintenance since 02.02.2026	
14	GALOGI	3X1+0.5 = 3.5	RO	RO	RO	0.017	0.017	0.459	8.038							0.000	0.7			0.001		
15	DUNAO	2x.75=1.5	0.007	RO			0.007	0.136	2.99							0.000	0.4			0.003		
16	PILANG GAD	2x1.125=2.25	0.023	0.024			0.047	1.024	6.75							0.000	2.0			0.012		
17	URGAM	2x1.5=3.00	0.012	0.005			0.017	0.660	7.565							0.000	1.5			0.006		
18	KALIGANGA-I	2x2=4.00	RO	0.005			0.005	0.112	8.190							0.000	1.0			0.003		
19	KALIGANGA-II	2x2.25=4.5	0.011	RO			0.011	0.786	12.117							0.000	2.1			0.006		
20	SURINGAD-II	2x2.5=5	0.027	RO			0.027	0.596	12.708							0.000	1.3			0.007		
21	MADHYAMAHESHWAR	3x5=15	0.045	0.049	RO		0.094	1.911	33.438							0.000	6.0			0.033		
TOTAL							7.267	212.102	5159.528	0.000	0.000	0.000	0.000	0.307	0.000	0.307	620.16				1.886	

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
 MD UJVNL/MD UPCL
 Director(Operation) /Director(Project)/Director(Finance) Director(HR)

Dy. General Manager (Technical)