

Daily Generation Report of 28 March 2026

Reporting Date 29 March 2026

| SL NO | Name Of Power Station | CAPACITY (MW) | GENERATION OF THE DAY (MU) | | | | | Cumulative Gen. of the month till date (MU) | Cumulative Gen. in FY till date (MU) | LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU) | | | | | | | Declared Capacity (MW)/ Peak Load | PAF of the Day | Av PAF of the month | Generation in M/E Peaking hrs (MU) | Remarks | |
|--------------|-----------------------|----------------|----------------------------|--------|--------|--------|--------------|---|--------------------------------------|---|---------------------------------|-------------------------------------|----------------------|----------------|-------------------------|--------------|-----------------------------------|----------------|---------------------|------------------------------------|---|--|
| | | | Unit-1 | Unit-2 | Unit-3 | Unit-4 | Total | | | B/D of Equipment | System Condition & Grid Failure | Flushing & choking / High Head Loss | Flood Pass/ High PPM | Planned Outage | Unusual & Other Reasons | Total | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | |
| 1 | CHIBRO | 4x60=240 | PO | 0.350 | 0.726 | RO | 1.076 | 27.667 | 796.419 | | | | | | | 0.000 | 105 | 44 | 45 | 0.315 | Unit 1 is in Capital Maintenance since 27.01.2026 | |
| 2 | KHODRI | 4x 30 = 120 | PO | PO | 0.379 | 0.183 | 0.562 | 14.265 | 382.870 | | | | | | | 0.000 | 55 | 23 | 23 | 0.165 | Unit 1 is in Capital Maintenance since 28.01.2026 Unit 2 is in AM since 28.01.2026 | |
| 3 | DHAKRANI | 3x11.25=33.75 | 0.091 | 0.169 | RMU | | 0.260 | 6.156 | 125.386 | | | | | | | 0.000 | 22 | 9 | 9 | 0.066 | Unit 3 is in RMU Since 30.10.2025 | |
| 4 | DHALIPUR | 3x17 = 51 | 0.133 | 0.243 | PO | | 0.376 | 8.765 | 225.528 | | | | | | | 0.000 | 33 | 14 | 14 | 0.099 | Unit 3 is in AM since 14.03.2026 | |
| 5 | KULHAL | 3x 10= 30 | 0.079 | PO | 0.182 | | 0.260 | 6.379 | 146.783 | | | | | | | 0.000 | 20 | 8 | 8 | 0.060 | Unit 2 is in AM since 07.03.2026 | |
| 6 | TILOTH (MB-I) | 3x30=90 | PO | 0.208 | 0.523 | | 0.730 | 17.640 | 479.973 | | | | | | | 0.000 | 57 | 24 | 24 | 0.171 | Unit 1 is in AM since 14.02.2026 | |
| 7 | DHARASU (MB-II) | 4x 76 = 304 | 1.136 | PO | 0.370 | PO | 1.506 | 33.841 | 1264.365 | | | | | | | 0.000 | 156 | 66 | 89 | 0.468 | Unit 2 is in AM since 03.02.2026. Unit 4 is in AM since 26.03.2026 | |
| 8 | CHILLA | 4x 36 = 144 | 0.740 | PO | 0.718 | RMU | 1.458 | 44.467 | 640.913 | | | | | 0.292 | | 0.292 | 60 | 25 | 30 | 0.180 | Unit 2 is in AM since 09.03.2026, Unit 4 is in RMU since 07.11.2024 | |
| 9 | RAMGANGA | 3x 66 = 198 | RO | RO | RO | | 0.000 | 27.871 | 326.727 | | | | | | | 0.000 | 0 | 0 | 18 | 0.000 | | |
| 10 | KHATIMA | 3x 13.8 =41.40 | PO | 0.002 | RO | | 0.002 | 9.719 | 194.321 | | | | | | | 0.000 | 7 | 3 | 9 | 0.021 | Unit 1 is in AM since 06.03.2026 | |
| 11 | VYASI | 2x60=120 | 0.307 | PO | | | 0.307 | 6.905 | 347.741 | | | | | | | 0.000 | 60 | 25 | 23 | 0.180 | Unit 2 is in AM since 27.01.2026 | |
| 12 | PATHRI | 3x6.8=20.4 | PO | 0.092 | 0.055 | | 0.147 | 6.544 | 99.043 | | | | | | | 0.000 | 9.4 | | | 0.028 | Unit 1 is in Capital Maintenance since 20.02.2026 | |
| 13 | MOHD. PUR | 3x 3.1 =9.30 | 0.028 | 0.046 | PO | | 0.074 | 2.957 | 44.417 | | | | | | | 0.000 | 5.0 | | | 0.015 | Unit 3 is in Capital Maintenance since 02.02.2026 | |
| 14 | GALOGI | 3X1+0.5 = 3.5 | RO | RO | RO | 0.017 | 0.017 | 0.477 | 8.056 | | | | | | | 0.000 | 0.7 | | | 0.001 | | |
| 15 | DUNAO | 2x.75=1.5 | 0.008 | RO | | | 0.008 | 0.144 | 3.00 | | | | | | | 0.000 | 0.4 | | | 0.003 | | |
| 16 | PILANG GAD | 2x1.125=2.25 | 0.022 | 0.024 | | | 0.046 | 1.069 | 6.80 | | | | | | | 0.000 | 2.0 | | | 0.012 | | |
| 17 | URGAM | 2x1.5=3.00 | 0.010 | RO | | | 0.010 | 0.670 | 7.575 | | | | | | | 0.000 | 1.5 | | | 0.006 | | |
| 18 | KALIGANGA-I | 2x2=4.00 | RO | 0.007 | | | 0.007 | 0.118 | 8.197 | | | | | | | 0.000 | 1.0 | | | 0.003 | | |
| 19 | KALIGANGA-II | 2x2.25=4.5 | 0.025 | RO | | | 0.025 | 0.811 | 12.141 | | | | | | | 0.000 | 2.2 | | | 0.006 | | |
| 20 | SURINGAD-II | 2x2.5=5 | 0.027 | RO | | | 0.027 | 0.623 | 12.735 | | | | | | | 0.000 | 1.3 | | | 0.007 | | |
| 21 | MADHYAMAHESHWAR | 3x5=15 | 0.071 | 0.022 | RO | | 0.093 | 2.004 | 33.531 | | | | | | | 0.000 | 5.0 | | | 0.033 | | |
| TOTAL | | | | | | | 6.989 | 219.091 | 5166.517 | 0.000 | 0.000 | 0.000 | 0.000 | 0.292 | 0.000 | 0.292 | 603.44 | | | | 1.838 | |

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
 MD UJVNL/MD UPCL
 Director(Operation) /Director(Project)/Director(Finance) Director(HR)

Dy. General Manager (Technical)