

Daily Generation Report of 02 April 2026

Reporting Date 03 April 2026

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. in FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks	
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total						
1	CHIBRO	4x60=240	PO	0.211	0.734	0.152	1.097	2.077	2.077							0.000	105	44	44	0.315	Unit 1 is in Capital Maintenance since 27.01.2026	
2	KHODRI	4x 30 = 120	PO	0.057	0.311	0.197	0.566	1.074	1.074							0.000	53	22	23	0.159	Unit 1 is in Capital Maintenance since 28.01.2026	
3	DHAKRANI	3x11.25=33.75	0.101	0.143	RMU		0.244	0.481	0.481							0.000	22	9	9	0.066	Unit 3 is in RMU Since 30.10.2025	
4	DHALIPUR	3x17 = 51	0.144	0.189	PO		0.333	0.679	0.679		0.009					0.009	34	14	14	0.102	Unit 3 is in AM since 14.03.2026, Grid Disturbance	
5	KULHAL	3x 10= 30	0.084	PO	0.147		0.230	0.477	0.477							0.000	20	8	8	0.060	Unit 2 is in AM since 07.03.2026	
6	TILOTH (MB-I)	3x30=90	0.575	0.206	RO		0.781	1.570	1.570							0.000	68	29	29	0.204		
7	DHARASU (MB-II)	4x 76 = 304	0.539	PO	0.847	PO	1.386	3.044	3.044							0.000	156	66	66	0.468	Unit 2 is in AM since 03.02.2026, Unit 4 is in AM since 26.03.2026	
8	CHILLA	4x 36 = 144	0.703	PO	0.716	RMU	1.419	2.843	2.843					0.291		0.291	59	25	25	0.177	Unit 2 is in AM since 09.03.2026, Unit 4 is in RMU since 07.11.2024	
9	RAMGANGA	3x 66 = 198	RO	RO	RO		0.000	0.000	0.000							0.000	0	0	0	0.000		
10	KHATIMA	3x 13.8 =41.40	PO	0.306	0.172		0.478	0.851	0.851							0.000	26	11	9	0.078	Unit 1 is in AM since 06.03.2026	
11	VYASI	2x60=120	0.339	PO			0.339	0.522	0.522							0.000	60	25	25	0.180	Unit 2 is in AM since 27.01.2026	
12	PATHRI	3x6.8=20.4	PO	0.135	0.082		0.218	0.367	0.367							0.000	10.3			0.031	Unit 1 is in Capital Maintenance since 20.02.2026	
13	MOHD. PUR	3x 3.1 =9.30	0.061	0.051	PO		0.112	0.192	0.192			0.003				0.003	5.7			0.017	Unit 3 is in Capital Maintenance since 02.02.2026, Heavy choking in Unit-2	
14	GALOGI	3X1+0.5 = 3.5	RO	RO	RO	0.017	0.017	0.034	0.034							0.000	0.7			0.001		
15	DUNAO	2x.75=1.5	0.005	RO			0.005	0.013	0.01							0.000	0.3			0.002		
16	PILANG GAD	2x1.125=2.25	0.023	0.023			0.046	0.088	0.09							0.000	2.0			0.011		
17	URGAM	2x1.5=3.00	0.030	RO			0.030	0.065	0.065							0.000	1.5			0.008		
18	KALIGANGA-I	2x2=4.00	RO	0.005			0.005	0.018	0.018							0.000	0.9			0.004		
19	KALIGANGA-II	2x2.25=4.5	0.022	RO			0.022	0.024	0.024							0.000	2.0			0.010		
20	SURINGAD-II	2x2.5=5	0.032	RO			0.032	0.063	0.063							0.000	1.5			0.009		
21	MADHYAMAHESHWAR	3x5=15	RO	0.077	RO		0.077	0.166	0.166							0.000	5.0			0.030		
TOTAL							7.439	14.648	14.648	0.000	0.009	0.003	0.000	0.291	0.000	0.303	632.87				1.932	

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
 MD UJVNL/MD UPCL
 Director(Operation) /Director(Project)/Director(Finance) Director(HR)

Dy. General Manager (Technical)