

Daily Generation Report of 31 March 2026

Reporting Date 01 April 2026

| SL NO | Name Of Power Station | CAPACITY (MW) | GENERATION OF THE DAY (MU) | | | | | Cumulative Gen. of the month till date (MU) | Cumulative Gen. in FY till date (MU) | LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU) | | | | | | | Declared Capacity (MW) Peak Load | PAF of the Day | Av PAF of the month | Generation in M/E Peaking hrs (MU) | Remarks | |
|--------------|-----------------------|----------------|----------------------------|--------|--------|--------|--------------|---|--------------------------------------|---|---------------------------------|--------------------------------------|----------------------|----------------|-------------------------|--------------|----------------------------------|----------------|---------------------|------------------------------------|---|--|
| | | | Unit-1 | Unit-2 | Unit-3 | Unit-4 | Total | | | BID of Equipment | System Condition & Grid Failure | Flushing & chocking / High Head Loss | Flood Pass/ High PPM | Planned Outage | Unusual & Other Reasons | Total | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | |
| 1 | CHIBRO | 4x60=240 | PO | RO | 0.812 | 0.689 | 1.501 | 31.270 | 800.021 | | | | | | | 0.000 | 105 | 44 | 45 | 0.315 | Unit 1 is in Capital Maintenance since 27.01.2026 | |
| 2 | KHODRI | 4x 30 = 120 | PO | PO | 0.454 | 0.319 | 0.773 | 16.132 | 384.737 | | | | | | | 0.000 | 54 | 23 | 23 | 0.162 | Unit 1 is in Capital Maintenance since 28.01.2026 Unit 2 is in AM since 28.01.2026 | |
| 3 | DHAKRANI | 3x11.25=33.75 | 0.139 | 0.180 | RMU | | 0.319 | 6.940 | 126.170 | | | | | | | 0.000 | 22 | 9 | 9 | 0.066 | Unit 3 is in RMU Since 30.10.2025 | |
| 4 | DHALIPUR | 3x17 = 51 | 0.219 | 0.243 | PO | | 0.463 | 9.891 | 226.654 | | | | | | | 0.000 | 34 | 14 | 14 | 0.102 | Unit 3 is in AM since 14.03.2026 | |
| 5 | KULHAL | 3x 10= 30 | 0.121 | PO | 0.194 | | 0.314 | 7.170 | 147.574 | | | | | | | 0.000 | 20 | 8 | 8 | 0.060 | Unit 2 is in AM since 07.03.2026 | |
| 6 | TILOTH (MB-I) | 3x30=90 | 0.360 | 0.523 | RO | | 0.884 | 20.022 | 482.355 | | | | | | | 0.000 | 68 | 29 | 24 | 0.204 | | |
| 7 | DHARASU (MB-II) | 4x 76 = 304 | 1.371 | PO | 0.249 | PO | 1.620 | 38.486 | 1269.010 | | | | | | | 0.000 | 156 | 66 | 87 | 0.468 | Unit 2 is in AM since 03.02.2026, Unit 4 is in AM since 26.03.2026 | |
| 8 | CHILLA | 4x 36 = 144 | 0.723 | PO | 0.716 | RMU | 1.439 | 48.803 | 645.249 | | | | 0.317 | | | 0.317 | 59 | 25 | 29 | 0.177 | Unit 2 is in AM since 09.03.2026, Unit 4 is in RMU since 07.11.2024 | |
| 9 | RAMGANGA | 3x 66 = 198 | RO | RO | RO | | 0.000 | 27.871 | 326.727 | | | | | | | 0.000 | 0 | 0 | 16 | 0.000 | | |
| 10 | KHATIMA | 3x 13.8 =41.40 | PO | 0.289 | 0.051 | | 0.340 | 10.380 | 194.982 | | | | | | | 0.000 | 19 | 8 | 9 | 0.057 | Unit 1 is in AM since 06.03.2026 | |
| 11 | VYASI | 2x60=120 | 0.425 | PO | | | 0.425 | 8.030 | 348.866 | | | | | | | 0.000 | 60 | 25 | 23 | 0.180 | Unit 2 is in AM since 27.01.2026 | |
| 12 | PATHRI | 3x6.8=20.4 | PO | 0.075 | 0.063 | | 0.138 | 6.982 | 99.482 | | | | | | | 0.000 | 6.5 | | | 0.020 | Unit 1 is in Capital Maintenance since 20.02.2026 | |
| 13 | MOHD. PUR | 3x 3.1 =9.30 | 0.012 | 0.050 | PO | | 0.062 | 3.191 | 44.651 | | | | | | | 0.000 | 3.8 | | | 0.011 | Unit 3 is in Capital Maintenance since 02.02.2026 | |
| 14 | GALOGI | 3X1+0.5 = 3.5 | RO | RO | RO | 0.015 | 0.015 | 0.524 | 8.103 | | | | | | | 0.000 | 0.7 | | | 0.001 | | |
| 15 | DUNAO | 2x.75=1.5 | 0.007 | RO | | | 0.007 | 0.164 | 3.02 | | | | | | | 0.000 | 0.4 | | | 0.002 | | |
| 16 | PILANG GAD | 2x1.125=2.25 | 0.020 | 0.023 | | | 0.043 | 1.202 | 6.93 | | | | | | | 0.000 | 1.9 | | | 0.011 | | |
| 17 | URGAM | 2x1.5=3.00 | 0.026 | RO | | | 0.026 | 0.760 | 7.665 | | | | | | | 0.000 | 1.5 | | | 0.006 | | |
| 18 | KALIGANGA-I | 2x2=4.00 | RO | 0.010 | | | 0.010 | 0.146 | 8.224 | | | | | | | 0.000 | 1.0 | | | 0.005 | | |
| 19 | KALIGANGA-II | 2x2.25=4.5 | 0.022 | RO | | | 0.022 | 0.891 | 12.221 | | | | | | | 0.000 | 2.1 | | | 0.009 | | |
| 20 | SURINGAD-II | 2x2.5=5 | 0.029 | RO | | | 0.029 | 0.702 | 12.814 | | | | | | | 0.000 | 1.4 | | | 0.008 | | |
| 21 | MADHYAMAHESHWAR | 3x5=15 | RO | 0.078 | RO | | 0.078 | 2.254 | 33.781 | | | | | | | 0.000 | 5.0 | | | 0.031 | | |
| TOTAL | | | | | | | 8.507 | 241.811 | 5189.237 | 0.000 | 0.000 | 0.000 | 0.000 | 0.317 | 0.000 | 0.317 | 621.31 | | | | 1.895 | |

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
 MD UJVN/LMD UPCL
 Director(Operation) /Director(Project)/Director(Finance) / Director(HR)

Dy. General Manager (Technical)