

Daily Generation Report of 13 April 2026

Reporting Date 14 April 2026

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. in FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks	
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total						
1	CHIBRO	4x60=240	PO	0.796	0.339	0.168	1.263	17.342	17.342							0.000	155	65	62	0.465	Unit 1 is in Capital Maintenance since 27.01.2026	
2	KHODRI	4x 30 = 120	PO	0.226	0.094	0.321	0.641	8.788	8.788							0.000	75	32	30	0.225	Unit 1 is in Capital Maintenance since 28.01.2026	
3	DHAKRANI	3x11.25=33.75	0.141	0.170	RMU		0.311	3.889	3.889							0.000	23	10	10	0.069	Unit 3 is in RMU Since 30.10.2025	
4	DHALIPUR	3x17 = 51	0.207	0.240	PO		0.448	5.588	5.588							0.000	34	14	14	0.101	Unit 3 is in AM since 14.03.2026	
5	KULHAL	3x 10= 30	0.139	PO	0.167		0.306	3.806	3.806							0.000	20	8	8	0.060	Unit 2 is in AM since 07.03.2026	
6	TILOTH (MB-I)	3x30=90	0.583	0.177	PO		0.759	10.521	10.521							0.000	68	29	29	0.204	Unit 3 is in PO due to Interim repair work since 03.04.2026	
7	DHARASU (MB-II)	4x 76 = 304	0.339	0.715	0.247	PO	1.301	19.472	19.472							0.000	228	96	76	0.684	Unit 4 is in AM since 26.03.2026	
8	CHILLA	4x 36 = 144	0.494	0.280	0.684	RMU	1.458	18.136	18.136						0.002	0.002	67	28	30	0.201	Unit 4 is in RMU since 07.11.2024 Due to Unit 2, UGB Temp Very High	
9	RAMGANGA	3x 66 = 198	RO	RO	RO		0.000	0.000	0.000							0.000	0	0	0	0.000		
10	KHATIMA	3x 13.8 =41.40	PO	0.137	0.129		0.266	4.931	4.931							0.000	15	6	9	0.045	Unit 1 is in AM since 06.03.2026	
11	VYASI	2x60=120	PO	0.427			0.427	4.707	4.707							0.000	60	25	25	0.180	Unit 1 is in AM since 10.04.2026	
12	PATHRI	3x6.8=20.4	PO	0.061	0.112		0.173	2.849	2.849							0.000	11.1			0.033	Unit 1 is in Capital Maintenance since 20.02.2026	
13	MOHD. PUR	3x 3.1 =9.30	0.039	0.029	PO		0.069	1.450	1.450							0.000	3.0			0.009	Unit 3 is in Capital Maintenance since 02.02.2026	
14	GALOGI	3X1+0.5 = 3.5	RO	RO	RO	0.018	0.018	0.219	0.219							0.000	0.7			0.001		
15	DUNAO	2x.75=1.5	0.006	RO			0.006	0.090	0.09							0.000	0.5			0.003		
16	PILANG GAD	2x1.125=2.25	0.018	0.019			0.037	0.560	0.56							0.000	1.9			0.010		
17	URGAM	2x1.5=3.00	0.036	RO			0.036	0.404	0.404							0.000	1.5			0.009		
18	KALIGANGA-I	2x2=4.00	0.002	RO			0.002	0.134	0.134							0.000	0.9			0.001		
19	KALIGANGA-II	2x2.25=4.5	0.003	RO			0.003	0.236	0.236							0.000	2.3			0.002		
20	SURINGAD-II	2x2.5=5	0.037	RO			0.037	0.436	0.436							0.000	1.6			0.009		
21	MADHYAMAHESHWAR	3x5=15	0.049	0.071	RO		0.120	1.248	1.248							0.000	6.4			0.048		
<b>TOTAL</b>							<b>7.680</b>	<b>104.806</b>	<b>104.806</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.002</b>	<b>0.002</b>	<b>774.29</b>				<b>2.359</b>	

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-  
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.  
 MD UJVNL/MD UPCL  
 Director(Operation) /Director(Project)/Director(Finance) Director(HR)

Dy. General Manager (Technical)