

Daily Generation Report of 14 April 2026

Reporting Date 15 April 2026

| SL NO | Name Of Power Station | CAPACITY (MW) | GENERATION OF THE DAY (MU) | | | | | Cumulative Gen. of the month till date (MU) | Cumulative Gen. in FY till date (MU) | LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU) | | | | | | | Declared Capacity (MW)/ Peak Load | PAF of the Day | Av PAF of the month | Generation in M/E Peaking hrs (MU) | Remarks | |
|--------------|-----------------------|----------------|----------------------------|--------|--------|--------|--------------|---|--------------------------------------|---|---------------------------------|-------------------------------------|----------------------|----------------|-------------------------|--------------|-----------------------------------|----------------|---------------------|------------------------------------|--------------|---|
| | | | Unit-1 | Unit-2 | Unit-3 | Unit-4 | Total | | | B/D of Equipment | System Condition & Grid Failure | Flushing & choking / High Head Loss | Flood Pass/ High PPM | Planned Outage | Unusual & Other Reasons | Total | | | | | | |
| 1 | CHIBRO | 4x60=240 | PO | 0.695 | 0.160 | 0.381 | 1.235 | 18.577 | 18.577 | | | | | | | | 0.000 | 155 | 65 | 62 | 0.465 | Unit 1 is in Capital Maintenance since 27.01.2026 |
| 2 | KHODRI | 4x 30 = 120 | PO | 0.349 | 0.203 | 0.081 | 0.633 | 9.420 | 9.420 | | | | | | | | 0.000 | 75 | 32 | 31 | 0.225 | Unit 1 is in Capital Maintenance since 28.01.2026 |
| 3 | DHAKRANI | 3x11.25=33.75 | 0.114 | 0.175 | RMU | | 0.290 | 4.179 | 4.179 | | | | | | | | 0.000 | 23 | 10 | 10 | 0.069 | Unit 3 is in RMU Since 30.10.2025 |
| 4 | DHALIPUR | 3x17 = 51 | 0.172 | 0.243 | PO | | 0.415 | 6.003 | 6.003 | | | | | | | | 0.000 | 34 | 14 | 14 | 0.101 | Unit 3 is in AM since 14.03.2026 |
| 5 | KULHAL | 3x 10= 30 | 0.130 | PO | 0.155 | | 0.285 | 4.091 | 4.091 | | | | | | | | 0.000 | 20 | 8 | 8 | 0.060 | Unit 2 is in AM since 07.03.2026 |
| 6 | TILOTH (MB-I) | 3x30=90 | 0.607 | 0.206 | PO | | 0.813 | 11.334 | 11.334 | | | | | | | | 0.000 | 68 | 29 | 29 | 0.204 | Unit 3 is in PO due to Interim repair work since 03.04.2026 |
| 7 | DHARASU (MB-II) | 4x 76 = 304 | 0.248 | 0.876 | 0.234 | PO | 1.358 | 20.830 | 20.830 | | | | | | | | 0.000 | 228 | 96 | 77 | 0.684 | Unit 4 is in AM since 26.03.2026 |
| 8 | CHILLA | 4x 36 = 144 | 0.349 | 0.543 | 0.580 | RMU | 1.472 | 19.608 | 19.608 | | | | | | | | 0.000 | 90 | 38 | 31 | 0.270 | Unit 4 is in RMU since 07.11.2024 |
| 9 | RAMGANGA | 3x 66 = 198 | RO | RO | RO | | 0.000 | 0.000 | 0.000 | | | | | | | | 0.000 | 0 | 0 | 0 | 0.000 | |
| 10 | KHATIMA | 3x 13.8 =41.40 | PO | 0.197 | 0.078 | | 0.275 | 5.206 | 5.206 | | | | | | | | 0.000 | 15 | 6 | 9 | 0.045 | Unit 1 is in AM since 06.03.2026 |
| 11 | VYASI | 2x60=120 | PO | 0.369 | | | 0.369 | 5.076 | 5.076 | | | | | | | | 0.000 | 60 | 25 | 25 | 0.180 | Unit 1 is in AM since 10.04.2026 |
| 12 | PATHRI | 3x6.8=20.4 | PO | 0.109 | 0.112 | | 0.220 | 3.069 | 3.069 | | | | | | | | 0.000 | 11.3 | | | 0.034 | Unit 1 is in Capital Maintenance since 20.02.2026 |
| 13 | MOHD. PUR | 3x 3.1 =9.30 | 0.058 | 0.027 | PO | | 0.085 | 1.535 | 1.535 | | | | | | | | 0.000 | 4.6 | | | 0.014 | Unit 3 is in Capital Maintenance since 02.02.2026 |
| 14 | GALOGI | 3X1+0.5 = 3.5 | RO | RO | RO | 0.017 | 0.017 | 0.236 | 0.236 | | | | | | | | 0.000 | 0.7 | | | 0.001 | |
| 15 | DUNAO | 2x.75=1.5 | 0.006 | RO | | | 0.006 | 0.096 | 0.10 | | | | | | | | 0.000 | 0.4 | | | 0.002 | |
| 16 | PILANG GAD | 2x1.125=2.25 | 0.020 | 0.020 | | | 0.039 | 0.599 | 0.60 | | | | | | | | 0.000 | 1.9 | | | 0.010 | |
| 17 | URGAM | 2x1.5=3.00 | 0.026 | RO | | | 0.026 | 0.430 | 0.430 | | | | | | | | 0.000 | 1.5 | | | 0.006 | |
| 18 | KALIGANGA-I | 2x2=4.00 | 0.006 | RO | | | 0.006 | 0.140 | 0.140 | | | | | | | | 0.000 | 1.1 | | | 0.003 | |
| 19 | KALIGANGA-II | 2x2.25=4.5 | 0.012 | RO | | | 0.012 | 0.248 | 0.248 | | | | | | | | 0.000 | 2.3 | | | 0.007 | |
| 20 | SURINGAD-II | 2x2.5=5 | 0.036 | RO | | | 0.036 | 0.471 | 0.471 | | | | | | | | 0.000 | 1.6 | | | 0.009 | |
| 21 | MADHYAMAHESHWAR | 3x5=15 | 0.032 | 0.040 | 0.030 | | 0.102 | 1.351 | 1.351 | | | | | | | | 0.000 | 6.7 | | | 0.037 | |
| TOTAL | | | | | | | 7.694 | 112.499 | 112.499 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 799.45 | | | | 2.426 | |

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
 MD UJVNL/MD UPCL
 Director(Operation) /Director(Project)/Director(Finance) Director(HR)

Dy. General Manager (Technical)