

Daily Generation Report of 18 April 2026

Reporting Date 19 April 2026

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. in FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks	
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total						
1	CHIBRO	4x60=240	PO	0.759	0.414	0.167	1.340	23.634	23.634								0.000	155	65	63	0.465	Unit 1 is in Capital Maintenance since 27.01.2026
2	KHODRI	4x 30 = 120	PO	0.133	0.354	0.195	0.682	12.002	12.002								0.000	76	32	31	0.228	Unit 1 is in Capital Maintenance since 28.01.2026
3	DHAKRANI	3x11.25=33.75	0.107	0.188	RMU		0.295	5.340	5.340								0.000	23	10	10	0.069	Unit 3 is in RMU Since 30.10.2025
4	DHALIPUR	3x17 = 51	0.172	0.264	PO		0.436	7.679	7.679								0.000	34	14	14	0.102	Unit 3 is in AM since 14.03.2026
5	KULHAL	3x 10= 30	0.101	PO	0.196		0.297	5.231	5.231								0.000	20	8	8	0.060	Unit 2 is in AM since 07.03.2026
6	TILOTH (MB-I)	3x30=90	0.651	0.317	RO		0.968	14.933	14.933								0.000	68	29	29	0.204	
7	DHARASU (MB-II)	4x 76 = 304	0.260	1.059	0.250	PO	1.569	26.490	26.490								0.000	228	96	81	0.684	Unit 4 is in AM since 26.03.2026
8	CHILLA	4x 36 = 144	0.256	0.659	0.638	RMU	1.553	25.713	25.713								0.000	94	40	32	0.282	Unit 4 is in RMU since 07.11.2024
9	RAMGANGA	3x 66 = 198	RO	RO	RO		0.000	0.000	0.000								0.000	0	0	0	0.000	
10	KHATIMA	3x 13.8 =41.40	PO	0.285	0.014		0.299	6.100	6.100								0.000	15	6	8	0.045	Unit 1 is in AM since 06.03.2026
11	VYASI	2x60=120	PO	0.318			0.318	6.462	6.462								0.000	60	25	25	0.180	Unit 1 is in AM since 10.04.2026
12	PATHRI	3x6.8=20.4	PO	0.104	0.115		0.219	3.964	3.964								0.000	11.8			0.035	Unit 1 is in Capital Maintenance since 20.02.2026,
13	MOHD. PUR	3x 3.1 =9.30	0.058	0.059	PO		0.117	1.979	1.979								0.000	5.5			0.017	Unit 3 is in Capital Maintenance since 02.02.2026
14	GALOGI	3X1+0.5 = 3.5	RO	RO	RO	0.016	0.016	0.277	0.277								0.000	0.7			0.001	
15	DUNAO	2x.75=1.5	0.004	RO			0.004	0.120	0.12								0.000	0.3			0.002	
16	PILANG GAD	2x1.125=2.25	0.013	0.014			0.027	0.750	0.75								0.000	1.9			0.006	
17	URGAM	2x1.5=3.00	0.023	RO			0.023	0.548	0.548								0.000	1.5			0.006	
18	KALIGANGA-I	2x2=4.00	0.017	RO			0.017	0.196	0.196								0.000	1.2			0.007	
19	KALIGANGA-II	2x2.25=4.5	RO	0.034			0.034	0.342	0.342								0.000	2.3			0.013	
20	SURINGAD-II	2x2.5=5	0.031	RO			0.031	0.605	0.605								0.000	1.5			0.009	
21	MADHYAMAHESHWAR	3x5=15	RO	RO	0.100		0.100	1.760	1.760								0.000	5.0			0.039	
TOTAL							8.348	144.123	144.123	0.000	0.000	0.000	0.000	0.000	0.000	0.000	804.65				2.453	

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
 MD UJVNL/MD UPCL
 Director(Operation) /Director(Project)/Director(Finance) Director(HR)

Dy. General Manager (Technical)