

Daily Generation Report of 26 April 2026

Reporting Date 27 April 2026

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. in FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks	
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total						
1	CHIBRO	4x60=240	PO	0.891	0.251	0.593	1.736	35.068	35.068							0.000	150	63	64	0.450	Unit 1 is in Capital Maintenance since 27.01.2026	
2	KHODRI	4x 30 = 120	PO	0.314	0.439	0.125	0.877	17.798	17.798							0.000	76	32	31	0.228	Unit 1 is in Capital Maintenance since 28.01.2026	
3	DHAKRANI	3x11.25=33.75	0.164	0.178	RMU		0.342	7.809	7.809							0.000	23	10	10	0.069	Unit 3 is in RMU Since 30.10.2025	
4	DHALIPUR	3x17 = 51	0.268	RO	0.235		0.503	11.238	11.238							0.000	33	14	14	0.099		
5	KULHAL	3x 10= 30	0.188	PO	0.144		0.332	7.643	7.643							0.000	20	8	8	0.060	Unit 2 is in CM since 07.03.2026	
6	TILOTH (MB-I)	3x30=90	0.203	0.629	0.713		1.544	24.412	24.412							0.000	95	40	31	0.284		
7	DHARASU (MB-II)	4x 76 = 304	1.086	0.245	1.162	PO	2.493	42.160	42.160							0.000	228	96	85	0.684	Unit 4 is in AM since 26.03.2026	
8	CHILLA	4x 36 = 144	0.502	0.739	0.678	RMU	1.919	38.883	38.883							0.000	96	40	33	0.288	Unit 4 is in RMU since 07.11.2024	
9	RAMGANGA	3x 66 = 198	0.769	0.918	0.894		2.581	12.240	12.240							0.000	108	46	7	0.324		
10	KHATIMA	3x 13.8 =41.40	PO	0.294	0.257		0.551	9.693	9.693							0.000	27	11	9	0.081	Unit 1 is in AM since 06.03.2026	
11	VYASI	2x60=120	PO	0.373			0.373	9.006	9.006							0.000	60	25	25	0.180	Unit 1 is in AM since 10.04.2026	
12	PATHRI	3x6.8=20.4	PO	0.128	0.147		0.275	6.195	6.195	0.102				0.010		0.112	13.0			0.039	Unit 1 is in Capital Maintenance since 20.02.2026, Loss due to CM of U#1 & Thurst bearing cooling water problem	
13	MOHD. PUR	3x 3.1 =9.30	0.056	0.058	PO		0.114	2.924	2.924							0.000	5.2			0.016	Unit 3 is in Capital Maintenance since 02.02.2026	
14	GALOGI	3X1+0.5 = 3.5	RO	0.001	RO	0.016	0.017	0.409	0.409							0.000	0.7			0.001		
15	DUNAO	2x.75=1.5	0.002	RO			0.002	0.145	0.14							0.000	0.5			0.000		
16	PILANG GAD	2x1.125=2.25	RO	0.004			0.004	1.011	1.01							0.000	0.5			0.005		
17	URGAM	2x1.5=3.00	0.035	RO			0.035	0.746	0.746							0.000	1.5			0.008		
18	KALIGANGA-I	2x2=4.00	0.025	RO			0.025	0.423	0.423							0.000	1.9			0.009		
19	KALIGANGA-II	2x2.25=4.5	0.041	RO			0.041	0.660	0.660							0.000	2.3			0.014		
20	SURINGAD-II	2x2.5=5	0.028	RO			0.028	0.832	0.832							0.000	1.4			0.008		
21	MADHYAMAHESHWAR	3x5=15	0.012	0.041	0.050		0.104	2.668	2.668							0.000	6.5			0.056		
TOTAL							13.896	231.962	231.962	0.102	0.000	0.000	0.000	0.010	0.000	0.112	949.04				2.903	

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
 MD UJVNL/MD UPCL
 Director(Operation) /Director(Project)/Director(Finance) Director(HR)

Dy. General Manager (Technical)