

Daily Generation Report of 12 May 2026

Reporting Date 13 May 2026

| SL NO | Name Of Power Station | CAPACITY (MW) | GENERATION OF THE DAY (MU) | | | | | Cumulative Gen. of the month till date (MU) | Cumulative Gen. in FY till date (MU) | LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU) | | | | | | | Declared Capacity (MW)/ Peak Load | PAF of the Day | Av PAF of the month | Generation in M/E Peaking hrs (MU) | Remarks | | |
|--------------|-----------------------|----------------|----------------------------|--------|--------|--------|---------------|---|--------------------------------------|---|---------------------------------|-------------------------------------|----------------------|----------------|-------------------------|--------------|-----------------------------------|----------------|---------------------|------------------------------------|--------------|---|---|
| | | | Unit-1 | Unit-2 | Unit-3 | Unit-4 | Total | | | B/D of Equipment | System Condition & Grid Failure | Flushing & choking / High Head Loss | Flood Pass/ High PPM | Planned Outage | Unusual & Other Reasons | Total | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | CHIBRO | 4x60=240 | PO | PO | 0.883 | 1.215 | 2.097 | 17.231 | 59.099 | | | | | | | | 0.000 | 105 | 44 | 53 | 0.315 | Unit #1 is in Capital Maintenance since 27.01.2026 Unit # 2 is in AM since 09.05.2026 | |
| 2 | KHODRI | 4x 30 = 120 | PO | 0.452 | 0.627 | FO | 1.078 | 8.826 | 30.032 | | | | | | | | 0.000 | 54 | 23 | 27 | 0.162 | Unit #1 is in Capital Maintenance since 28.01.2026 Unit # 4 is in FO since 07.05.2026 | |
| 3 | DHAKRANI | 3x11.25=33.75 | 0.224 | 0.224 | RMU | | 0.447 | 3.983 | 13.248 | | | | | | | | 0.000 | 23 | 10 | 10 | 0.069 | Unit # 3 is in RMU Since 30.10.2025 | |
| 4 | DHALIPUR | 3x17 = 51 | 0.326 | PO | 0.329 | | 0.655 | 5.740 | 19.079 | | | | | | | | 0.000 | 34 | 14 | 14 | 0.101 | Unit # 2 is in AM since 29.04.2026 | |
| 5 | KULHAL | 3x 10= 30 | 0.216 | PO | 0.218 | | 0.435 | 3.882 | 12.898 | | | | | | | | 0.000 | 20 | 8 | 8 | 0.060 | Unit # 2 is in CM since 07.03.2026 | |
| 6 | TILOTH (MB-I) | 3x30=90 | 0.426 | 0.646 | 0.611 | | 1.683 | 15.258 | 46.243 | | | | | | | | 0.000 | 95 | 40 | 40 | 0.284 | | |
| 7 | DHARASU (MB-II) | 4x 76 = 304 | 1.229 | 0.347 | 1.049 | PO | 2.625 | 25.406 | 78.479 | | | | | | | | 0.000 | 230 | 97 | 97 | 0.690 | Unit # 4 is in AM since 26.03.2026 | |
| 8 | CHILLA | 4x 36 = 144 | 0.594 | 0.645 | 0.665 | RMU | 1.904 | 24.131 | 71.033 | | | | | | | | 0.000 | 95 | 40 | 40 | 0.285 | Unit # 4 is in RMU since 07.11.2024 | |
| 9 | RAMGANGA | 3x 66 = 198 | 0.740 | 0.816 | 0.816 | | 2.372 | 30.354 | 52.108 | | | | | | | | 0.000 | 99 | 42 | 44 | 0.297 | | |
| 10 | KHATIMA | 3x 13.8 =41.40 | PO | 0.135 | 0.137 | | 0.272 | 6.058 | 18.177 | 0.004 | | | | | | | 0.008 | 0.012 | 27 | 11 | 11 | 0.081 | Unit # 1 is in AM since 06.03.2026 . Loss due to abnormal sound in U#3 & U#2 Hydraulic Overspeed |
| 11 | VYASI | 2x60=120 | 0.194 | RO | | | 0.194 | 4.201 | 14.734 | | | | | | | | 0.100 | 0.100 | 60 | 25 | 31 | 0.180 | Loss due to Gate maintenance work at Juddo dam |
| 12 | PATHRI | 3x6.8=20.4 | PO | 0.160 | 0.164 | | 0.324 | 3.531 | 10.914 | | 0.007 | | | 0.159 | | | 0.166 | 13.8 | | | 0.041 | Unit 1 is in Capital Maintenance since 20.02.2026 Loss due to Grid Disturbance, Capital maintenance of U#1 | |
| 13 | MOHD. PUR | 3x 3.1 =9.30 | 0.050 | 0.055 | PO | | 0.105 | 1.332 | 4.715 | | 0.009 | | | 0.020 | | | 0.029 | 5.1 | | | 0.015 | Unit 3 is in Capital Maintenance since 02.02.2026 Loss due to Grid Disturbance, Capital maintenance of U#3 | |
| 14 | GALOGI | 3X1+0.5 = 3.5 | RO | RO | RO | 0.018 | 0.018 | 0.160 | 0.631 | | | | | | | | 0.000 | 0.7 | | | 0.001 | | |
| 15 | DUNAO | 2x.75=1.5 | 0.002 | 0.007 | | | 0.009 | 0.114 | 0.27 | | | | | | | | 0.000 | 0.4 | | | 0.002 | | |
| 16 | PILANG GAD | 2x1.125=2.25 | RO | 0.024 | | | 0.024 | 0.161 | 1.21 | | | | | | | | 0.000 | 1.0 | | | 0.006 | | |
| 17 | URGAM | 2x1.5=3.00 | 0.034 | PO | | | 0.034 | 0.392 | 1.267 | | | | | | | | 0.000 | 1.5 | | | 0.009 | Unit 2 is in CM since 05.04.2026 | |
| 18 | KALIGANGA-I | 2x2=4.00 | 0.040 | RO | | | 0.040 | 0.396 | 0.935 | | | | | | | | 0.000 | 2.0 | | | 0.011 | | |
| 19 | KALIGANGA-II | 2x2.25=4.5 | 0.038 | RO | | | 0.038 | 0.449 | 1.279 | | | | | | | | 0.000 | 2.3 | | | 0.013 | | |
| 20 | SURINGAD-II | 2x2.5=5 | 0.030 | RO | | | 0.030 | 0.246 | 1.174 | | | | | | | | 0.000 | 1.7 | | | 0.008 | | |
| 21 | MADHYAMAHESHWAR | 3x5=15 | RO | 0.099 | 0.092 | | 0.191 | 2.132 | 5.419 | | | | | | | | 0.000 | 10.0 | | | 0.072 | | |
| TOTAL | | | | | | | 14.576 | 153.985 | 442.946 | 0.004 | 0.016 | 0.000 | 0.000 | 0.179 | 0.108 | 0.307 | 879.52 | | | | 2.702 | | |

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-
 Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
 MD UJVNL/MD UPCL
 Director(Operation) /Director(Project)/Director(Finance) Director(HR)

Dy. General Manager (Technical)