

Daily Generation Report of 15 May 2026

Reporting Date 16 May 2026

| SL NO | Name Of Power Station | CAPACITY (MW) | GENERATION OF THE DAY (MU) | | | | | Cumulative Gen. of the month till date (MU) | Cumulative Gen. in FY till date (MU) | LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU) | | | | | | | Declared Capacity (MW)/ Peak Load | PAF of the Day | Av PAF of the month | Gen. in M/E Peaking hrs (MU) | Remarks | |
|--------------|-----------------------|-----------------|----------------------------|--------|--------|--------|---------------|---|--------------------------------------|---|---------------------------------|-------------------------------------|----------------------|----------------|-------------------------|--------------|-----------------------------------|----------------|---------------------|------------------------------|--------------|---|
| | | | Unit-1 | Unit-2 | Unit-3 | Unit-4 | Total | | | B/D of Equipment | System Condition & Grid Failure | Flushing & Choking / High Head Loss | Flood Pass/ High PPM | Planned Outage | Unusual & Other Reasons | Total | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | |
| 1 | CHIBRO | 4x60=240 | PO | PO | 0.722 | 0.973 | 1.695 | 22.371 | 64.239 | | | | | | | | 0.000 | 105 | 44 | 51 | 0.315 | Unit #1, is in Capital Maintenance since 27.01.2026 Unit # 2 is in AM since 09.05.2026 |
| 2 | KHODRI | 4x 30 = 120 | PO | 0.369 | 0.508 | FO | 0.877 | 11.485 | 32.691 | | | | | | | | 0.000 | 54 | 23 | 26 | 0.162 | Unit #1, is in Capital Maintenance since 28.01.2026 Unit # 4, is in FO since 07.05.2026 |
| 3 | DHAKRANI | 3x11.25=33.75 | 0.215 | 0.152 | RMU | | 0.367 | 5.070 | 14.335 | | | | | | | | 0.000 | 23 | 10 | 10 | 0.069 | Unit # 3, is in RMU Since 30.10.2025 |
| 4 | DHALIPUR | 3x17 = 51 | 0.294 | PO | 0.234 | | 0.529 | 7.294 | 20.633 | | | | | | | | 0.000 | 34 | 14 | 14 | 0.101 | Unit # 2, is in AM since 29.04.2026 |
| 5 | KULHAL | 3x 10= 30 | 0.144 | PO | 0.210 | | 0.354 | 4.760 | 13.775 | | | | | | | | 0.000 | 20 | 8 | 8 | 0.060 | Unit # 2, is in CM since 07.03.2026 |
| 6 | TILOTH (MB-I) | 3x30=90 | 0.580 | 0.553 | 0.608 | | 1.740 | 20.529 | 51.514 | | | | | | | | 0.000 | 95 | 40 | 40 | 0.284 | |
| 7 | DHARASU (MB-II) | 4x 76 = 304 | 0.381 | 1.360 | 1.033 | PO | 2.774 | 34.077 | 87.150 | | | | | | | | 0.000 | 230 | 97 | 97 | 0.690 | Unit # 4, is in AM since 26.03.2026 |
| 8 | CHILLA | 4x 36 = 144 | 0.570 | 0.612 | 0.576 | RMU | 1.758 | 29.605 | 76.507 | | | | | | | | 0.000 | 92 | 39 | 40 | 0.276 | Unit # 4, is in RMU since 07.11.2024 |
| 9 | RAMGANGA | 3x 66 = 198 | 0.740 | 0.816 | 0.816 | | 2.372 | 37.470 | 59.224 | | | | | | | | 0.000 | 99 | 42 | 44 | 0.297 | |
| 10 | KHATIMA | 3x 13.8 =41.40 | PO | 0.303 | 0.278 | | 0.581 | 7.690 | 19.809 | | | | | | | 0.008 | 0.008 | 27 | 11 | 11 | 0.081 | Unit # 1, is in AM since 06.03.2026 , Loss due to abnormal sound in Unit # 3 |
| 11 | VYASI | 2x60=120 | 0.200 | 0.206 | | | 0.406 | 5.494 | 16.027 | | | | | | | | 0.000 | 120 | 51 | 33 | 0.360 | |
| 12 | PATHRI | 3x6.8=20.4 | PO | 0.162 | 0.167 | | 0.329 | 4.500 | 11.883 | | | | | 0.158 | | | 0.158 | 13.9 | | | 0.042 | Unit #1, is in Capital Maintenance since 20.02.2026 Loss due to Capital maintenance of Unit #1 |
| 13 | MOHD. PUR | 3x 3.1 =9.30 | 0.061 | 0.065 | PO | | 0.125 | 1.658 | 5.041 | | | | | 0.016 | | | 0.016 | 5.5 | | | 0.017 | Unit #3, is in Capital Maintenance since 02.02.2026 Loss due to Capital maintenance of Unit #3 |
| 14 | GALOGI | 3X1+0.5 = 3.5 | RO | RO | RO | 0.017 | 0.017 | 0.210 | 0.681 | | | | | | | | 0.000 | 0.7 | | | 0.001 | |
| 15 | DUNAO | 2x.75=1.5 | 0.003 | 0.003 | | | 0.006 | 0.135 | 0.29 | | | | | | | | 0.000 | 0.3 | | | 0.002 | |
| 16 | PILANG GAD | 2x1.125=2.25 | RO | 0.021 | | | 0.021 | 0.200 | 1.25 | | | | | | | | 0.000 | 1.0 | | | 0.006 | |
| 17 | URGAM | 2x1.5=3.00 | 0.036 | PO | | | 0.036 | 0.492 | 1.367 | | | | | | | | 0.000 | 1.5 | | | 0.009 | Unit #2, is in CM since 05.04.2026 |
| 18 | KALIGANGA-I | 2x2=4.00 | 0.041 | RO | | | 0.041 | 0.504 | 1.043 | | | | | | | | 0.000 | 2.0 | | | 0.012 | |
| 19 | KALIGANGA-II | 2x2.25=4.5 | RO | 0.030 | | | 0.030 | 0.574 | 1.405 | | | | | | | | 0.000 | 2.3 | | | 0.014 | |
| 20 | SURINGAD-II | 2x2.5=5 | 0.045 | RO | | | 0.045 | 0.336 | 1.263 | | | | | | | | 0.000 | 2.1 | | | 0.012 | |
| 21 | MADHYAMAHESHWAR | 3x5=15 | RO | 0.091 | 0.092 | | 0.182 | 2.685 | 5.972 | | | | | | | | 0.000 | 10.0 | | | 0.074 | |
| TOTAL | | 1440.600 | | | | | 14.284 | 197.139 | 486.100 | 0.000 | 0.000 | 0.000 | 0.000 | 0.175 | 0.008 | 0.183 | 937.28 | | | | 2.881 | |

AM - Annual Maintenance, CM - Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-
Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
MD UJVNL/MD UPCL
Director(Operation) / Director(Project) / Director(Finance) / Director(HR)

Dy. General Manager (Technical)