

Daily Generation Report of 12 May 2026

Reporting Date 13 May 2026

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. in FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total					
1	CHIBRO	4x60=240	PO	PO	0.883	1.215	2.097	17.231	59.099							0.000	105	44	53	0.315	Unit #1 is in Capital Maintenance since 27.01.2026 Unit # 2 is in AM since 09.05.2026
2	KHODRI	4x 30 = 120	PO	0.452	0.627	FO	1.078	8.826	30.032							0.000	54	45	53	0.162	Unit #1 is in Capital Maintenance since 28.01.2026 Unit # 4 is in FO since 07.05.2026
3	DHAKRANI	3x11.25=33.75	0.224	0.224	RMU		0.447	3.983	13.248							0.000	23	69	69	0.069	Unit # 3 is in RMU Since 30.10.2025
4	DHALIPUR	3x17 = 51	0.326	PO	0.329		0.655	5.740	19.079							0.000	34	66	66	0.101	Unit # 2 is in AM since 29.04.2026
5	KULHAL	3x 10= 30	0.216	PO	0.218		0.435	3.882	12.898							0.000	20	67	67	0.060	Unit # 2 is in CM since 07.03.2026
6	TILOTH (MB-I)	3x30=90	0.426	0.646	0.611		1.683	15.258	46.243							0.000	95	106	106	0.284	
7	DHARASU (MB-II)	4x 76 = 304	1.229	0.347	1.049	PO	2.625	25.406	78.479							0.000	230	76	76	0.690	Unit # 4 is in AM since 26.03.2026
8	CHILLA	4x 36 = 144	0.594	0.645	0.665	RMU	1.904	24.131	71.033							0.000	95	67	67	0.285	Unit # 4 is in RMU since 07.11.2024
9	RAMGANGA	3x 66 = 198	0.740	0.816	0.816		2.372	30.354	52.108							0.000	99	50	54	0.297	
10	KHATIMA	3x 13.8 =41.40	PO	0.135	0.137		0.272	6.058	18.177	0.004					0.008	0.012	27	66	66	0.081	Unit # 1 is in AM since 06.03.2026 . Loss due to abnormal sound in U#3 & U#2 Hydraulic Overspeed
11	VYASI	2x60=120	0.194	RO			0.194	4.201	14.734						0.100	0.100	60	51	61	0.180	Loss due to Gate maintenance work at Juddo dam
12	PATHRI	3x6.8=20.4	PO	0.160	0.164		0.324	3.531	10.914		0.007			0.159		0.166	13.8			0.041	Unit 1 is in Capital Maintenance since 20.02.2026 Loss due to Grid Disturbance, Capital maintenance of U#1
13	MOHD. PUR	3x 3.1 =9.30	0.050	0.055	PO		0.105	1.332	4.715		0.009			0.020		0.029	5.1			0.015	Unit 3 is in Capital Maintenance since 02.02.2026 Loss due to Grid Disturbance, Capital maintenance of U#3
14	GALOGI	3X1+0.5 = 3.5	RO	RO	RO	0.018	0.018	0.160	0.631							0.000	0.7			0.001	
15	DUNAO	2x.75=1.5	0.002	0.007			0.009	0.114	0.27							0.000	0.4			0.002	
16	PILANG GAD	2x1.125=2.25	RO	0.024			0.024	0.161	1.21							0.000	1.0			0.006	
17	URGAM	2x1.5=3.00	0.034	PO			0.034	0.392	1.267							0.000	1.5			0.009	Unit 2 is in CM since 05.04.2026
18	KALIGANGA-I	2x2=4.00	0.040	RO			0.040	0.396	0.935							0.000	2.0			0.011	
19	KALIGANGA-II	2x2.25=4.5	0.038	RO			0.038	0.449	1.279							0.000	2.3			0.013	
20	SURINGAD-II	2x2.5=5	0.030	RO			0.030	0.246	1.174							0.000	1.7			0.008	
21	MADHYAMAHESHWAR	3x5=15	RO	0.099	0.092		0.191	2.132	5.419							0.000	10.0			0.072	
TOTAL		1440.60					14.576	153.985	442.946	0.004	0.016	0.000	0.000	0.179	0.108	0.307	879.52			2.702	
AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning																					

Distributed to:-
Chairman /Principal Secretary(Energy) Govt of Uttarakhand.
MD UUVNL/MD UPCL
Director(Operation) /Director(Project)/Director(Finance)/ Director(HR)

Dy. General Manager (Technical)