

Daily Generation Report of 24 July 2026

Reporting Date 25 July 2026

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. In FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity	PAF of the Day	Avg. PAF of the month	Gen. In M/E Peaking hrs (MU)	Remarks
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & Choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total					
1	CHIBRO	4x60=240	1.259	1.247	1.256	1.110	4.872	96.012	247.351							0.000	199.0	82.9	73.5	0.597	
2	KHODRI	4x 30 = 120	0.541	0.526	0.556	0.529	2.152	44.981	121.797							0.000	89.0	74.2	68.5	0.267	
3	DHAKRANI	3x11.25=33.75	0.268	0.273	0.271		0.812	17.187	49.663							0.000	34.0	100.7	98.3	0.102	
4	DHALIPUR	3x17 = 51	0.405	0.403	0.402		1.210	26.252	73.010							0.000	50.7	99.4	99.1	0.152	
5	KULHAL	3x 10= 30	0.247	0.237	0.234		0.718	14.935	45.547							0.000	30.0	100.0	99.1	0.090	
6	TILOTH (MB-I)	3x30=90	0.722	0.549	0.796		2.067	48.496	192.021	0.093						0.093	94.5	105.0	103.6	0.284	Due to repairing of head cover balancing pipe in unit #2
7	DHARASU (MB-II)	4x 76 = 304	1.929	1.726	1.830	1.841	7.326	162.870	442.261							0.000	305.0	100.3	99.5	0.915	
8	CHILLA	4x 36 = 144	0.707	0.788	0.640	RMU	2.135	48.095	218.329			0.035		0.433		0.468	90.0	62.5	62.5	0.270	Unit # 4 is in RMU since 07.11.2024 Loss due to RMU and Flushing- Choking
9	RAMGANGA	3x 66 = 198	RO	RO	RO		0.000	9.613	163.301							0.000	0.0	0.0	9.7	0.000	
10	KHATIMA	3x 13.8 =41.40	0.286	0.296	0.300		0.882	18.552	67.295							0.000	38.0	91.8	90.9	0.114	
11	VYASI	2x60=120	1.459	1.449			2.908	46.619	79.264							0.000	120.0	100.0	97.9	0.360	
12	PATHRI	3x6.8=20.4	PO	0.121	0.138		0.259	4.748	30.166							0.000	12.1			0.036	Unit #1 is in Capital Maintenance since 20.02.2026
13	MOHD. PUR	3x3.1 =9.30	0.054	0.035	0.049		0.138	2.358	12.193							0.000	6.3			0.019	
14	GALOGI	3X1+0.5 = 3.5	RO	0.00658	RO	0.021	0.027	0.428	1.751							0.000	1.2			0.002	
15	DUNAO	2x.75=1.5	RO	0.011			0.011	0.314	0.982							0.000	0.7			0.004	
16	PILANG GAD	2x1.125=2.25	RO	RO			0.000	0.181	2.722				0.012			0.012	0.0			0.000	High PPM
17	URGAM	2x1.5=3.00	RO	0.007			0.007	0.304	2.429							0.000	0.9			0.002	
18	KALIGANGA-I	2x2=4.00	RO	0.042			0.042	0.929	3.631							0.000	2.0			0.011	
19	KALIGANGA-II	2x2.25=4.5	0.039	0.012			0.051	0.977	4.482							0.000	3.0			0.014	
20	SURINGAD-II	2x2.5=5	0.008	0.001			0.009	1.388	4.310							0.000	4.4			0.008	
21	MADHYAMAHESHWAR	3x5=15	RO	0.075	0.037		0.112	2.840	17.234							0.000	9.0			0.059	
TOTAL		1440.600					25.739	548.080	1779.740	0.093	0.000	0.035	0.012	0.433	0.000	0.573	1089.7			3.306	
AM - Annual Maintenance, CM- Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T&C-Testing & Commissioning, S/D- Shut Down																					

Dy. General Manager (Technical)