

Daily Generation Report of 22 July 2026

Reporting Date 23 July 2026

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. In FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Avg. PAF of the month	Gen. in M/E Peaking hrs (MU)	Remarks
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & Choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total					
1	CHIBRO	4x60=240	1.250	1.223	1.230	1.094	4.796	86.270	237.609							0.000	199.0	82.9	72.7	0.597	
2	KHODRI	4x 30 = 120	0.535	0.537	0.564	0.533	2.168	40.670	117.486							0.000	90.0	75.0	68.0	0.270	
3	DHAKRANI	3x11.25=33.75	0.260	0.275	0.272		0.807	15.608	48.084							0.000	34.0	100.7	98.0	0.102	
4	DHALIPUR	3x17 = 51	0.395	0.393	0.392		1.179	23.834	70.592				0.014			0.014	50.7	99.4	99.1	0.152	High PPM
5	KULHAL	3x 10= 30	0.165	0.212	0.158		0.534	13.501	44.113				0.184			0.184	30.0	100.0	99.0	0.090	High PPM
6	TILOTH (MB-I)	3x30=90	0.682	0.788	0.789		2.259	44.171	187.696							0.000	94.5	105.0	103.5	0.284	
7	DHARASU (MB-II)	4x 76 = 304	1.940	1.437	1.874	1.885	7.136	148.648	428.039							0.000	297.0	97.7	99.5	0.891	
8	CHILLA	4x 36 = 144	0.605	0.784	0.669	RMU	2.058	43.859	214.093			0.166		0.305		0.471	86.0	59.7	62.5	0.258	Unit # 4 is in RMU since 07.11.2024 Loss due to RMU and Flushing- Choking
9	RAMGANGA	3x 66 = 198	RO	RO	RO		0.000	9.613	163.301							0.000	0.0	0.0	10.6	0.000	
10	KHATIMA	3x 13.8 =41.40	0.300	0.301	0.294		0.895	16.785	65.528							0.000	40.0	96.6	90.6	0.120	
11	VYASI	2x60=120	1.470	1.449			2.919	40.799	73.443							0.000	120.0	100.0	97.7	0.360	
12	PATHRI	3x6.8=20.4	PO	0.102	0.125		0.227	4.249	29.667			0.026				0.026	12.4			0.037	Unit #1 is in Capital Maintenance since 20.02.2026 Loss due Choking
13	MOHD. PUR	3x3.1 =9.30	0.048	0.041	0.012		0.101	2.103	11.937	0.008		0.010				0.018	6.2			0.019	Loss due to Choking and TGB Vibration Testing of Unit 3
14	GALOGI	3X1+0.5 = 3.5	RO	0.00441	RO	0.020	0.025	0.377	1.700							0.000	1.2			0.002	
15	DUNAO	2x.75=1.5	RO	0.013			0.013	0.289	0.957							0.000	0.7			0.004	
16	PILANG GAD	2x1.125=2.25	RO	RO			0.000	0.169	2.710				0.008			0.008	0.0			0.000	High PPM
17	URGAM	2x1.5=3.00	RO	RO			0.000	0.287	2.412				0.015			0.015	0.0			0.000	High PPM
18	KALIGANGA-I	2x2=4.00	RO	0.042			0.042	0.845	3.546							0.000	2.0			0.012	
19	KALIGANGA-II	2x2.25=4.5	0.020	0.005			0.025	0.880	4.386							0.000	2.3			0.013	
20	SURINGAD-II	2x2.5=5	0.024	0.028			0.052	1.317	4.239							0.000	5.0			0.012	
21	MADHYAMAHESHWAR	3x5=15	RO	0.092	0.019		0.112	2.598	16.992							0.000	9.4			0.050	
TOTAL		1440.600					25.349	496.871	1728.531	0.008	0.000	0.201	0.221	0.305	0.000	0.736	1080.4			3.272	
AM - Annual Maintenance, CM- Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T&C-Testing & Commissioning, S/D- Shut Down																					

Dy. General Manager (Technical)