

**F. No.: 238/17/2017-Wind  
Government of India  
Ministry of New and Renewable Energy  
Wind Energy Division**

**Atal Akshaya Urja Bhawan,  
CGO Complex, Lodi Road, New Delhi-110003  
Dated: 09<sup>th</sup> April, 2025**

**CIRCULAR**

**Subject: Draft revised guidelines for installation of prototype wind turbine models -reg.**

The undersigned is directed to forward herewith draft revised guidelines for installation of prototype wind turbine models for stakeholders' consultation.

2. In this regard, all the concerned stakeholders are requested to provide the comments within three (03) weeks to Virendra Singh Naruka, SO [@vsnaruka.mnre@gov.in](mailto:@vsnaruka.mnre@gov.in).



**(Rishikesh Vaishnav)  
Scientist 'C'**

**Email ID: rishikesh.mnre@gov.in**

**To  
All Concerned**



**DRAFT**

**F. No.: 238/17/2017-Wind  
Ministry of New and Renewable Energy  
(Wind Energy Division)**

**Atal Akshaya Urja Bhawan,  
CGO Complex, Lodhi Road, New Delhi-11003**

**Date: \_\_\_\_\_**

**Subject: Revised guidelines for installation of prototype wind turbine models -reg.**

Ministry had issued guidelines for installation of prototype wind turbine models on 22.05.2012 and amended the same on 20.09.2012 and on 01.06.2016. These guidelines are being issued in suppression of the existing guidelines in order to facilitate the installation of limited number of prototype wind turbines so as to promote testing and certification process of wind turbine in the country.

These guidelines are applicable for all the wind turbine manufacturers in India, who wish to install prototype wind turbine model(s) in the country and synchronize with the Indian grid system. It is desirable to allocate land on "footprint basis" for installation of prototype wind turbine(s).

The installation of a prototype wind turbine model will be allowed only to carry out type testing for obtaining type certificate from Internationally Accredited Certifying Agencies, subject to the following conditions:

**(i) Implementing Agency:**

The guidelines will be implemented by the National Institute of Wind Energy (NIWE), Chennai. The manufacturer(s) of the wind turbine whose prototype is to be installed, shall submit requisite information and documentation as per the prescribed format (to be provided by NIWE) to NIWE, Chennai for obtaining recommendation to permit installation of wind turbine prototype model for testing and grid synchronization / commissioning.

**(ii) Eligibility for Type Certification Schemes and documents required to be submitted with application:**

- a. The type certification scheme shall be in accordance with IEC scheme in vogue presently, given below.
  - IECRE OD 501
  - IS/IEC 61400-22:2010
- b. The type testing and certification shall be carried out only by Internationally Accredited Testing and Certification bodies.
- c. Prototype certificate for the prototype wind turbine model (to be installed at a specific location) shall be provided to NIWE by the Wind turbine manufacturer.



- d. The manufacturer(s) of wind turbines shall provide copies of contracts signed for type testing and type certificate with Internationally Accredited Testing and Certification Bodies.
- e. The prototype certificate shall have a maximum validity period of 3 years. Extension of prototype certificate validity may be allowed subject to the compliance of the conditions stipulated in the clause 6.3: "Prototype Certification" of IECRE OD501 and submission of revised/modified prototype certificate for the same prototype wind turbine model to NIWE. In addition, a list of changes/modifications and a list of new components/ parts used in the modified prototype wind turbine issued by the type certification body shall have to be provided to NIWE along with revised/modified prototype certificate to obtain the revised recommendation letter to carryout type testing.
- f. A letter issued by the type testing and type certification body on the status of type testing and type certification shall be provided at the end of every year to NIWE.

(iii) Operation and Maintenance:

1. Regular maintenance and service shall be carried out for the prototype wind turbines installed. The type certification body will provide a letter at the end of the year regarding regular operation and maintenance of prototype wind turbines. Failing which the wind turbines are liable to be disconnected from the grid.
2. A maximum period of 3 years from date of issuance of recommendation letter from NIWE for the prototype wind turbines will be allowed to complete testing and for obtaining the type certificate. However, validity of prototype certificate shall be maintained till the type certificate is issued. In case of submission of revised/modified prototype certificate for the existing prototype wind turbine model and after obtaining the revised recommendation letter from NIWE to carryout type testing, the testing and certification shall have to be completed and type certificate shall be submitted within the validity period of prototype certificate.
3. A maximum period of 18 months from date of issuance of recommendation letter from NIWE, within which all the prototype wind turbines shall be commissioned / grid synchronized.
4. Commissioning certificate / grid synchronization report for the prototype wind turbines, issued by the concerned State utility / SNA shall be provided by manufacturer to NIWE, immediately after the commissioning / grid synchronization.
5. Since higher capacity wind turbines such as 5.2 MW is already available in the Indian market, it is suggested to mention the number of prototype turbines instead of MW.
6. The type certificate for prototype wind turbine model shall be obtained from an Internationally Accredited Type Certification Body as per the scheme mentioned in Para-1(ii) within the 3 years from the letter of NIWE. In case of submission of modified/revised prototype certificate, the type certificate shall have to be submitted within the validity period of revised/modified prototype certificate, failing which such installed prototype wind turbine(s) shall be immediately disconnected from the grid and uprooted at the cost of manufacturer(s).
7. The prototype wind turbines shall be owned by the concerned wind turbine manufacturer and shall not be sold to any party, until the model is included in Revised List of Models and Manufacturers of wind turbines (RLMM).
8. Serial production and installation of prototype wind turbines will not be allowed until the wind turbine model is included in RLMM.
9. The components / items procured / imported for manufacturing of the prototype wind turbines will be new and unused. No second-hand components / machines will be allowed.



10. The components / items procured / imported for manufacturing of the prototype wind turbines will be new and unused. No second-hand components / machines will be allowed. However, the changes/modification to the already installed prototype wind turbine will be allowed as per the clause II(e) above.
11. An Affidavit and indemnity bond have to be submitted by the manufacturers to the State utility/ SNA and NIWE for complying to the above conditions. The format of the indemnity bond can be obtained from NIWE.
12. If one or more of the conditions mentioned above are not satisfied, the permission granted for the prototype installation and testing can be withdrawn unilaterally in the interest of safety and security.
13. This issues with the approval of Secretary, MNRE.

**(Rishikesh Vaishnav)**  
**Scientist-‘C’**

**To**

**All concerned.**