

Sub:- Regarding application for issue of Occupancy Certificate.

Ref:- Application dated. 10/04/2017 for granting Occupancy Certificate for Industrial building on land bearing Survey No. 321/1, 322/1, 322/2, 322/3, 323/1 & 323 of Village Kachigam, Nani Daman of U.T. of Daman and Diu.


With reference to your application referred to above, it is to inform that the proposal for grant of Occupancy Certificate for building on land bearing Survey No. 321/1, 322/1, 322/2, 322/3, 323/1 & 323 of Village Kachigam is scrutinized from planning point of view and as per the site inspection on 15/05/2017 following points are observed.


1. Side set back and Rear set back are not as per approved building plan.
2. Applicant has not provided Rain Water Harvesting system in constructed building.

In view of the above, we may not considered the proposal for Occupancy Certificate of Industrial Shed building from planning point of view.

DFA is put up for approval please.



MS(PDA)/ATP Pls. put up fair copy.


16/05/2017 PD(J)


17/5 Sh. Jayesh

Fair copy is put up for sign. please.

MS (PDA) / ATP
Signed.


16/05/17

17/05/17

LOG