

Name of the unit	Baader Schylz Laboratories	
Address	Plot No. J/6, OI DC, Mahatma Gandhi Udyog Nagar, Dabhel, Daman.	
Area	Dabhel	
Category	Category - II	
Applied for	Consent to Operate (D.G. set- 45 KVA – 01 no.)	
Consent granted for	Consent to Establish	
Sr. No.	Documents required	Submitted
1.	Application in Form XIII under Water Act.	NA
2.	Application in Form I under Air Act.	Yes (C/133)
3.	Declaration letter showing capital investment.	Yes (C/129)
4.	Copy of Consent to Establish obtained under Water and Air Act.	Yes (C/127)
4.	Consent fees of Rs. 5500/- in form of DD under Air Act.	Yes (C/131)
5.	Display Sign Board.	Yes (C/115)
6.	Application for authorization to handle hazardous waste and industry data sheet in Form – I.	Yes (C/113)
7.	Industry Data Sheet Format	Yes (C/119)
8.	Copy of hazardous waste manifest in Form 13.	Not submitted
9.	Copy of membership of common TSDF.	Not submitted
10.	Copy of analysis of treated effluent.	Not submitted
11.	Copy of stack monitoring report and ambient air quality monitoring report.	Yes (C/125, C/123)
Effluent discharge with quantity		
	Consumption	Discharge
Domestic water	500 Lit./Day	500 Lit./Day
Industrial water	1000 Lit./Day	1000 Lit./Day
Air Emission		
Installation	Fuel used	Stack/Acoustic
D.G. sets (45 KVA-01 no.)	Diesel	Yes
Details of Effluent Treatment Plant/APCDS		
ETP	Yes	
APCD	No	
Monitoring Reports		
Effluent Norms		
	Norms as per consent	As per report
pH	6.5-9.0	--
Suspended Solids	Not to exceed 100 mg/Lit	--
BOD	Not to exceed 100 mg/Lit	--
COD	Not to exceed 250 mg/Lit	--
Oil & grease	Not to exceed 10 mg/Lit	--

Air Emission from Stack of D.G. set

	Norms as per consent	As per report
	D. G. set (45 KVA)	
Particulate Matter	150 mg/Nm ³	43
SO ₂	40 mg/Nm ³	22
NOx	25 mg/Nm ³	10

Observations and Recommendations :

The unit was inspected on 31/08/2017 and at the time of inspection following observations were noted:

- Display signboard was prepared and installed at the main gate of premises.
- The unit was in operation at the time of inspection.
- Products being manufactured at the time of inspection were Capsules, Ointments and Syrups.
- The unit has installed D.G. set of 45 KVA (01 no.) and provided acoustic enclosure.
- The unit has submitted stack monitoring report, noise monitoring report, and ambient air monitoring report.

In view of above, Consent to Operate (Category-II) to "Operate D.G. set of 45 KVA (01 no)" under Air (Prevention & Control of Pollution) Act, 1981 for the period upto 31/08/2020 may be issue.

Submitted for your kind perusal and approval, Sir.

[Signature]
31/08/17

Member Secretary

f/250000-25747/
Dt-27/09/17
Dt-07/10/17

X

Kindly peruse Noti above.

may be approved

Chairman/PCC

[Signature]

राहता, दमण/ Collector, Daman

फाइल / Inward File

F.No. - दिनांक /Dt. 18/9/17

फाइल / Outward File

253344 दिनांक /Dt. 27/09/17

11/16/09/17
Dt-27/09/17

11/16/09/17
Dt-27/09/17