



प्रदुषण नियंत्रण समिति  
Pollution Control Committee

दमण एवं दीव तथा दा.न.ह.  
Daman & Diu and Dadra Nagar Haveli  
1st Floor, Udyog Bhavan, Bhenstora, Nani Daman.

**CATEGORY - II (OPERATE)**

Consent No. PCC/DDD/O-2670/WA/AA/DR/15-16/640

Date :- 04/03/17

In exercise of the powers delegated to the Pollution Control Committee, Daman, Diu and Dadra & Nagar Haveli by the Central Pollution Control Board vide notification No.B-12015/7/92 published in the gazette of India No.746 dated 26/11/1992 and administration order No.45/1(1)/92-F&E/4700 dated 8/2/1993, the consent is hereby granted under Section 25, Sub section (1) & (2) of Water (Prevention & Control of Pollution) Amended Act, 1988 and under Section 21 of Air (Prevention & Control of Pollution) Act, 1981 and the rules and orders made there under to manufacture below mentioned products at the below mentioned address subjected to the following terms and conditions.

Consent is granted to:

**M/s. Laxmi Plastic,**  
**Shed no.1, Ground Floor, Vaghdhara Road,**  
**Near Sterlite Company, Sr. no.33/1/2/2,**  
**Village Dadra, UT of DNH.**

1. The Consent to **Operate** is granted for a period upto **28/02/2022**.
2. The Consent is valid for the manufacture of following items:

Sr. No.	Product	Maximum Production Quantity
1.	Plastic Granules (from 1 <sup>st</sup> generation in house plastic waste/scraps only (excluding PVC))	1200 TPA

3. Conditions under Water Act:

- 3.1 The daily quantity of trade effluent from the factory shall be NIL.
- 3.2 The daily quantity of sewage from the factory shall not exceed 200 Lit/Day.
- 3.3 Trade Effluent: If any the quality of the treated effluent as per PCC norms mentioned below.

(1)	pH	Between	6.5-9.0
(2)	Suspended Solids	Not to exceed	100 mg/L.
(3)	BOD, 3 days, 27°C	Not to exceed	100 mg/L.
(4)	C.O.D.	Not to exceed	250 mg/L.
(5)	Oil & Grease	Not to exceed	10 mg/L.

3.4 Trade Effluent Disposal Outlet Conditions: Industry shall not discharge treated effluent out side factory premises. The treated effluent shall be reused/recycled/incinerated or used for plantation /gardening with in the factory premises:

3.5 Sewage Treatment - Domestic effluent shall be disposed off through septic tank/soak pit system to conform to the following standards.

BOD (5 days at 20 <sup>o</sup> C)	less than 20 mg/l
Suspended solids	less than 30 mg/l
Residual Chlorine	minimum 0.5 mg/l



4. Conditions under Air Act:

4.1 The concentration of the following parameters in the ambient air within the premises of the industry shall not exceed the limits specified hereunder:

Parameter	Permissible Limit
Particulate Matter (size less than 10 $\mu$ m) or PM <sub>10</sub> $\mu$ g/m <sup>3</sup>	100 (24 hours average)
Particulate Matter (size less than 2.5 $\mu$ m) or PM <sub>2.5</sub> $\mu$ g/m <sup>3</sup>	60 (24 hours average)
Oxides of Nitrogen (NO <sub>2</sub> ) $\mu$ g/m <sup>3</sup>	80 (24 hours average)
Oxides of Sulphur (SO <sub>2</sub> ) $\mu$ g/m <sup>3</sup>	80 (24 hours average)

4.2 The applicant shall provide ports in the chimney/stack and facilities such as ladder, platform etc. as per requirements for monitoring the air emissions and the same shall be open for inspection and use by the committees staff. The chimney/stacks attached to various source of emission shall be designated by number such as S-1, S-2 etc and these shall be painted/displayed to facilitate identification.

4.3 There shall be no emission other than the permitted installation and the quarterly stack monitoring report from recognized laboratory shall be submitted along with the renewal application.

5. GENERAL CONDITIONS:-

5.1 Any change in personnel, equipment or working conditions as mentioned in the consents form/order should immediately be intimated to the Pollution Control Committee.

5.2 If at any time, it is observed that effluent fails to conform to the limits prescribed, consent will be withdrawn prohibiting the industry to manufacture either existing or new products.

5.3 The applicant shall submit separate application for obtaining Consent for Operation/Renewal under Water (Prevention and Control of Pollution) Act, 1974, before 30 days of expiry of validity period of Consent.

5.4 The industry shall comply with Water (Prevention and Control of Pollution) Cess Act, 1977, and submit monthly Cess returns as contemplated in the Act, in the prescribed form.

5.5 The applicant shall comply with the notified standards under Environment (Protection) Act, 1986.


5.6 This consent is further subject to green up the surrounding area inside and outside the unit/factory.

5.7 In case of change process/installation, which is likely to have discharge/an emission a separate application shall be made.

5.8 In case of failure to comply with any of the consent conditions, the consent order issue to you stands automatically revoked without any notice on this behalf.

5.9 This consent is granted to establish and operate DG Set as a standby arrangement only and not as a captive power generation unit.

6.0 Applicant shall also comply with the general conditions given in annexure I.

  
Member Secretary  
Pollution Control Committee  
Daman, Diu and Dadra & Nagar Haveli  
Daman

Copy to:-

1. SWIFT, Silvassa.

2. Guard file.