भारत सरकार / Government of India

सरकारी राजपत्र
OFFICIAL GAZETTE

संघ प्रदेश दादरा एवं नगर हवेली तथा दमण एवं दीव प्रशासन
U.T. ADMINISTRATION OF DADRA AND NAGAR HAVELI AND DAMAN AND DIU

असाधारण
EXTRAORDINARY

प्राधिकरण द्वारा प्रकाशित / PUBLISHED BY AUTHORITY

Daman 05th November, 2026 14 Kartika, 1948 (Saka) No. : 83

U.T. Administration of Dadra & Nagar Haveli and Daman & Diu
Office of the Secretary (Power),
Vidyut Bhavan, Kachigam, Daman.

No. ED/DNHDD/2026-27/72 **Dt : 24/09/2026**

NOTIFICATION

In pursuance of Regulation 136(1) of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2023, read with the letter dated 24.04.2026 issued by the Central Electricity Authority, Ministry of Power, **the Hon'ble Administrator, Union Territory of Dadra and Nagar Haveli and Daman and Diu,** is pleased to permit a deviation from the provisions of Regulation 33 of the said Regulations with regard to the requirement of submission of test reports for low-risk category consumers having connected load up to 20 kW, by accepting self-attested test reports/self-certification in lieu of the prescribed test reports.

This notification is issued with the approval of the Hon'ble Administrator, Union Territory of Dadra and Nagar Haveli and Daman and Diu.

Sd/–
Secretary (Power)
U.T. of DNH & DD

***