

	 <b>सांगली जिल्हा परिषद, सांगली</b> <b>ग्रामीण पाणी पुरवठा विभाग</b> <b>सांगली मिरज रोड, सांगली</b>	
फोन. नं. ०२३३-२३७६६५०	ई-मेल- cebnsangli@gmail.com	दिनांक :- 19 / 12/2025

प्रति,

मा.उपमुख्य कार्यकारी अधिकारी


सामान्य प्रशासन विभाग

जिल्हा परिषद, सांगली.

विषय: जिल्हा परिषद वेबसाईट वरती टेंडर जाहीरात प्रसिद्ध करणेबाबत.

वरील विषयास अनुसरून जिल्हा परिषद सांगलीकडील 12,25,50, व 1000 लिटर प्रति तास क्षमतेचे वॉटर पुरिफायर बसवणे साहित्याचे अंदाजपत्रके दर निश्चित करण्याकरिता दरपत्रके 2 लिफाफा पद्धतीने मागविण्यात येत आहे. सांगली जिल्हा परिषद येथील कामासाठी जाहीर निविदा मागणीबाबत. याकरीता निविदा विहित केलेले नियम आणि कार्यपद्धतीनुसार येळदरी प्राथमिक आरोग्य केंद्र या कामास मान्यता घेणेत आली आहे व कामासाठी जाहीर निविदा मागवण्यात आलेले आहेत तरी जिल्हा परिषद वेबसाईट वरती जाहीर निविदाची प्रसिद्धी देण्यात यावी.

सोबत: जाहीर निविदा पत्र.

  
**कार्यकारी अभियंता**  
**ग्रामीण पाणीपुरवठा विभाग**  
**जिल्हा परिषद, सांगली.**

## जाहीर सूचना

उपभोक्तव्यांता (यांत्रिकी), देखभाल व दुरुस्ती कक्षा, जिसका परीक्षण सांगली.

निविदा सुचना क्रमांक- जि.प.यां.उद्धि/तांशा/५०८/१०१५ दिनांक- १५/११/१०१५

१२,२५,५० व १००० ली/प्रति तास क्षमतेचे Water Purifier चसविजे साहित्याचे अंदाजपत्रकीय दर निश्चीत करण्याकरीता दरपत्रके २ लिफ्टाका पद्धतीने मार्गविण्यात येत आहे.

दर पत्रके सादर करण्याचा दिनांक - १५/११/१०१५

दर पत्रके अरणेचा शेवटचा दिनांक - १२/११/१०१५

दर पत्रके उपडणेचा दिनांक - १५/११/१०१५

Sr.No	Item Name	Specification	Rate
1	2	3	4

## 100 LPH Water Purifier

1	Output Water Conforming standard	As per IS 10500 or better	
2	Type of water purification technology	RO+UV	
3	Operation mode	Semi Automatic with External Auto Cut off	
4	Availability of Water level Control switch (Floaty)	Yes	
5	Availability of sediment and activated carbon filter	Yes	
6	Ultraviolet (UV) LAMP	Yes	
7	Conformity to Standard for Ultraviolet system	IS 14724 (latest) for water purification system with Ultraviolet disinfection	
8	Stages of purification	Minimum 5	
9	No of RO Membranes provided	3	
10	RO Membrane rating	300 GPD	
11	No of Particulate filter provided	2	
12	Particulate Filter size	20 inch	
13	Particulate Filter Porosity	5 micron	
14	Availability of Activated Carbon filter	Yes	
15	No of Activated Carbon filter provided	1	
16	Activated Carbon filter Size	20 Inch	
17	Minimum inlet pressure	0.3 KG/CM2	
18	Maximum inlet pressure	3.5 KG/CM2	
19	Maximum Inlet water temperature	40 Degree Celsius	
20	Booster Pump	Yes	
21	Filteration water capacity in liter/ hour	100	
22	TDS removal percentage from RO Membrane	upto 95%	
23	TDS Adjuster	Yes	
24	Body of filter	ABS Food Grade/MS Powder Coated	
25	Membrane Housing	Yes	
26	Number of candles	2	
27	Installation Type	Wall Mounted/Tabletop	
28	Power supply	SINGLE PHASE ( 230 ± 10 % VOLT, %0 Hz)	

29	Installation and Commissioning inclusive in the scope of Supply	Yes	
30	Inlet Pipe & Fitting from raw water sources to water purification system	Suitable pipe and fitting to be provided by seller up to 20 feet	
31	Raw Water storage Tank	to be arranged by Buyer	
32	Pure Water storage Tank	to be arranged by Buyer	
33	Pipe & Fitting from Out let to purified water tank	to be arranged by Seller (upto 20 feet)	
34	Pipe and pipe fitting material	UPVC	
35	Electrical fitting and plug points	to be arranged by Buyer/Consignee	
36	ISI marked Electronic and electrical parts provided	Yes	
37	Open installation of Water pipe fitting and waste water pipe line fitting provided	Yes	
38	Warranty in years Including electronic ,electric parts, replacement of filters	2	
<b>50 LPH Water Purifier</b>			
1	Output Water Conforming standard	As per IS 10500 or better	
2	Type of water purification technology	RO+UV	
3	Operation mode	Semi Automatic with External Auto Cut off	
4	Availability of Water level Control switch (Floaty)	Yes	
5	Availability of sediment and activated carbon filter	Yes	
6	Ultraviolet (UV) LAMP	Yes	
7	Conformity to Standard for Ultraviolet system	IS 14724 (latest) for water purification system with Ultraviolet disinfection	
8	Stages of purification	Minimum 5	
9	No of RO Membranes provided	3 Or More	
10	RO Membrane rating	120/300 GPD	
11	No of Particulate filter provided	2	
12	Particulate Filter size	20 Inch	
13	Particulate Filter Porosity	5 micron	
14	Availability of Activated Carbon filter	Yes	
15	No of Activated Carbon filter provided	1	
16	Activated Carbon filter Size	20 Inch	
17	Minimum inlet pressure	0.3 KG/CM2	
18	Maximum Inlet pressure	3.5 KG/CM2	
19	Maximum inlet water temperature	40 Degree Celsius	
20	Booster Pump	Yes	

21	Filteration water capacity in liter/ hour	50
22	TDS removal percentage from RO Membrane	upto 95%
23	TDS Adjuster	Yes
24	Body of filter	ABS Food Grade/MS Powder Coated
25	Membrane Housing	Yes
26	Number of candles	2
27	Installation Type	Wall Mounted/Tabletop
28	Power supply	SINGLE PHASE ( 230 ± 10 % VOLT,%0 Hz)
29	Installation and Commissioning Inclusive in the scope of Supply	Yes
30	Inlet Pipe & Fitting from raw water source to water purification system	Suitable pipe and fitting to be provided by seller up to 20 feet
31	Raw Water storage Tank	to be aranged by Buyer
32	Pure Water storage Tank	to be aranged by Buyer
33	Pipe & Fitting from Out let to purified water tank	to be aranged by Seller (upto 20 feet)
34	Pipe and pipe fitting material	UPVC
35	Electrical fitting and plug points	to be aranged by Buyer/Consignee
36	ISI marked Electronic and electrical parts provided	Yes
37	Open installation of Water pipe fitting and waste water pipe line fitting provided	Yes
38	Warranty in years including electronic ,electric parts, replacement of filters	2
25 LPH Water Purifier		
1	Output Water Conforming standard	As per IS 10500 or better
2	Type of water purification technology	RO+UV
3	Operation mode	Semi Automatic with External Auto Cut off
4	Availability of Water level Control switch (Floaty)	Yes
5	Availability of sediment and activated carbon filter	Yes
6	Ultraviolet (UV) LAMP	Yes
7	Conformity to Standard for Ultraviolet system	IS 14724 (latest) for water purification system with Ultraviolet disinfection
8	Stages of purification	Minimum 5
9	No of RO Membranes provided	2
10	RO Membrane rating	80 GPD 2 No
11	No of Particulate filter provided	1

(4)


12	Particulate Filter size	10 inch	
13	Particulate Filter Porosity	5 micron	
14	Availability of Activated Carbon filter	Yes	
15	No of Activated Carbon filter provided	1	
16	Activated Carbon filter Size	20 inch	
17	Minimum Inlet pressure	0.3 KG/CM2	
18	Maximum Inlet pressure	3.5 KG/CM2	
19	Maximum Inlet water temperature	40 Degree Celsius	
20	Booster Pump	Yes	
21	Filteration water capacity in liter/ hour	25	
22	TDS removal percentage from RO Membrane	upto 95%	
23	TDS Adjuster	Yes	
24	Body of filter	ABS Food Grade/MS Powder Coated	
25	Membrane Housing	Yes	
26	Number of candles	2	
27	Installation Type	Wall Mounted/Tabletop	
28	Power supply	SINGLE PHASE ( 230 ± 10 % VOLT,%0 Hz)	
29	Installation and Commissioning Inclusive in the scope of Supply	Yes	
30	Inlet Pipe & Fitting from raw water source to water purification system	Suitable pipe and fitting to be provided by seller up to 20 feet	
31	Raw Water storage Tank	to be aranged by Buyer	
32	Pure Water storage Tank	to be aranged by Buyer	
33	Pipe & Fitting from Out let to purified water tank	to be aranged by Seller (upto 20 feet)	
34	Pipe and pipe fitting material	UPVC	
35	Electrical fitting and plug points	to be aranged by Buyer/Consignee	
36	ISI marked Electronic and electrical parts provided	Yes	
37	Open Installation of Water pipe fitting and waste water pipe line fitting provided	Yes	
38	Warranty in years including electronic ,electric parts, replacement of filters	2	

#### 12 LPH Water Purifier

1	Output Water Conforming standard	As per IS 10500 or better	
2	Type of water purification technology	RO+UV	
3	Operation mode	Semi Automatic with External Auto Cut off	
4	Availability of Water level Control switch (Floaty)	Yes	

5	Availability of sediment and activated carbon filter	Yes	
6	Ultraviolet (UV) LAMP	Yes	
7	Conformity to Standard for Ultraviolet system	IS 14724 (latest) for water purification system with Ultraviolet disinfection	
8	Stages of purification	Minimum 5	
9	No of RO Membranes provided	1 Or More	
10	RO Membrane rating	80 GPD	
11	No of Particulate filter provided	1	
12	Particulate Filter size	10 Inch	
13	Particulate Filter Porosity	5 micron	
14	Availability of Activated Carbon filter	Yes	
15	No of Activated Carbon filter provided	1	
16	Activated Carbon filter Size	12 Inch	
17	Minimum inlet pressure	0.3 KG/CM2	
18	Maximum inlet pressure	3 KG/CM2	
19	Maximum Inlet water temperature	40 Degree Celsius	
20	Booster Pump	Yes	
21	Filtration water capacity in liter/ hour	12	
22	TDS removal percentage from RO Membrane	upto 95%	
23	TDS Adjuster	Yes	
24	Body of filter	ABS Food Grade/MS Powder Coated	
25	Membrane Housing	Yes	
26	Number of candles	2	
27	Installation Type	Wall Mounted/Tabletop	
28	Power supply	SINGLE PHASE ( 230 ± 10 % VOLT,%0 Hz)	
29	Installation and Commissioning inclusive in the scope of Supply	Yes	
30	Inlet Pipe & Fitting from raw water source to water purification system	Suitable pipe and fitting to be provided by seller up to 20 feet	
31	Raw Water storage Tank	to be arranged by Buyer	
32	Pure Water storage Tank	12 Lit	
33	Pipe & Fitting from Out let to purified water tank	to be arranged by Seller (upto 20 feet)	
34	Pipe and pipe fitting material	UPVC	
35	Electrical fitting and plug points	to be arranged by Buyer/Consignee	
36	ISI marked Electronic and electrical parts provided	Yes	
37	Open installation of Water pipe fitting and waste water pipe line fitting provided	Yes	
38	Warranty in years including electronic, electric parts, replacement of filters	2	
:: Above Rates Should Include Supply & Installation With Necessary Accessories			

आर्थिक लिफ्टाफ्टा (आवश्यक कागदपत्रे)		
१. Water Purifier मरीनचे उत्पादक किंवा अधिकृत पुरवठादार असलेलाबाबतचे कागदपत्रे.		
२. शासकीय विभागाकडे Water Purifier मरीनचे काम केलेलाबताचा अनुभव असलेला दर्खला.		
३. फर्म नॉदणी प्रमाणपत्र.		
४. GST प्रमाणपत्र.		
५. पैन कार्ड.		
आर्थिक लिफ्टाफ्टा		
६. कामाचे नांव स्पेसिफिकेशन या दर नमुद करावेत.		

  
 कार्यकारी अधिकृता  
 ग्रामीण पाणी पुरवठा विभाग  
 जिल्हा परिषद सांगली