



ऊर्जा दक्षता ब्यूरो
(भारत सरकार, विद्युत मंत्रालय)
BUREAU OF ENERGY EFFICIENCY
(Government of India, Ministry of Power)




No.: BEE/Star-Rating/Certificates/Office/22-23/05

It is certified that Uttarakhand Electricity Regulatory Commission Building, Dehradun located in Composite climatic zone has been awarded a BEE 5-Star Label with the details below:

Name and address of the building	:	Uttarakhand Electricity Regulatory Commission Building, Dehradun
Connected load	:	75.00 KW/89 KVA
Climatic zone	:	Composite
Building Type	:	Day-time use Office Building
Percentage Air Conditioning	:	100%
Built up area	:	1720 sq. meter
Annual Energy Consumption	:	85,560 kWh/year
Energy Performance Index (EPI)	:	49.74 (kWh/sq.m/yr)
BEE Star Label Awarded	:	5 Star (★★★★★)

The label would be valid for a period of 3 years from the date of issue.

Date: 07th February 2023


(Saurabh Diddi)

Director

स्वहित एवं राष्ट्रहित में ऊर्जा बचाएँ Save Energy for Benefit of self and Nation

चौथा तल, सेवा भवन, आर.के. पुरम, नई दिल्ली-110 066, वेबसाइट/Website : www.beeindia.gov.in
4th Floor, Sewa Bhawan, R.K. Puram, New Delhi-110 066, दूरभाष/Tel : 91 (11) 26766700, फैक्स/Fax : 91 (11) 20867402