

Before
UTTARAKHAND ELECTRICITY REGULATORY COMMISSION
Pet. No. 07 of 2024

In the Matter of:

Application seeking removal of difficulty/clarification in the UERC (The Electricity Supply Code, Release of New Connections and Related Matters) Regulations, 2020

And

In the Matter of:

Uttarakhand Power Corporation Ltd.,
Victoria Cross Vijeta Gabar Singh Urja Bhawan,
Kanwali Road, Dehradun

...Petitioner

And

- (1) M/s Radiant Bar Pvt. Ltd.
Plot No. A-1/2, UPSIDC Industrial Area,
Village-Landhaura, Roorkee, Distt.-Haridwar
 &
(2) Power Transmission Corporation of Uttarakhand Ltd. (PTCUL),
‘Vidyut Bhawan’, Near ISBT,
Majra, Dehradun

...Respondents

Coram

Shri Anurag Sharma Member (Law)

Date of Hearing: August 28, 2024

Date of Order: August 28, 2024

ORDER

Parties were present, Petitioner represented by its counsel, Respondent no. 1 by its representative Sh. Musarrat Ali and Respondent no. 2 by Chief Engineer (O&M- Garhwal), PTCUL.

The Counsel for the Petitioner made submission on the Petition and clarified that they have filed a Petition basically for seeking permission from the Commission, and requested that the relief as mentioned at Para 9 (iii) of its Petition may kindly be considered accordingly and since Respondent no. 2 in its reply dated 23.07.2024 has given no objection for release of additional 3.5 MVA load at 33 kV, the Petitioner therefore, may kindly be allowed.

Representative of PTCUL also made submission and informed that presently in current months due to load being less on 132 kV S/s Mangalore and also considering that by March, 2025 the said Substation would be upgraded from 2x40 MVA to 40+80 MVA, therefore, it is possible to release the additional load as sought in the Petition and PTCUL has no objection in this regard.

M/s Radiant Bar did not file any written reply/submission, however, the representative of M/s Radiant Bar pointed out the difficulty faced by them due to delay in load enhancement and further submitted that considering the possibility of load enhancement in near future, requested to permit them additional load of 3.5 MVA over existing 33 kV line. He further submitted documents in support of deposition of system study fees to PTCUL which were taken on record.

Heard the parties.

The matter is reserved for the judgement.

(Anurag Sharma)
Member (Law)