

BEFORE
UTTARAKHAND ELECTRICITY REGULATORY COMMISSION

In the matter of:

Penalties imposed by UPCL on industries for excess usage of power during the restricted period effective from 31.12.2007 to 15.02.2008.

Coram

V.J. Talwar	Chairman
V.K. Khanna	Member
Anand Kumar	Member

Date of Order: July 24, 2008

ORDER

This Order relates to the complaints filed by industrial consumers alleging irregular and arbitrary imposition of penalty by Uttarakhand Power Corporation Limited (UPCL), the Distribution & Retail Supply Licensee in the State, for excess usage of electricity during the period of restriction commencing from 31.12.2007 till 15.02.2008, without giving any detail or basis for imposing this penalty.

1. Background

- 1.1 The Commission on the proposal of UPCL for load shedding due to acute shortage of power, through its Order dated 26.12.2008, had approved the area-wise scheduled load shedding programme for UPCL to be effective from 28.12.2007 to 15.1.2008 for different categories of consumers, which *inter-alia* included the industrial consumers. For industrial consumers connected on industrial feeders, the following specific schedule was given:

S.No.	Areas of Load Shedding	Time Period
6.	All 132, 33 kV and 11 kV Industrial feeders emanating from Primary & Secondary Sub-stations including SIDCUL Hardwar, SIDCUL Pantnagar except those industrial consumers, having continuous process and have opted for continuous supply during restricted hours at a higher tariff under Section 6 of RTS-7 and also those industrial consumers, having continuous process who may give this option up to 31.12.07 . All other industrial consumers shall be allowed to use power upto 15% of their contracted load to meet their lighting requirement. Any violation by such consumers in this regard shall attract penalty of Rs. 50 per KVA of contracted load of each day of default alongwith 20% higher tariff for the month of default as per Section 6 (iii) of RTS 7 of tariff order for 2006-07.	05.30 P.M. to 10.00 P.M.

- 1.2 Extracts of this order, which are relevant in the present case, are reproduced below:

*“e) In case UPCL while preparing day-ahead schedule notes that there is a possibility of surplus in power during next day, **relief shall be given to consumers** of such period having longest period of power cut.*

f) UPCL shall implement provisions given in Section 6 (restrictions in usage) of rate schedule RTS 7 of tariff order for 2006-07 for applying higher tariff on those industrial consumers, having continuous process and opts for continuous supply during restricted period. Relevant portion of Section 6 of RTS 7 is reproduced below:-

“Restriction in usage”

In case, imposition of restriction towards the usage of electricity by the industry during certain hours in the day is effected by the Commission at any point of time, then the following rates and charges shall start to be applicable.

i) For consumers opting for supply during restricted hours (Continuous)- 20% increase in the Energy charge as given in Rate of charge.....

ii) For consumers not opting for supply during restricted hours (Non continuous) – Energy charge, Demand charge and other charges as per rate of charge given above.

*iii) Peak Hour Violation Penalty shall get attracted. Consumers who do not opt for supply during Peak hours/Restricted hours (**Non Continuous supply**) shall not be allowed to use power in excess of 15% of their contracted demand. Any violation detected shall attract a penalty of Rs. 50 per KVA per day of the contracted demand, for the number of days of such violation. For the month of default, the consumer shall be billed at the rates specified at (i) above (for consumers opting for supply during restricted hours (Continuous)).*

*g) Increased tariff shall be charged from consumers who have opted for continuous supply **from the date of their option** till such times these rates are further modified by the Commission.*

....

j) Scheduled load shedding in areas which remained without power during the day of restriction due to breakdown in EHV system, shall be reduced suitably."

- 1.3 Salient features of this order were published by local News dailies, one such press clipping is enclosed as **Annexure 1**. The load shedding could be carried out by UPCL from 28.12.2007 as per the approved schedule, but UPCL actually imposed the restrictions from 31.12.2008, which it was authorized to do by virtue of para e) of the order quoted above. UPCL also gave a Public Notice in Newspapers on 27.12.2007 and 1.1.2008 (**Annexure 2(a) & 2(b)**) for making the industrial consumers aware about expected load shedding from 31.12.2007 and sought their option by 5 PM, 31.12.2007 for availing continuous supply.

- 1.4 Due to shutdown of ONGC's gas platform and further aggravation of power crisis, approval for additional load shedding as per revised schedule proposed by UPCL on 4.1.2008 was granted by Commission on 5.1.2008 and the load shedding hours were approved as 1600 hrs to 2230 hrs for industrial consumers, which was to be applicable till 15.1.2008. The Public Notice for the revised schedule was published by UPCL on 6.1.2008 (**Annexure 3(a)**) and the same was applicable from this date only. This was later extended upto 31.01.2008 (**Annexure 3(b)**).
- 1.5 On UPCL's request dated 31.01.2008, the Commission approved yet another revised load shedding programme on 1.2.2008 that was applicable from upto 15.2.2008. The Public Notice for this schedule was given by UPCL on 2.2.2008 (**Annexure 4**).
- 1.6 It may be noted that UPCL could give relief to consumers from the approved load shedding based on improved availability of power. Hence, the relief in restricted hours granted by UPCL shall not be counted towards imposition of penalty for excess usage during restricted hours. The scheduled restriction approved by the Commission and that actually implemented by UPCL is presented in **Annexure 5**.
- 1.7 Consequent to issue of bills for December 2007 and January 2008 by UPCL, which reflected payment of penalties on excess usage during restricted hours, the Commission started receiving a large number of complaints from individual industrial consumers and also collectively through Industries Association of Uttarakhand regarding penalty being imposed on them arbitrarily for excess usage of electricity during the restricted period without giving any detail or basis. In some cases, penalties were stated to have been calculated in the provisional bills, which were issued without MRI details.
- 1.8 The Commission, as a test check, analysed the bills of HT & LT industry consumers of Dehradun (Rural) division and HT Industry consumers of Kashipur divisions for January, 2008. The Commission discovered that not only the complaints regarding incorrect/unsubstantiated billing of penalty were prima

facie correct for large no. of consumers but also there were serious violation in application of tariffs approved by the Commission. Some of these are listed below:-

- 1) Where consumers have not opted for continuous supply during restricted period, penalty for exceeding the allowed demand (KVA) limit has not been applied in certain cases.
- 2) There have been evading instances of peak hour violation penalty by allowing continuous supply to industries from back date and at field levels without giving any supporting document for delegation of authority for doing so.
- 3) For certain consumers penalty has been applied without proper analysis of load survey.
- 4) 20% higher charges for continuous supply have either not been applied on certain consumers or have been applied for incorrect period.
- 5) Rate of Energy charges being applied is different from the approved tariff for continuous supply of power for certain consumers.
- 6) Excess demand charges for exceeding the contracted demand have been wrongly applied in certain cases.

1.9 Considering the gravity of complaints, the Commission decided to carry out detailed examination to obviate the difficulties faced by consumers in clearing payment of impugned bills along with the penalty. At the same time, the Commission directed UPCL vide its letter No. 1131/UERC/08 dated 22.02.2008 that the payments of such bills issued for the month of December 2007, January 2008 and all future bills be accepted without penalty. It was ordered that no disconnection should be done on this account and payment of penalty on excess charges shall remain suspended till a final view is taken by the Commission in the matter.

1.10 UPCL neither filed any reply nor was taking any interest in resolving the issue. Finding this lackadaisical attitude of the licensee company viz. UPCL, the

Commission took the initiative to issue a public notice, which was published on 28.03.2008 in Amar Ujala (**Annexure 6**), wherein all aggrieved consumers were invited to make a representation before the Commission along with the copy of the bill and receipt of payment made against such bill and any other relevant information to the Commission by 15.04.2008.

1.11 In response to this public notice, 92 representations from the aggrieved industrial consumers (List attached as **Annexure 7**) were received in the Commission, most of them being sent much after the last date i.e. 15.4.2008. The Commission, however, took all these representations on record and sent them to UPCL in batches on 17.4.2008, 25.4.2008, 14.5.2008 and 6.6.2008 along with a direction to submit the following information:

- 1) Copy of bills from November 2007 to February 2007.
- 2) Meter No., make, multiplying factor in case their details are not provided on the bills
- 3) Load Survey Report
- 4) Basis and Calculation for penalty.

1.12 On 29.5.2008, fresh complaints were received from President, Industries Association of Uttarakhand and SIDCUL Industries Association, Haridwar informing that despite clear cut orders deferring the payment of penalty for excess usage during restricted period, UPCL was still raising demand notice of peak hour penalty alongwith surcharge. The Commission took cognizance of the matter and through its letter dated 30.5.2008 directed UPCL not to levy surcharge on the penalty amount and also to make appropriate corrections in bills already raised with such surcharge.

1.13 On 8.7.2008, UPCL submitted to the Commission the division-wise revised summary and calculation of penalty, the summary of the original and revised calculation is enclosed as **Annexure 8**. A perusal of this Annexure establishes that not only consumer complaints of arbitrary imposition of penalties were correct, in

some cases the consumers were loaded with huge penalty bills when nothing was payable by them. The Commission has carried out analysis of data submitted by UPCL for validating the claims of consumers, which has been dealt later in the Order.

2. Views of Advisory Committee

- 2.1 In the meeting of Advisory Committee held on 15.7.2008, this issue of imposition of penalty and excess usage charges during restricted hours of supply and consumers' complaints thereon was taken up for discussion. MD, UPCL and all their other full time Directors were also present in this meeting. The views of the Committee are as follows:
- 2.2 Even though adequate press public notices were issued, informing the consumers about the restricted hours of supply and consequent penalty and/or excess charges for violation of restricted hours use, the Committee felt that industries may be informed about such restrictions in future through their associations also.
- 2.3 While the penalty provision may be continued to dissuade consumers resorting to violation of use during restricted hours, the Committee felt that quantum of penalty should, however, be in proportion to the degree of violation, whether the same is intentional and with immunity or otherwise.
- 2.4 Industry representatives in the Committee pointed out that penalty provision for excess usage has been there in the tariff since UPSEB days. However, though the same came into force during load shedding but never implemented because either meters were not able to record violations or MRI dump was not taken for implementing it. Since this was the first time these provisions have been enforced, the industry could not visualize the consequences of violations and should, therefore, be exempted from imposition of penalties for this year.

3. Response of Industries

3.1 To elicit the responses of aggrieved industrial consumers in the Commission held a public hearing on 16.07.2008 at IMA Hall, Chakrata Road, Dehradun. The representatives of the industries, aggrieved by such penalty, personally appeared before the Commission to present their case during the hearing. List of consumers who participated in this hearing is given at **Annexure 9**. Since the responses submitted by the individual industries, both in their written/oral submissions, were common in nature they have been clubbed issue-wise and summarised below.

3.2 Request for taking a sympathetic view

Since the violations in number of cases have been inadvertent and/or marginal, the penalty in such cases may be waived off.

3.3 Lack of communication

Industries have stated that they were not aware of UPCL's advertisement informing imposition of peak hour restrictions in the State and procedure to be followed to apply for continuous supply. Since the advertisement published by UPCL was appearing in inner pages of the local newspapers, they went unnoticed. They have requested that in future these be published in front pages. They also requested that in future every industry should be informed in advance by UPCL about such orders through post or email.

3.4 Penalty provision in Tariff Order Excessive

All industrial consumers have unequivocally submitted that the existing provisions of Tariff Order are very excessive. While the industries admitted that there should be penal provisions for violation of demand during restricted hours, the penalty should be in proportion to the amount of violation. While rampant violators should not be spared, there is a strong case of relief to be granted to

others who have occasionally and marginally violated the 15% limit, where penalty should be graded based on gravity of violations.

3.5 Relief for power cut during day time

Industries have pointed out that as per Commission's order, the hours of scheduled power cut approved by the Commission was ceiling and appropriate relief was required in number of hours during evening schedule for power cut during day time.

3.6 Delay in granting approval for continuous supply option

Industries submitted that UPCL took too much time to approve the option for continuous supply submitted by them, which resulted in unwarranted imposition of penalty for the delayed period. It was contended that as per Commission's order continuous status should be available to the consumer from the day he opts for it.

3.7 Dispute regarding number of days and timing of violation

Industrial consumers raised doubts about the authenticity of bills based on number of days of violations, for which no detail whatsoever has been provided by UPCL, nor has UPCL provided them with the load survey downloaded from MRI. Further, the violations have occurred due to ambiguity in applicable hours of restrictions, which kept on changing very frequently.

3.8 Not to apply the peak hour violation order on town/rural and mixed load feeders.

Industries which are on mixed load feeders and faced power cut during day hours should not be subjected to penalties for the evening peak hour restriction period.

3.9 Drifting of Real Time Clock (RTC) in ToD meters

Some of the Industries have pointed out that the RTC of their meters has time differential with the actual time due to drifting over time as they have never been synchronized after installation. This might have resulted into inadvertent usage at

marginal slots of restriction period. The Commission must exclude such violations.

3.10 No Continuous Supply Surcharge after 1st March 2008.

Some industries pointed out that Commission in its order dated 26th December 2007 had stated that increased tariff shall be charged from consumers who have opted for continuous supply from the date of their option till such times these rates are further modified by the Commission. Commission has since issued tariff order for effective from 1st March 2008, accordingly Continuous Supply Surcharge is not applicable after 1st March 2008 for industries who have opted out.

4. Commission's Analysis

4.1 The Commission notes that all the rules regarding approval of restricted time slots & publication of the information was followed by UPCL as per approvals granted by it from time to time. The contention of the consumers that they were ignorant of the restriction cannot be accepted. The Commission, however, accepted the suggestion of giving such notices on front pages in future. The suggestion of sending individual intimations by post/e-mail appear impractical. UPCL may, however, at its option consider communicating individual consumers of such announcements through e-mail wherever practicable. The Commission is also unable to accept the contention of industrial consumers that they were not aware of the consequences of penalty provisions when they existed from UPSEB days. The Commission did not approve direct cut of the feeders on request of industries for usage upto 15%, for which they promised to discipline themselves. However, the allowance of the Commission has been misused by certain consumers.

4.2 In line with Para 6 of Commission's Order dated 12.7.2006, the date of application for continuous supply by the consumer shall be taken as the date of submitting the option by consumer to UPCL and not the date of actual approval by UPCL. It is immaterial where the consumer had submitted its Option, whether to field staff or at corporate level. The consumers would, however, have to furnish the proof of

having given the option to UPCL, wherever required. The Commission is of the view that implementing this provision in literal sense shall not only lead to avoidable complexities in calculating the bill amount but also require discretion to be applied by UPCL. In order to simplify the matter, the Commission has decided that 20% surcharge shall be paid by the consumer from the beginning of the month in which option for continuous supply is given and no penalty shall be levied on such consumer for that month and thereafter.

- 4.3 Those industries whose units are connected to mixed/rural/town feeders, which were subjected to normal roastering of the area, no penalty shall be imposed on them.
- 4.4 Similarly, as per Commission's Order dated 26.12.2007, corresponding relief shall be granted to industries in the evening peak hours, where power has been cut during day time.
- 4.5 Considering widespread complaints of ambiguity in the hours of restriction due to frequent changes in restriction schedules, which could not be continuously monitored by industries, the Commission has also decided to consider the hours of restriction during this period as 1730 hrs to 2200 hrs for the period 1.1.2008 to 5.1.2008, 1700 hrs to 2200 hrs for each day from 6.1.2008 to 15.2.2008, which consistently remained to be applicable throughout this period right from beginning. However, this shall not be applicable for 1.2.2008, when no restriction was implemented.
- 4.6 As far as clock-drifting is concerned, the Commission is of the view that minor drifting of clock by 5 to 10 minutes is normal and hence till the meter clocks are synchronised, benefit of doubt can be granted to industrial consumers for the marginal slot (initial or last) of the restriction period for fast or slow meter clock. UPCL/consumers, however, are at liberty to check the meters of consumers where clock drifting is expected to be more than one time slot i.e. 30 minutes.

- 4.7 Regarding Applicability of Continuous Supply Surcharge on industries after 1st March 2008, the Commission would like to clarify that Commission in its order dated 26th December 2007 have provided that *“Increased tariff shall be charged from consumers who have opted for continuous supply from the date of their option till such times these rates are further modified by the Commission.”* Continuous Supply Surcharge has not been modified in tariff order for FY 2008-09 and accordingly Continuous Supply Surcharge at same rate is still applicable.
- 4.8 The Commission has analysed the MRI data for 48 industrial consumers on sample basis, the summary of which is enclosed in the Chart given in **Annexure 10**. A perusal of this Chart shows that during this restriction period, the average number of slots of violation/day for about 50% industries is lying between 0 to 2 only. Similarly, most of the industries have tried to restrain their load much below their contracted load. This indicates that some industries have shown intent of complying with the restrictions within their constraints and, hence, would need to be treated differently from those who have violated the restrictions with impunity.
- 4.9 A penalty is generally a punishment and may refer to in the law as fine or sentence for breaking the law. The sole purpose of imposing the fine is to deter a person from breaking the law and not to generate windfall revenue to the State. It is well settled that penal provisions have to be strictly construed and before fixing the penalty adequate opportunity has to be given to the person on whom penalty is imposed. Having done so, an opinion has to form whether penalty is to be levied or not. Even for determining the quantum of penalty to be levied, an objective consideration must also be brought. After proper opportunity is accorded and if the explanation tendered by the assessee is ignored before the order is made, it would definitely violate the principle of natural justice.
- 4.10 The Commission finds that flat rate of Rs 50/kVA of contracted load/day of load violation penalty takes into account only number of days of violation. It neither takes into account the period during which violation continued in each day nor

the quantum of violation beyond 15% limit. Thus, the present provision treats violation in one time slot as equivalent to violation during entire 10 time slots of restricted period in a day. Similarly, marginal violation of 1% excess load (i.e. 16% load) is not differentiated with 85% excess load (i.e. 100% load). In the worst case, marginal violation of 1% load in one time slot is treated equivalent to 85% load violation for entire 10 time slots of restriction in a particular day. The Commission also notes that in addition to load violation penalty as discussed above, 20% higher rate of energy charges for the month are also charged irrespective of number of days of violations. Accordingly, one day of small violation and 30 days of continuous and heavy violation entail same financial burden.

4.11 Considering the above provisions of the Tariff Order dated 12.7.2006 and with a view to obviate the difficulties of the consumers as put forth before the Commission in writing as also in person during hearing on 16.07.2008, the Commission has decided as follows:

- 1) 20% of energy charge as continuous supply surcharge shall apply from 1st day of month of option and no penalty for excess usage shall be levied for that month.
- 2) As the last date for submission of option for continuous supply was stipulated as 31.12.2007 in the load shedding schedule approved by the Commission in its Order dated 26.12.2007, the month of December 2007 shall not be taken into account for the purpose of levy of penalty and/or continuous supply surcharge.
- 3) For consumers who did not opt for continuous supply:
 - i) The hours of restriction shall be deemed to be from 1730 hrs to 2200 hrs for the period 1.1.2008 to 5.1.2008, 1700 hrs to 2200 hrs for each day from 6.1.2008 to 15.2.2008, except on 1.2.2008 when no restriction was applied.
 - ii) The benefit of clock drifting shall be available to the consumer for one time slot either in the beginning or at the end of restricted period. Thus, if number of days of violations during the first time slot are more than number of days of

violation of last time slot, then first time slot shall be ignored for calculation of penalty and vice versa.

iii) There shall graded penalty for violation of load during restricted hours of each day beyond 15% limit based on the following two factors:

(a) No. of time slots (30 minutes duration each) during which violation occurred

(b) Quantum of violation in excess of 15%

iv) The penalty shall be zero for load upto 15% and maximum for load equal to or more than 50%. It shall be also proportionate to number of slots of violation in a day.

Illustration: There are 10 time slots during restriction period. Dividing full penalty of Rs 50 in 10 equal parts, penalty for excess usage for each time slot works out to be Rs 5. Rate of penalty for each time slot shall be proportionate to percentage of usage varying from Rs 1.6 (for 16% usage) to Rs 5 (for usage equal to or more than 50%) per kVA of contracted load.

Industry	Contracted Load (KVA)	Usage (%)	No. of time slot where usage is more than 15%	Penalty as per provisions of tariff order (50 x Cont Load)	Penalty for each time slot. (No TS x Rate x Cont Load)	Total Penalty
A	100	16% 20% 60%	1 3 1	50x100=5000	1x1.6x100=160 3x2.0x100=600 1x5x100=500	1260
B	3000	25%	1	50x3000=150000	2.5x1x3000=7500	7500
C	1000	52%	10	50x1000=50000	5x10x1000=50000	50000

4) The continuous supply charge of 20% on energy charges shall be in proportion to the number of days of violation in the month.

Illustration: Energy Charges for month of January = Rs. 340000

No. of days of violation = 17

Continuous Supply Surcharge for 17 days = $0.2 \times 340000 \times 17 / 31 = \text{Rs. } 37290.32$

5) In case any consumer who had opted for continuous supply now feels that he is at loss (for opting continuous supply) after implementation of this order may opt out for continuous supply w.e.f. 1st January 2008. This change may be exercised within period of one month from date of issue of this order. UPCL

shall treat such consumers at par with other consumers who have not opted for continuous supply and prepare bills for penalty for such consumers. Such industry shall, however, not be allowed to re-opt continuous supply during current financial year.

- 6) UPCL shall recalculate the penalties/continuous supply surcharge of industrial consumers who have not opted for continuous supply for the months of January and February 2008 and give it to consumers along with its calculations and MRI load survey within a period of 3 months giving at least 15 clear days to consumer for making payment after delivery of bill. Original penalties as calculated by the field staff shall not be shown as arrears in the bills hereafter.
- 7) All bills for penalties shall be prepared at UPCL's centralized billing section at headquarters and no bill shall be prepared at field level.
- 8) For implementing the above decisions, UPCL shall use the template being annexed with this order in soft form for preparation of the bills of penalty/continuous supply surcharge. **UPCL shall only fill up consumption for each time slot and shall not disturb the formula fields of the template. In case, UPCL has any doubt, they may contact Commission for any clarification.**
- 9) The revenue on account of such penalties/continuous supply surcharge and the data on additional power purchase cost incurred for UI overdrawl during this period shall be distinctly reflected by UPCL in next ARR.

(Anand Kumar)
Member

(V.K. Khanna)
Member

(V.J. Talwar)
Chairman

राष्ट्रीय सहारा

देहरादून, बृहस्पतिवार, 27 दिसम्बर 2007

यानी पूर्ण सत्य

अंक-1 अंक- 68

कल से बिजली कटौती

सहारा न्यूज ब्यूरो
देहरादून, 26 दिसम्बर।

ऊर्जा प्रदेश में बिजली की भारी कमी है। इस कमी से निपटने के लिए ऊर्जा विभाग बिजली कटौती का सहाय लेने जा रहा है। अधोषित कटौती तो पिछले कुछ समय से जारी थी लेकिन अब इसके लिए बकायदा शेड्यूल जारी कर दिया है। निगम ने कटौती के विद्युत नियामक आयोग के समक्ष प्रस्ताव रखा था जिसे आयोग ने हरी झंडी दे दी है। कटौती की यह मार सैदामी इलाकों पर ज्यादा पड़ेगी और पर्वतीय क्षेत्र कटौती से मुक्त रहेंगे। आयोग के सचिव आनंद कुमार ने इसकी पुष्टि की है। कटौती का यह शेड्यूल 28 दिसम्बर से 15 जनवरी तक के लिए घोषित किया गया है। प्रदेश में बिजली की कितनी कमी है इसका अंदाजा इसी से लगाया जा सकता है कि कटौती शेड्यूल में उद्योगों को भी नहीं बख्सा गया है। उद्योगों पर कटौती 31 दिसम्बर की रात से लागू होगी।

औद्योगिक इलाकों में यह कटौती शाम 5.30 से रात 10 बजे तक की जाएगी। इस दौरान फीडर बंद हो नहीं होंगे लेकिन औद्योगिक इकाइयों को फुल स्वीकृत लोड के साथ 15 फीसद बिजली का ही उपयोग करने को इजाजत होगी। इसका अनुपालन न करने वालों पर भारी पैनाल्टी लगेगी। आवासीय क्षेत्रों के लिए सुबह 8 बजे शाम के पीक आवर्स को चुना गया है। इसके लिए समय सारिणी जारी की जाएगी और उस दौरान हर झल में बिजली की कटौती की जाएगी। ऊर्जा निगम के सूत्रों के अनुसार बिजली की भारी कमी से निपटने के लिए विभाग के पास इसके अलावा कोई चारा नहीं था। इससे पहले ही विभाग बिना घोषित कार्यक्रम के कटौती कर रहा था लोगों की शिकायत पर फीडर या लाइन में काम चलने जैसे बहाने बनाये जाते थे। इस तरह ज्यादा दिन तक काम नहीं चलने की स्थिति में विभाग बकायदा शेड्यूल जारी करने पर बाध्य हो गया। बताया जा रहा है कि कटौती के इस कार्यक्रम को और आगे भी बढ़ाया जा सकता है।

■ कमी से निपटने के लिए
कटौती का शेड्यूल जारी
■ पहाड़ों को रखा मुक्त,
उद्योग पर भी होगा असर

हरिद्वार, रुड़की में रहेगा अंधेरा

देहरादून, 26 दिसम्बर (एसएनबी)। बिजली कटौती का सबसे अधिक असर हरिद्वार व रुड़की में दिखेगा। जानकारी मिली है कि कटौती का जो शेड्यूल तैयार किया गया है उसमें इन दो शहरों के साथ ही कथमसिंहनगर में ज्यादा समय कटौती करने का निर्णय लिया गया है। सूत्रों का कहना है कि बिजली चोरी के सबसे अधिक मामले हरिद्वार और रुड़की में पकड़े जाने के कारण ऐसा किया गया है। ऐसे में इन क्षेत्रों के लिए पश्चिम में अधिक कटौती का यह फैसला लिया गया है।

Dainik Jagran, 27.12.2007

उत्तराखण्ड माता कारखानेयन विधिते

जन सूचना

सभी सम्मानित औद्योगिक उपभोक्ताओं को सूचित किया जाता है कि देश के उत्तरी क्षेत्र में मांग के सापेक्ष उत्पादन में अत्याधिक विद्युत की कमी के कारण उत्तराखण्ड राज्य में दिनांक 31.12.2007 की शाम से औद्योगिक इकाईयों की विद्युत कटौती की सम्भावना है। अतः यदि कोई औद्योगिक उपभोक्ता जिसको विद्युत, स्वतंत्र पोषक / औद्योगिक पोषक द्वारा प्राप्त होती है और विद्युत कटौती की अवधि में विद्युत आपूर्ति चाहते हैं तो वे दिनांक 31.12.2007, 5.00 बजे तक अपना आवेदन निदेशक (परिचालन) / अधिशासी निदेशक (वाणिज्य), ऊर्जा भवन, कांवली रोड, देहरादून को उपलब्ध करवा सकते हैं। ऐसे सभी औद्योगिक उपभोक्ताओं को टैरिफ के अनुसार सामान्य इनर्जी चार्ज पर 20 प्रतिशत अतिरिक्त धनराशि देनी होगी।

No : 1042/DGM(MQ)/A-2 Date : 26.12.07

(सह-निर्देशक, विद्युत आपूर्ति)

Danik Jagran-Amar Ujala, 01.01.2008



उत्तराखण्ड पावर कारपोरेशन लि.

ऊर्जा भवन, कावली रोड, देहरादून-248001

दूरभाष: 91 135 2768895 फैक्स: 91 135 2768867

पूर्व निर्धारित विद्युत कटौती की सूचना

उत्तराखण्ड पावर कारपोरेशन के सम्मानित औद्योगिक उपभोक्ताओं को फिर से सूचित किया जाता है कि वर्तमान में देश के सम्पूर्ण उत्तरी क्षेत्र में विद्युत उत्पादन के सापेक्ष मांग बहुत अधिक बढ़ गयी है। उत्तराखण्ड पर्वतीय राज्य होने के कारण शीतकाल में यहाँ भी विद्युत मांग बहुत बढ़ गयी है एवं इसके विपरीत नदियों में जल कम हो जाने के कारण राज्य का विद्युत उत्पादन कम हुआ है। अतः वर्तमान में राज्य में विद्युत की अत्यधिक कमी हो गयी है जिसके कारण समय-समय पर आकस्मिक विद्युत कटौती करनी पड़ रही है।

समय-समय पर विद्युत कटौती से औद्योगिक उपभोक्ताओं को असुविधा न हो इसको ध्यान में रखते हुये विभिन्न क्षेत्रों में, मूलनीय उत्तराखण्ड विद्युत नियामक आयोग से मिले अनुमोदन के आधार पर, विद्युत कटौती का समय निम्नवत निर्धारित किया गया है जो दिनांक 31.12.2007 की सायं से लागू होगा:-

औद्योगिक उपभोक्ता	विद्युत कटौती का समय
सभी प्राथमिक एवं द्वितीय प्रणाली उपस्थानों से पोषित 132 के.वी, 33 के.वी. एवं 11 के.वी. औद्योगिक पोषक-सिडकुल हरिद्वार एवं पंतनगर सहित। उच्च दरों (20 प्रतिशत अधिक) पर विद्युत आपूर्ति का विकल्प चुने हुये औद्योगिक उपभोक्ता प्रतिबन्धित अवधि में विद्युत कटौती से मुक्त रहेंगे। अविरल विधा के औद्योगिक उपभोक्ता 31.12.2007 तक उच्च दरों (20 प्रतिशत अधिक) पर विद्युत आपूर्ति का विकल्प चुन सकते हैं। अन्य औद्योगिक उपभोक्ता उनको कुल स्वीकृत विद्युत भार के 15 प्रतिशत तक प्रकाश एवं पंखों के लिये उपयोग कर सकते हैं। उपर्युक्त प्रतिबन्ध का उल्लंघन करने पर दर सूची आर.टी.एस.-7 के अनुभाग-6 (iii) के अनुसार प्रति के.वी. ए. रू. 50/- प्रतिदिन की दर से अर्थदंड देय होगा एवं प्रसन्नता माह में 20 प्रतिशत उच्च दर देय होगी।	सायं 5.30 बजे से रात्रि 10.00 बजे तक (विद्युत कटौती 31.12.2007 सायं से लागू होगी)

(माननीय नियामक आयोग द्वारा इन दरों में संशोधन होने तक, उपरोक्तानुसार विकल्प चुनने वाले औद्योगिक उपभोक्ताओं को अविरल विद्युत आपूर्ति की जायेगी एवं उन पर इनजी चार्ज 20 प्रतिशत अतिरिक्त दर लागू रहेगी।)

सम्मानित औद्योगिक उपभोक्ताओं से पुनः अनुरोध है कि वे विद्युत कटौती के समय धैर्य बनाये रखकर कारपोरेशन को विद्युत आपूर्ति व्यवस्था सुचारू किये जाने के कार्य में सहयोग प्रदान करने का कष्ट करें। विकल्प चुनने हेतु कृपया अधिशासी निर्देशक (वाणिज्य), ऊर्जा भवन, कावली रोड, देहरादून से सम्पर्क करें।

उत्तराखण्ड पावर कारपोरेशन लि.

"राष्ट्र हित में बिजली बचाये"

Dainik Jagran, 06.01.2008

संशोधित पूर्व निर्धारित विद्युत कटौती की सूचना

उत्तराखण्ड पावर कारपोरेशन के सम्मानित उपभोक्ताओं को पुनः सूचित किया जाता है वर्तमान में देश के सम्पूर्ण उत्तरी क्षेत्र में विद्युत उपलब्धता की स्थिति विकट हो गयी है। ओ0एन0जी0सी0 के एक गैस प्लेटफार्म में उत्पादन बन्द हो जाने से उत्तराखण्ड को बैंकिंग द्वारा सी0एस0ई0एस0 से मिलने वाली 100 मेगावाट एवं रिलाइन्स इनर्जी लि0 से 50 मेगावाट विद्युत उपलब्धता में भी बहुत अधिक कमी हो गयी है। पर्वतीय राज्य होने के कारण शीतकाल में यहां विद्युत मांग बहुत बढ गयी है एवं इसके विपरीत नदियों में जल कम हो जाने के कारण राज्य का विद्युत उत्पादन कम हुआ है। अतः वर्तमान में राज्य में विद्युत की अत्यधिक कमी हो गयी है जिसके कारण पूर्व निर्धारित विद्युत कटौती के अतिरिक्त समय-समय पर, आकस्मिक विद्युत कटौती भी करनी पड रही है जो कि उत्तराखण्ड पावर कारपोरेशन के नियंत्रण में नहीं है।

समय-समय पर विद्युत कटौती से उपभोक्ताओं को असुविधा न हो इसको ध्यान में रखते हुये विभिन्न क्षेत्रों में संशोधित विद्युत कटौती का समय दिनांक 15.01.08 तक निम्नवत निर्धारित किया गया है जो तत्काल प्रभाव से लागू होगा :-

क्षेत्र का नाम	विद्युत कटौती का समय
शहर/कस्बे लक्सर, लंदौरा, मंगलौर, रुडकी, जसपुर, रुद्रपुर, काशीपुर, खटीमा, गदरपुर, बाजपुर, किच्छा, सितारगंज, रामनगर, बहादुराबाद।	प्रातः 6 बजे से पूर्वाह्न 10 बजे तक
ग्रामीण क्षेत्र-गढ़वाल मंडल ज्वालापुर, सुल्तानपुर-भट्टीपुर, रुडकी, मंगलौर, लंदौरा, भगवानपुर, लक्सर, खानपुर और नारसन।	प्रातः 7 बजे से मध्याह्न 12 बजे तक
ग्रामीण क्षेत्र-कुमायूँ मंडल खटीमा, किच्छा, जसपुर, बाजपुर, केलाखेडा, पिपलिया, एनडी नगर, गढी नेगी, और सरबरखेडा।	प्रातः 7 बजे से मध्याह्न 12 बजे तक
हल्द्वानी शहर, ऋषिकेश शहर, 33 के0वी0 डोईवाला पोषक से पोषित क्षेत्र, ढकरानी, विकासनगर एवं सेलाकुई का सम्पूर्ण क्षेत्र	प्रातः 10 बजे से अपराह्न 02 बजे तक
देहरादून, मसूरी एवं नैनीताल शहर (संवेदनशील क्षेत्रों को छोड कर)	मध्याह्न 12 बजे से अपराह्न 3 बजे तक
हरिद्वार एवं ज्वालापुर शहर (हरि की पैडी को छोड कर)।	अपराह्न 2 बजे से सायं 05 बजे तक
समस्त पर्वतीय क्षेत्र (देहरादून, मसूरी एवं नैनीताल शहरों को छोड कर)	अपराह्न 2 बजे से सायं 05 बजे तक
ग्रामीण क्षेत्र-गढ़वाल मंडल ज्वालापुर, सुल्तानपुर-भट्टीपुर, रुडकी, मंगलौर, लंदौरा, भगवानपुर, लक्सर, खानपुर और नारसन।	सायं 4 बजे से रात्रि 8.30 बजे तक
ग्रामीण क्षेत्र-कुमायूँ मंडल खटीमा, किच्छा, जसपुर, बाजपुर, केलाखेडा, पिपलिया, एनडी नगर, गढी नेगी, और सरबरखेडा।	सायं 4 बजे से रात्रि 8.30 बजे तक
सभी प्राथमिक एवं द्वितीय प्रणाली उपस्थानों से पोषित 132 के0वी0, 33 के0वी0 एवं 11 के0वी0 औद्योगिक पोषक - सिडकुल, हरिद्वार एवं पंतनगर सहित। उच्च दरों(20 प्रतिशत अधिक) पर विद्युत आपूर्ति का विकल्प चुने हुये औद्योगिक उपभोक्ता प्रतिबन्धित अवधि में विद्युत कटौती से मुक्त रहेंगे। औद्योगिक पोषकों से पोषित अन्य औद्योगिक उपभोक्ता कुल स्वीकृत विद्युत भार के 15 प्रतिशत तक प्रकाश एवं पंखों के लिये उपयोग कर सकते हैं।	सायं 4.00 बजे से रात्रि 10.30 बजे तक
शहर/कस्बे लक्सर, लंदौरा, मंगलौर, जसपुर, खटीमा, गदरपुर, बाजपुर, किच्छा, सितारगंज, रामनगर।	रात्रि 8.30 बजे से मध्यरात्रि 12.00 बजे तक


सम्मानित उपभोक्ताओं से अनुरोध है कि वे विद्युत कटौती के समय धैर्य बनाये रखकर कारपोरेशन को विद्युत आपूर्ति व्यवस्था सुचारु किये जाने के कार्य में सहयोग प्रदान करने का कष्ट करें।


सम्मानित उपभोक्ताओं से यह भी अनुरोध है कि इस स्थिति का सामना करने एवं पीक घंटों में सुचारु विद्युत आपूर्ति व्यवस्था बनाये रखने हेतु वे कृपया प्रातः एवं सायं कम से कम विद्युत का उपयोग कर विद्युत बचायें।



उत्तराखण्ड पावर कारपोरेशन लि०

Amar Ujala, 15.01.2008

	उत्तराखण्ड पावर कारपोरेशन लिमिटेड
पूर्व निर्धारित विद्युत कटौती की सूचना	
उत्तराखण्ड पावर कारपोरेशन के सम्मानित उपभोक्ताओं को पुनः सूचित किया जाता है वर्तमान में देश के सम्पूर्ण उत्तरी क्षेत्र में विद्युत उपलब्धता की स्थिति खपत के सापेक्ष अत्यन्त विकट है। ओ0एन0जी0सी0 के एक गैस प्लेटफार्म में शटडाउन वापिस न किये जाने के कारण उत्तराखण्ड में विद्युत उपलब्धता की स्थिति लगभग यथावत बनी हुई है जो कि उत्तराखण्ड पावर कारपोरेशन के नियंत्रण में नहीं है।	
समय-समय पर विद्युत कटौती से उपभोक्ताओं को असुविधा न हो इसको ध्यान में रखते हुये विभिन्न क्षेत्रों में विद्युत कटौती का समय निम्नवत निर्धारित किया गया है जो दिनांक 16.01.2008 से 31.01.2008 तक लागू रहेगा।	
क्षेत्र का नाम	विद्युत कटौती का समय
शहर/कस्बे लक्सर, लंडौरा, मंगलौर, रुड़की, जसपुर, रुद्रपुर, काशीपुर खटीमा, गदरपुर, बाजपुर, किच्छा, सितारगंज, रामनगर, बहादुराबाद।	प्रातः 6 बजे से पूर्वाह्न 10 बजे तक
ग्रामीण क्षेत्र-गढ़वाल मंडल ज्वालापुर, सुल्तानपुर-भदटीपुर, रुड़की, मंगलौर, लंडौरा, भगवानपुर, लक्सर, खानपुर, नारसन और बहादुराबाद।	प्रातः 7 बजे से मध्याह्न 12 बजे तक
ग्रामीण क्षेत्र-कुमायूं मंडल खटीमा, किच्छा, जसपुर, बाजपुर, केलाखेडा, पिपलिया, एनडी नगर, गढी नेगी, और सरबरखेडा।	प्रातः 7 बजे से मध्याह्न 12 बजे तक
हल्द्वानी शहर एवं सम्पूर्ण क्षेत्र, ऋषिकेश शहर, 33 के0वी0 डोईवाला पोषक से पोषित क्षेत्र, ढकरानी, विकासनगर एवं सेलाकुई का सम्पूर्ण क्षेत्र	प्रातः 10 बजे से अपराह्न 02 बजे तक
देहरादून, मसूरी एवं नैनीताल शहर (संवेदनशील क्षेत्रों को छोड़ कर)	मध्याह्न 12 बजे से अपराह्न 03 बजे तक
हरिद्वार एवं ज्वालापुर शहर (हरि की पौड़ी को छोड़ कर)	अपराह्न 2 बजे से सांय 05 बजे तक
समस्त पर्वतीय क्षेत्र (देहरादून, मसूरी एवं नैनीताल शहरों को छोड़ कर)	अपराह्न 2 बजे से सांय 05 बजे तक
ग्रामीण क्षेत्र-गढ़वाल मंडल ज्वालापुर, सुल्तानपुर-भदटीपुर, रुड़की, मंगलौर, लंडौरा, भगवानपुर, लक्सर, खानपुर, नारसन और बहादुराबाद।	सांय 4 बजे से रात्रि 8.30 बजे तक
ग्रामीण क्षेत्र-कुमायूं मंडल खटीमा, किच्छा, जसपुर, बाजपुर, केलाखेडा, पिपलिया, एनडी नगर, गढी नेगी, और सरबरखेडा।	सांय 4 बजे से रात्रि 8.30 बजे तक
सभी प्राथमिक एवं द्वितीय प्रणाली उपस्थानों से पोषित 132 के0वी0, 33 के0वी0 एवं 11 के0वी0 औद्योगिक पोषक - सिडकुल हरिद्वार एवं पतनगर सहित। उच्च दरों (20 प्रतिशत अधिक) पर विद्युत आपूर्ति का विकल्प चुने हुये औद्योगिक उपभोक्ता प्रतिबन्धित अवधि विद्युत कटौती से मुक्त रहेंगे। औद्योगिक पोषकों से पोषित अन्य औद्योगिक उपभोक्ता कुल स्वीकृत विद्युत भार के 15 प्रतिशत तक प्रकाश एवं पंखों के लिये उपभोग कर सकते हैं।	सांय 5.00 बजे से रात्रि 11.00 बजे तक
शहर/कस्बे लक्सर, लंडौरा, मंगलौर, जसपुर, खटीमा, गदरपुर, बाजपुर किच्छा, सितारगंज रामनगर।	रात्रि 8.30 बजे से मध्यरात्रि 12.00 बजे तक
सम्मानित उपभोक्ताओं से अनुरोध है कि वे विद्युत कटौती के समय धैर्य बनाये रखकर कारपोरेशन को विद्युत आपूर्ति व्यवस्था सुचारु किये जाने के कार्य में सहयोग प्रदान करने का कष्ट करें। सम्मानित उपभोक्ताओं से यह भी अनुरोध है कि इस स्थिति का सामना करने एवं पीक घंटों में सुचारु विद्युत आपूर्ति व्यवस्था बनाये रखने हेतु वे कृपया प्रातः एवं सांय कम से कम विद्युत का उपयोग कर विद्युत बचायें।	
उत्तराखण्ड पावर कारपोरेशन लि0 "(राष्ट्र हित में बिजली बचायें)"	

 उत्तराखण्ड पावर कारपोरेशन लिमिटेड.	
पूर्व निर्धारित विद्युत कटौती की सूचना	
<p>उत्तराखण्ड पावर कारपोरेशन के सम्मानित उपभोक्ताओं को पुनः सूचित किया जाता है कि सम्पूर्ण उत्तर भारत विशेषतया उत्तराखण्ड में शीत लहर का प्रकोप जारी है जिसके कारण की खपत अधिक बढ़ गयी है। विद्युत उपलब्धता के सापेक्ष खपत का अन्तर बहुत अधिक हो गया है एवं स्थिति पूर्ववत् बनी हुई है।</p> <p>अतः समय-समय पर विद्युत कटौती से उपभोक्ताओं को असुविधा न हो इसकी ध्यान में रखते हुये विभिन्न क्षेत्रों में विद्युत कटौती का समय निम्नवत् निर्धारित किया गया है जो दिनांक 01.02.2008 से 15.02.2008 तक लागू रहेगा:-</p>	
क्षेत्र का नाम	विद्युत कटौती का समय
शहर/कस्बे लक्सर, लंदौरा, मंगलौर, जसपुर, खटीमा, गदरपुर, बाजपुर, किच्छा, सिमारगंज, बहादुराबाद।	प्रातः 6 बजे से पूर्वाह्न 10 बजे तक
रूडकी शहर, रूद्रपुर शहर, कशीपुर शहर एवं रामनगर शहर,	प्रातः 6 बजे से पूर्वाह्न 7 बजे तक
ग्रामीण क्षेत्र-गढ़वाल मंडल ज्वालापुर, सुल्तानपुर-भट्टीपुर, रूडकी, मंगलौर, लंदौरा, भगवानपुर, लक्सर, खानपुर, नारसन और बहादुराबाद।	प्रातः 7 बजे से माध्याह्न 12 बजे तक
ग्रामीण क्षेत्र-कुमायूँ मंडल खटीमा, किच्छा, जसपुर, बाजपुर, केलाखेडा, पिपलिया, एनडी नगर, गढी नेगी, और सरवरखेडा।	प्रातः 7 बजे से माध्याह्न 12 बजे तक
हल्द्वानी शहर, ऋषिकेश शहर, 33 के0वी0 डोईवाला पोषक से पोषित क्षेत्र, ढकरानी, विकासनगर एवं सेलाकुई का सम्पूर्ण क्षेत्र।	प्रातः 10 बजे से अपराह्न 02 बजे तक
हरिद्वार एवं ज्वालापुर शहर (हरि की पैडी को छोड़ कर)।	माध्याह्न 12 बजे से सायं 03 बजे तक
रूडकी शहर, रूद्रपुर शहर, काशीपुर शहर एवं रामनगर शहर,	माध्याह्न 12 बजे से अपराह्न 4 बजे तक
देहरादुन शहर (संवेदनशील क्षेत्रों को छोड़ कर)	अपराह्न 01 बजे से अपराह्न 4 बजे तक
ग्रामीण क्षेत्र-गढ़वाल मंडल ज्वालापुर, सुल्तानपुर-भट्टीपुर, रूडकी, मंगलौर, लंदौरा, भगवानपुर, लक्सर, खानपुर, नारसन और बहादुराबाद।	सायं 04.00 बजे से रात्रि 8.30 बजे तक
ग्रामीण क्षेत्र-कुमायूँ मंडल खटीमा, किच्छा, जसपुर, बाजपुर, केलाखेडा, पिपलिया, एनडी नगर, गढी नेगी, और सरवरखेडा।	सायं 04.00 बजे से रात्रि 8.30 बजे तक
सभी प्राथमिक एवं द्वितीय प्रणाली उपस्थानों से पोषित 132 के0मी0, 33 के0वी0 एवं 11 के0वी0 औद्योगिक पोषक- सिडकुल हरिद्वार एवं पंतनगर सहित। उच्च दरों (20 प्रतिशत अधिक) पर विद्युत आपूर्ति का विकल्प चुने हुये औद्योगिक उपभोक्ता प्रतिबन्धित अवधि में विद्युत कटौती से मुक्त रहेंगे। औद्योगिक पोषित अन्य औद्योगिक उपभोक्ता कुल स्वीकृत विद्युत भार के 15 प्रतिशत तक प्रकाश एवं पंखों के लिये उपयोग कर सकते हैं।	सायं 05.00 बजे से रात्रि 11 बजे तक
शहर/कस्बे लक्सर, लंदौरा, मंगलौर, जसपुर, खटीमा, गदरपुर, बाजपुर, किच्छा, सितारगंज, बहादुराबाद।	रात्रि 8.30 बजे से मध्यरात्रि 12.00 बजे तक
<p>सम्मानित उपभोक्ताओं से अनुरोध है कि वे विद्युत कटौती के समय धैर्य बनाये रखकर कारपोरेशन को विद्युत आपूर्ति व्यवस्था सुचारु किये जाने के कार्य में सहयोग प्रदान करने का कष्ट करें।</p> <p>सम्मानित उपभोक्ताओं से यह भी अनुरोध है कि इस स्थिति का सामना करने एवं पीक घंटों में सुचारु विद्युत आपूर्ति व्यवस्था बनाये रखने हेतु वे कृपया प्रातः एवं सायं कम से कम विद्युत का उपयोग कर विद्युत बचायें।</p>	
<p>No.152/DGM(HQ)/A2 Dt. 01.02.08</p> <p>उत्तराखण्ड पावर कारपोरेशन लि0</p>	
राष्ट्र हित में बिजली बचायें	

Annexure: 5

The scheduled restriction approved by Commission and that actually implemented by UPCL

Date/Time	Approved Load Shedding Schedule												Actual Schedule Implemented by UPCL															
	1600-1630	1630-1700	1700-1730	1730-1800	1800-1830	1830-1900	1900-1930	1930-2000	2000-2030	2030-2100	2100-2130	2130-2200	2200-2230	2230-2300	1600-1630	1630-1700	1700-1730	1730-1800	1800-1830	1830-1900	1900-1930	1930-2000	2000-2030	2030-2100	2100-2130	2130-2200	2200-2230	2230-2300
28/12/07																												
29/12/07																												
30/12/07																												
31/12/07																												
01/01/08																												
02/01/08																												
03/01/08																												
04/01/08																												
05/01/08																												
06/01/08																												
07/01/08																												
08/01/08																												
09/01/08																												
10/01/08																												
11/01/08																												
12/01/08																												
13/01/08																												
14/01/08																												
15/01/08																												
16/01/08																												
17/01/08																												
18/01/08																												
19/01/08																												
20/01/08																												
21/01/08																												
22/01/08																												
23/01/08																												
24/01/08																												
25/01/08																												
26/01/08																												
27/01/08																												
28/01/08																												
29/01/08																												
30/01/08																												
31/01/08																												
01/02/08																												
02/02/08																												
03/02/08																												
04/02/08																												
05/02/08																												
06/02/08																												
07/02/08																												
08/02/08																												
09/02/08																												
10/02/08																												
11/02/08																												
12/02/08																												
13/02/08																												
14/02/08																												
15/02/08																												

Dainik Jagran-Amar Ujala, 28.03.2008

**UTTARAKHAND ELECTRICITY REGULATORY COMMISSION**Institution of Engineers (India), 1st Floor, Near ISBT, Majra, Dehradun (UA)

PH. 0135-2641119 FAX- 2643755 Website www.uerc.in E-mail- uttaranchalerc@rediffmail.com

PUBLIC NOTICE

It has been brought to the notice of the Commission that Uttarakhand Power Corporation Limited (UPCL) has levied unjustified and huge penalties on industries for usage of power during restriction period. Complaints have also been received from industries that they have been levied penalties in spite of their option for continuous power during restriction period. In the light of above, the payment of penalties had been deferred and UPCL had been directed to accept current dues without penalty till the matter is finally resolved by the Commission.

The Commission has decided to analyse the issue in detail and hereby grants an opportunity to an industry, which has been aggrieved by such penalty, to make a representation before the Commission along with copy of the impugned bill and receipt of payment made against such bill and any other relevant information by 15th April 2008. The Commission would hold hearing(s) on the issue during 2nd week of May 2008. The exact date and venue shall be informed individually to each of the industries who submit representation to the Commission in this regard.

Advt. No.33/07-08

SECRETARY

List of Respondents

1.	M/s. Shivangee Crafts Ltd., 5 th Km. Stone, Ramnagar Road, Kashipur Pin-244713
2.	M/s. Indian Rubber Products, Industrial Area, Hardwar, Pin-249401
3.	M/s. Tiger Steel Engineering (India) Pvt. Ltd., Plot No. 4, Sector 12, SIDCUL, Hardwar, Pin-249403
4.	M/s. Poddar Pharmaceuticals Pvt. Ltd., E-35, Industrial Area, Hardwar.
5.	M/s. Jai Mata Di Industries, 24-A, Nandnagar, Ind. Estate, Mahuakheraganj, Aliganj Road, Kashipur(U.S.Nagar) Pin-244713
6.	M/s. PSB Papers Ltd., Beria Road, Bazpur (U.S. Nagar) Pin-262401
7.	M/s. Cheema Papers Ltd., Regd. & Admn. Office Kashipur, U.S. Nagar
8.	M/s. Khatima Fibers Ltd., UPSIDC Industrial Area, Khatima, U.S. Nagar, Pin-262308
9.	M/s. Bharat Electronics Ltd., Govt. Of India, Kotdwar, Pauri Garhwal Pin-246149
10.	M/s. Jubilant Organosys Science Active, Village Sikandarpur Bhainswal Roorkee Dehradun Highway, Bhagwanpur, Roorkee, Distt- Haridwar Pin-247661
11.	M/s. GBPL Industries, 11/24 Co-operative Industrial Estate, 2 nd Shed After Director of Industries Patel Nagar, Dehradun
12.	M/s. Glass Bulbs Pvt. Ltd., 7, Co operative Industrial Estate, Patel Nagar, Dehradun Pin-248001
13.	M/s. Satya Industries, Mohabewala Industrial Area, Dehradun Pin-248110

14.	M/s. Dass Electronics, Govt. Industrial Estate, Patel Nagar, Dehradun Pin248001
15.	M/s. Mahadev Marble General Mahadev Singh Road, Kanwali, Dehradun. Pin-248001
16.	M/s. Automatic Products, Vill.-Shankarpur, Sahaspur, Dehradun.
17.	M/s. Sidcul Industrial Association ,(SIA) Kirby Building System (Hardwar) Ltd., Plot No. 2, Sector-11, IIE, Sidcul, Hardwar – 249403.
18.	M/s. Sant Steel & Alloys Pvt. Ltd., Plot No. 1 Jashodhapur Industrial Area, Kotdwar Pin-246149
19.	M/s. Jindal Lamps (P) Ltd., Plot No. 1 Nand Nagar Industrial Estate, Village –Mahuakheraganj, Aliganj Raod, Kashipur Pin-244713
20.	M/s. Shri Ram Polymers, Kashipur
21.	M/s. Pioneer Pet Industries, E-66, Industrial Area, Haridwar, Pin-249401
22.	M/s. Contemporary Target Pvt. Ltd., F-7, Industrial Area Haridwar, Pin- 249401
23.	M/s. Sehgal Steel Industries, D-26, Industrial Area ,Hardwar Pin-249401
24.	M/s. Platinum Pharmaceuticals P. Ltd., Plot No 90-91, Sector -6A, I.I.E, SIDCUL, Hardwar.
25.	M/s. Industries Association of Uttarakhand, C/o Satya Industries, Mohabewala Industrial Area, Dehradun. Pin-248110
26.	M/s. Shivnesh Pet India, E-72, Hardwar Industrial Area, Hardwar, 249401
27.	M/s. Wings Commercial Co. Ltd., C-1 & C-2, U.P.S.I.D.C Industrial Area, Bazpur, U.S. Nagar
28.	M/s. Manokamna Steel (P) Ltd., Plot no. C-4, U.P.S.I.D.C Industrial Area, Village-Jagannathpur, Bazpur,

29.	M/s. Mica Glass Industries, D/34-35, Indl. Area, Hardwar, Pin-249401
30.	M/s. Kukreti Steel Ltd., F-23-27, Industrial Area, Jashodharpur, Kotdwar
31.	M/s. VVS Pharmaceutical & Chemicals Pvt. Ltd, D-9, Indl. Area, Hardwar Pin-249401
32.	M/s. ANTAK, D-3, Industrial Area, Site -II, Hardwar
33.	M/s. Sunshine Industries Ltd., 279/5, Vill.-Vikrampur, Tehsil Bazpur, U.S. Nagar
34.	M/s. Rashtriya Sahara, Shed no. 3, Co-operative Industrial Estate, Patel Nagar, Dehradun
35.	M/s. Shree Shyam Pulp & Board Mills Ltd., 5 th K.M. Moradabad Road, Kahsipur, U.S. Nagar Pin-244713
36.	M/s. Marico Ltd., B2 Plot, UPSIDC Industrial Area, Selaqui, Dehradun Pin-248197
37.	M/s. Sagar Paper Mills Pvt. Ltd., 5 th Km. Manglor- Jhabrera Road, Latherdeva Hunn, Hardwar
38.	M/s. Vishwakarma Paper and Boards Ltd., 4.5 Km., Ramnagar Road, Kashipur, U.S. Nagar
39.	M/s. Kashi Enterprises, B-25-29, Indl. Estate, Bazpur Road, Kashipur Pin- 244713
40.	M/s. Galwalia Ispat Udyog Ltd., Narain Nagar Industrial Estate, Bazpur Road, Kashipur, U.S. Nagar
41.	M/s. Kashi Vishwanath Steels Ltd., Narain Nagar Industrial Estate, Bazpur Road, Kashipur, Pin-244713
42.	M/s. Lotus Beauty Care Products Pvt. Ltd., Plot No. 7, Sector IA, IIE, Hardwar Pin-249403
43.	M/s. Uttaranchal Iron & Ispat Ltd., Plot no. 3-4 UPSIDC Industrial Area, Jashodhapur, Kotdwar
44.	M/s. Sumo Steels Pvt. Ltd., E-45/50, Jasodharpur, Industrial Area, Kotdwar, Distt- Pauri Garhwal

45.	M/s. Bhagyashree Steels & Alloys (P) Ltd., E-17-24, Jasodharpur, Industrial Area, Kotdwar, Distt- Pauri Garhwal. Pin -246149
46.	M/s. Himgiri Ispat Pvt. Ltd., E-27, 28, 39 & 40, Jashodharpur, Kotdwar
47.	M/s. Kotdwar Steel Ltd., Block-E , Jashodharpur Industrial Area, Kotdwar.
48.	M/s. J.N. Ispat Pvt. Ltd., E-16, Industrial Area, Jashodharpur, Kotdwar Pin-246149
49.	M/s. HRJ Steels Pvt. Ltd., Plot no. F-12 to 22, Jashodharpur, Kotdwar Pin-246149
50.	M/s. Uttaranchal Iron & Ispat Ltd., Furnace Division(Unit-II) Plot no. 5-7 Jasodharpur Industrial Kotdwar, Pauri Garhwal
51.	M/s. Poddar Alloys Pvt. Ltd., E-29-E-38, UPSIDC, Industrial Area, Jashodharpur, Kotdwar Pin-203131
52.	M/s. Shree Sidhabali Sugar Ltd., E-67-72, UPSIDC, Industrial Area, Jasodharpur, Kotdwar
53.	M/s. Pushkar Steel Pvt. Ltd., D-23-25, UPSIDC Industrial Area, Kotdwar
54.	M/s. Shree Sidhabali Steels Ltd, Kandi Road, Kotdwar Pin-246149
55.	M/s. Shreya Life Sciences (P) Ltd., Plot no. 13/14/15, Vill. Raipur, Bhagwanpur, Roorkee, Pin-247667
56.	M/s. Excel Engineering, Plot no. 16 Sec-IIDC Integrated Industrial Estate SIDCUL, Hardwar Pin-249403
57.	M/s. Hardwar Industrial Development Association, E-12, Industrial Area, Hardwar, Pin-249401
58.	M/s. Kissan Mechanical Works, D-37, Industrial Area, Hardwar Pin-249401
59.	M/s Rishi Chemical Works (P) Ltd., F-5 to 10, Govt. Industrial Area, Haridwar Pin-249401
60.	M/s Springfit, F-61-62, Industrial Area, Haridwar

61.	M/s Keep In Touch Clothing Pvt. Ltd. E-26, UPSIDC, Indl. Area, Site II, Haridwar
62.	M/s. Kumaun Garhwal Chamber of Commerce and Industry, Uttarakhand, Chamber House, Industrial Estate Bazpur Road, Kashipur, U.S. Nagar Pin-244713
63.	M/s. Digital Electronics & Telecom, D-21, Industrial Area, (Near 33 KV Electric sub-Station) Hardwar Pin-249401
64.	M/s. Ambuja Cement Ltd., Village- Lakeswari , P.O. Sikandarpur Bhainswal, Tehsil Roorkee, Hardwar Pin-247661
65.	M/s. Shree Tribhuvan Ispat Pvt. Ltd., Industrial Estate Vikarampur, Ramraj Road, Bazpur, U.S. Nagar
66.	M/s. Siddhi Plast India, E-46, Hardwar Industrial Area, Hardwar
67.	M/s. Umashakti Steels Pvt. Ltd., Kotdwar
68.	M/s. J.T. Engineering (P) Ltd., 11-12/1, Village Mohabewala, Saharanpur Road, Dehradun. Pin-248002
69.	M/s. Everest Industries Ltd., Khasra no. 158 & 159, Village Lakesari, Bhagwanpur, Roorkee, Hardwar Pin-247667
70.	M/s. Padmawati Pharmaceuticals, F-52, Indl. Area, Hardwar Pin-249401
71.	M/s. Varahamurti Flexirub Industries (P) Ltd., Plot no. 14 Sec-3, SIDCUL Hardwar.
72.	M/s. H.K. Packers & Printers, Plot No. 60, Sector-7, IIE, Sidcul, Hardwar
73.	M/s. Varroc Engg. Pvt.Ltd., Plot NO. 20, Sector-9, IIE, Pantnagar. Pin-263153
74.	M/s. HCL Infosystems Ltd., Plot No. 1, 2, 27 & 28, Sector-5, IIE, Pantnagar
75.	M/s. Greenply Industries Ltd., Plot no.2 Sector-9, IIE, Pantnagar, U.S. Nagar. Pin-263153
76.	M/s. R.S. Steels & H.L. Papers Ltd., D-3, D-4, UPSIDC, Industrial Area, Dhalwala (Tehri Garhwal), Rishikesh Pin-249201

77.	M/s. Endurance Technologies Pvt. Ltd., Plot No. 3, Sector 10, IIE, Pantnagar, U.S.Nagar Pin.263153
78.	M/s. High Technology Transmission Systems (I) Pvt. Ltd., Plot No. 7, Sector 10, IIE, Pantnagar, U.S. Nagar. Pin.263145
79.	M/s. Usha Breco Ltd., Mansadevi,Udan Khatola , Hardwar Pin-249401
80.	M/s. Autocomp Corporation Panse Pvt. Ltd., Plot No. 38, Sector No. 11, SIDCUL, Pantnagar. Pin-263153
81.	M/s. Sansera Engineering Pvt. Ltd., Plot No. 18, Sector 9, IIE, Pantnagar, Rudrapur Pin-263153
82.	M/s. KKG Industries (Unit No. 1, 2 & 3), Plot No. 55, D-28 & 31, Sector-7, Industrial Area, Bahadradbad & Sector 3A, Hardwar. Pin-249403
83.	M/s. TVS Sundaram Fasteners Ltd., Pantnagar
84.	M/s. Ganesh Polytex Ltd., Plot No. 6, Sector 2, IIE, Pantnagar, Rudrapur
85.	M/s. Kores Printer Technology (P) Ltd., Plot No. 15A, Sector II, Pantnagar, Rudrapur
86.	M/s. Archidply, Site- Plot no.7, Sector-9 SIDCUL, Pantnagar, Rudrapur -263153
87.	M/s. Active Personal Care Products (P) Ltd. Plot no. 48 to 57 Sector-3, IIE, Pantnagar, U.S. Nagar.
88.	M/s. Steel Bird International , Plant: Plot 62 & 69, Sector IIDC , IIE Pantnagar,Uttarakhand Pin 263153
89.	M/s. GSK Pharmaceuticals, Factory, B-3. Dev Bhoomi Industrial Estate Puhana, Iqbalpur Road, Banta Khedi Roorkee Distt- Haridwar.
90.	M/s. TKG Prestige, Plot no. A-1-A-2, Devbhoomi Industrial Estate Pohana Iqbalpur Road, Vill Bentakhedi, Tehsil Roorke.
91.	M/s. Salarar Pipes, Plot no-35 Sector no.6, IIE Pantnagar, Rudrapur, U.S.Nagar.
92.	Shree Shyam Polyemers, Industrial Estate, Kashipur, U.S. Nagar

Summary of Original and Revised Penalty submitted by UPCL

Sl. No.	Name of Consumer	Original Penalty (Rs.)	Revised Penalty (Rs.)
1.	M/s HRJ Steel	560602.00	NIL
2.	M/s Kukreti Steel	531877.00	NIL
3.	M/s Sumo Steel	568546.00	378540.00
4.	M/s Sidh Bali Steel	552775.00	552775.00
5.	M/s Jai Mateshwari	463256.00	NIL
6.	M/s Himgiri Ispat	983157.00	683157.00
7.	M/s Poddar Alloys	1559668.00	1237668.00
8.	M/s Pushkar Steel	495532.00	495532.00
9.	M/s Kotdwar Steel	793660.00	NIL
10.	M/s Sant Steel	434187.00	NIL
11.	M/s Sidh Bali Sugar	947927.00	NIL
12.	M/s J N Ispat	577059.00	58250.00
13.	M/s Bhagya Shree Steel	525166.00	NIL
14.	M/s Uttaranchal Iron & Ispat (3000KVA)	1615034.00	790566.00
15.	M/s Uttaranchal Iron & Ispat (1750KVA)	2153813.00	1091845.00
16.	M/s Bharat Electronics	853686.00	1543686.00
17.	M/s G.B. Equipments	74432.00	69152.00
18.	M/s Rhydberg Pharmaceuticals	295583.00	265583.00
19.	M/s Marico Ltd.	265278.00	277778.00
20.	M/s Beam Flash Lighting Pvt. Ltd.	248410.00	248410.00
21.	M/s Automatic Products	79261.00	79261.00
22.	M/s Excel Engineering	104219.00	99002.00
23.	M/s Paltinum Pharmaceuticals	103993.00	88993.00
24.	M/s Tiger Steel	633479.00	745379.00
25.	M/s Lotus Beauty Care	1002911.00	977911.00
26.	M/s Pine Packaging	1709341.00	1709341.00
27.	M/s Shreya Life Science	855321.00	855321.00
28.	M/s Jubilient Organics	585532.00	585532.00
29.	M/s Sagar Paper Mills	630175.00	590175.00
30.	M/s Sunshine Industries	6910152.00	6010152.00
31.	M/s Mano Kamana Steel	5868921.00	5718921.00
32.	M/s P.S.B. Ltd.	2217306.00	2217306.00
33.	M/s Wings Commercial	3145000.00	NIL
34.	M/s Kashi Enterprises	2322453.00	1872453.00
35.	M/s Sri Ram Polymer	259087.00	244587.00
36.	M/s Jindal Lamps	77363.00	66363.00
37.	M/s Galwalia Ispat	18665905.00	8490905.00
38.	M/s Vishwakarma Paper	155000.00	NIL
39.	M/s Kashi Vishwanath Steel	12570347.00	8370347.00

40.	M/s Shyam Pulp & Board	200000.00	NIL
41.	M/s Jai Mata Di	185498.00	140498.00
42.	M/s Shivangee Craft Ltd.	2223875.00	NIL
43.	M/s Cheema Papers	956129.00	213834.00
44.	M/s Dass Electronic	44649.00	46199.00
45.	M/s Glass Bulb Pvt. Ltd.	13495.00	10798.00
46.	M/s GBPL Industries	45367.00	43817.00
47.	M/s Drive Line Spare	96623.00	95156.00
48.	M/s Satya Industries	31205.00	58406.00
49.	M/s Sahara India Mass Communication	860823.00	816788.00
50.	M/s Mahadev Marble	41680.00	NIL
51.	M/s Keep in Touch	115391.00	112619.00
52.	M/s Kishen Mechanical	91977.00	89337.00
53.	M/s Mica Glass	59586.00	48406.00
54.	M/s V.V.S. Pharmaceutical	1098345.00	413714.00
55.	M/s Indian Rubber Product	236398.00	259798.00
56.	M/s T.R. Sehgal	161964.00	161964.00
57.	M/s Antak Agencies	106029.00	59829.00
58.	M/s Shivansh Pet	49541.00	45361.00
59.	M/s Rishi Chemicals	27873.00	40739.00
60.	M/s Poddar Pharmaceuticals	36376.00	105406.00
61.	M/s Spring Fields	65335.00	55303.00
62.	M/s Tribhuvan Ispat	2284146.00	1411648.00
63.	M/s Uma Shakti	895405.00	NIL
64.	M/s M V Enterprises	1149860.00	979860.00
65.	M/s ATP Silvi Product	1628607.00	1574028.00
66.	M/s HCL Industries	237460.00	440139.00
67.	M/s Ganesh Polytex Ltd.	404102.00	NIL
68.	M/s Varroc Engineering Pvt. Ltd.	892500.00	1041250.00
69.	M/s High Technology Transmission System	137500.00	137500.00
70.	M/s Sansera Engineers Pvt. Ltd.	300000.00	337500.00
71.	M/s Kore Printer Tech. Pvt. Ltd.	195143.00	247612.00
72.	M/s Sundrum Fastners Ltd.	2988193.00	3429054.00
73.	M/s Endurance Technologies Ltd.	1493700.00	1723500.00

List of Participants in Hearing held on 16.07.2008

S L	Name of Representative	Name of Company and Address
1.	Shri Vikram	M/s. Dass Electronics, Govt. Industrial Estate, Patel Nagar, Dehradun Pin248001
2.	Shri R.K. Agrawal	M/s. Glass Bulbs Pvt. Ltd., 7, Co operative Industrial Estate, Patel Nagar, Dehradun Pin-248001
3.	Shri R.K. Agrawal	M/s. G.B.P.L Industries, 11/24 Co-Operative Industrial Estate, 2 nd shed after Director of Industries. Patel Nagar, Dehradun.
4.	Shri Pankaj Gupta	M/s. Satya Industries, Mohabewala Industrial Area, Dehradun Pin-248110
5.	Shri Saurabh Tiwari	M/s. Varroc Engg. Pvt.Ltd., Plot NO. 20, Sector-9, IIE, Pantnagar. Pin-263153
6.	Shri K..S. Rawat & Shri M.S. Gambheer	M/s. J.T. Engineering (P) Ltd., 11-12/1, Village Mohabewala, Saharanpur Road, Dehradun. Pin-248002
7.	Shri Manoj Kumar Chugh	M/s. Sunshine Industries Ltd., 279/5, Vill.-Vikrampur, Tehsil Bazpur, U.S. Nagar
8.	Shri Manoj Kumar Chugh	M/s. Manokamna Steel (P) Ltd., Plot no. C-4, U.P.S.I.D.C Industrial Area, Village-Jagannathpur, Bazpur,
9.	Shri Manjeet Singh	M/s. PSB Papers Ltd., Beria Road, Bazpur (U.S. Nagar) Pin-262401
10.	Shri Prahlad Singh	M/s. Endurance Technologies Pvt. Ltd. Plot no.3 Sector 10, IIE Pantnagar, Rudrapur
11.	Shri Prahalad Singh	High Technology transmission Systems Pvt. Ltd. Plot no-7, Sector 10, IIE Pantnagar, Rudrapur
12.	Shri Sameer Gupta	M/s. Advanced Aromatics (P) Ltd F-39, Industrial Area, Haridwar
13.	Shri Ashutosh Verma	M/s Tata Motors, Pantnagar
14.	Shri. A.K. Saxena, Manager	M/s. Bharat Electronics Ltd., Govt. Of India, Kotdwar, Pauri Garhwal Pin-246149
15.	Shri Harpal Gautam, Director	M/s. Sumo Steels Pvt. Ltd., E-45/50, Jasodharpur, Industrial Area, Kotdwar, Distt- Pauri Garhwal

16.	Shri Pawan Agarwal, Director	M/s. Shree Sidhabali Steels Ltd, Kandi Road, Kotdwar Pin-246149
17.	Shri Deepak Poddar, Director	M/s. Poddar Alloys Pvt. Ltd., E-29-E-38, UPSIDC, Industrial Area, Jashodharpur, Kotdwar Pin-203131
18.	Shri Rupender Singh	M/s. Kishan Mechanical, Haridwar D-37 Industrial Area Haridwar
19.	Shri Sandeep Chhabra	M/s. Perfetti Mill (India) Pvt Lt. 14 B Sector-9, IIE Pantnagar SIDCUL, U.S. Nagar.
20.	Shri R.M. Khandewal	M/s. Indian Rubber Products, Industrial Area, Hardwar, Pin-249401
21.	Shri Sanjeev Jain	M/s. Automatic Products, Vill.-Shankarpur, Sahaspur, Dehradun.
22.	Shri Rupinder Singh	M/s. Excel Engineering, Plot no. 16 Sec-IIIDC Integrated Industrial Estate SIDCUL, Hardwar Pin-249403
23.	Shri S.S Rawat & Shri Rakesh Sharma	M/s. Lotus Beauty Care Products Pvt. Ltd., Plot No. 7, Sector IA, IIE, Hardwar Pin-249403
24.	Shri Mahak Singh	M/s. Tiger Steel Engineering (India) Pvt. Ltd., Plot No. 4, Sector 12, SIDCUL, Hardwar, Pin-249403
25.	Shri J.B Agrawal	M/s. Kashi Enterprises, B-25-29, Indl. Estate, Bazpur Road, Kashipur Pin- 244713
26.	Shri J.B. Agarwal	M/s. Galwalia Ispat Udyog Ltd., Narain Nagar Industrial Estate, Bazpur Road, Kashipur, U.S. Nagar
27.	Shri J.B. Agarwal	M/s. Kashi Vishwanath Steels Ltd., Narain Nagar Industrial Estate, Bazpur Road, Kashipur, Pin-244713
28.	Shri Vishnu Somadi	M/s. Jai Mata Di Industries, 24-A, Nandnagar, Ind. Estate, Mahuakheraganj, Aliganj Road, Kashipur(U.S.Nagar) Pin-244713
29.	Shri A.K. Babbar	M/s. Cheema Papers Ltd., Regd. & Admn. Office Kashipur, U.S. Nagar
30.	Shri A.K. Awasthi & Shri Hemant Kaushik	M/s. Shreya Life Sciences (P) Ltd., Plot no. 13/14/15, Vill. Raipur, Bhagwanpur, Roorkee, Pin-247667

31.	Shri Sanjeev Kumar & Shri Manoj Nangalia & Shri Sanjay Semalty	M/s. Jubilant Organosys Science Active, Village Sikandarpur Bhainswal Roorkee Dehradun Highway, Bhagwanpur, Roorkee, Distt- Haridwar Pin-247661
32.	Shri Anil Tyagi	M/s. Sagar Paper Mills Pvt. Ltd., 5 th Km. Manglor- Jhabrera Road, Latherdeva Hunn, Hardwar
33.	Shri R.K. Singh	M/s. TVS Sundram Fastners Plot no. 60, Sector 11, Integrated Industrial Estate, Pant Nagar
34.	Shri Harpal Singh	M/s. Siddhi Plast India, E-46, Hardwar Industrial Area, Hardwar
35.	Shri Shrireenivas	M/s. Padmawati Pharmaceuticals, F-52, Indl. Area, Hardwar Pin-249401
36.	Shri M.L. Jain	M/s. Shivangee Crafts Ltd., 5 th Km. Stone, Ramnagar Road, Kashipur Pin-244713
37.	Shri Pukhraj Kushwaha	M/s. Khatima Fibers Ltd., UPSIDC Industrial Area, Khatima, U.S. Nagar, Pin-262308
38.	Shri R. Upadhyay	M/s Rishi Chemical Works (P) Ltd., F-5 to 10, Govt. Industrial Area, Haridwar Pin-249401
39.	Shri G.S. Singhal	M/s. Mahadev Marble General Mahadev Singh Road, Kanwali, Dehradun. Pin-248001
40.	Shri Sudhir Mehta & Ravish Tyagi	M/s. Sidcul Industrial Association ,(SIA) Haridwar.
41.	Shri R.K. Khanna	M/s. Sant Steel & Alloys Pvt. Ltd., Plot No. 1 Jashodhapur Industrial Area, Kotdwar Pin-246149
42.	Shri Sanjeev Agarwal	M/s. Pioneer Pet Industries, E-66, Industrial Area, Haridwar, Pin-249401
43.	Shri K.S. Bisht & Shri M. Bisht	M/s. Contemporary Target Pvt. Ltd., F-7, Industrial Area Haridwar, Pin- 249401
44.	Shri T.R. Seghal	M/s. Sehgal Steel Industries, D-26, Industrial Area ,Hardwar Pin-249401
45.	Shri Manoj Kumar Chugh	M/s. Wings Commercial Co. Ltd., C-1 & C-2, U.P.S.I.D.C Industrial Area, Bazpur, U.S. Nagar.

46.	Shri R. Seghal	M/s. Mica Glass Industries, D/34-35, Indl. Area, Hardwar, Pin-249401
47.	Shri Suresh Bansal	M/s. Kukreti Steel Ltd., F-23-27, Industrial Area, Jashodharpur, Kotdwar
48.	Shri Manoranjan Subudhi	M/s. VVS Pharmaceutical & Chemicals Pvt. Ltd, D-9, Indl. Area, Hardwar Pin-249401
49.	Shri Samir Garg	M/s. Shree Shyam Pulp & Board Mill Ltd. 5 th K.m Moradabad Road, Kashipur, U.S. Nagar. Pin-244713
50.	Shri Manish Peshawaria	M/s. ANTAK, D-3, Industrial Area, Site -II, Hardwar
51.	Shri Mukesh Agarwal	M/s. Rashtriya Sahara, Shed no. 3, Co-operative Industrial Estate, Patel Nagar, Dehradun
52.	Shri Ajay Verma	M/s. Vishwakarma Paper and Boards Ltd., 4.5 Km., Ramnagar Road, Kashipur, U.S. Nagar
53.	Shri Rajnish Rathi	M/s. Bhagyashree Steels & Alloys (P) Ltd., E-17-24, Jasodharpur, Industrial Area, Kotdwar, Distt- Pauri Garhwal. Pin -246149
54.	Shri U.K. Rajput	M/s. Himgiri Ispat Pvt. Ltd., E-27, 28, 39 & 40, Jashodharpur, Kotdwar
55.	Shri Sanjeev Gupta	M/s. Kotdwar Steel Ltd., Block-E , Jashodharpur Industrial Area, Kotdwar.
56.	Shri Ankur Gupta	M/s. HRJ Steels Pvt. Ltd., Plot no. F-12 to 22, Jashodharpur, Kotdwar Pin-246149
57.	Shri V.K. Jain	M/s. Poddar Pharmaceuticals Pvt. Ltd., E-35, Industrial Area, Hardwar.
58.	Shri Pawan Agarwal	M/s. Shree Sidhabali Sugar Ltd., E-67-72, UPSIDC, Industrial Area, Jasodharpur, Kotdwar
59.	Shri G.P. Raturi	M/s Keep In Touch Clothing Pvt. Ltd. E-26, UPSIDC, Indl. Area, Site II, Haridwar
60.	Shri M.P. Mittal	M/s. Ambuja Cement Ltd., Village- Lakeswari , P.O. Sikandarpur Bhainswal, Tehsil Roorkee, Hardwar Pin-247661

61.	Shri B.P. Verma	M/s. Everest Industries Ltd., Khasra no. 158 & 159, Village Lakesari, Bhagwanpur, Roorkee, Hardwar Pin-247667
62.	Shri Arvind Chandra & Shri Ajay Kumar	M/s. Usha Breco Ltd., Mansadevi,Udan Khatola , Hardwar Pin-249401
63.	Shri P.K. Mishra & Shri J.R. Patel	M/s. Autocomp Corporation Panse Pvt. Ltd., Plot No. 38, Sector No. 11, SIDCUL, Pantnagar. Pin-263153
64.	Shri C.S. Mehta	M/s. Sansera Engineering Pvt. Ltd., Plot No. 18, Sector 9, IIE, Pantnagar, Rudrapur Pin-263153
65.	Shri S.S. Shekhawat	M/s. Ganesh Polytex Ltd., Plot No. 6, Sector 2, IIE, Pantnagar, Rudrapur
66.	Shri Binod Agarwal	M/s. Kores Printer Technology (P) Ltd., Plot No. 15A, Sector II, Pantnagar, Rudrapur
67.	Shri Prakash Gangwani	M/s. Active Personal Care Products (P) Ltd. Plot no. 48 to 57 Sector-3, IIE, Pantnagar, U.S. Nagar.
68.	Shri K.B. Thukral	M/s. Alps Industries Ltd 1A, Sector-10 , SIDCUL, Opp Roshanabad Court, Haridwar
69.	Shri Prakash Papnai	M/s. TKG Prestige, Plot no. A-1-A-2, Devbhoomi Industrial Estate Pohana Iqbalpur Road, Vill Bentakhedi, Tehsil Roorke.
70.	Shri J.K Khera	M/s. Kwalitty Polly threads Pvt. Ltd Sec-3A Plot no 34 IIE Haridwar
71.	Shri A. Sreedhar Reddy	M/s. Voltas Ltd Plot no 2-5 Sector 8 SIDCUL- Rudrapur, U.S.Nagar
72.	Shri N. Nagarajan	M/s. Hewleet Packard India Sales Pvt. Ltd. Plot no.9-11A & 35-37 A , Sector-5 SIDCUL, Rudrapur.
73.	Shri Sachin Verma	M/s. Radico Khaitan Ltd Bazpur Industrial Area, Sultanpur Area, Patti Haripur Bazpur.
74.	Shri Sudhir Mehta	M/s. Kirbu India Ltd Plot no 2, Sec-11 IIE SIDCUL, Haridawr
75.	Shri Praven	M/s. Masscom India Ltd. Plot no 32 Sector 3 A SIDCUL, Haridwar
76.	Shri Praveen Atray	M/s. Themis Medicare Ltd, Plot no. 16, 17, 18, Sec-6A,SIDCUL, Haridwar
77.	Shri N.S. Daga	M/s. Surya Polypack Ltd Plot no 11 Sector 3A SIDCUL, Haridwar

78.	Shri G.S Darji	M/s. Neel Auto Ltd Plot no.10 Sector 4 SIDCUL, Pantnagar
79.	Shri J.K. Mittal	M/s. Pricol Ltd. Plot no.11 Sector 10 Rudrapur
80.	Shri R.K. Maurya	M/s. SRF Limited Plot no 12 Rampura Ramnagar Road Kashipur, U.S. Nagar
81.	Shri Manish Tanwar & Shri C.P. Khanna	M/s. HCL Info systems Ltd. Plot no -1,2,27, 28 Sector 5 SIDCUL IIE, Pantnagar, U.S. Nagar (Rudrapur)
82.	Shri Neelesh Mehta & Shri Manish Mishra	M/s Sterlite Technologies Ktd. Plot no. 2 D, Sector-10 , IIE SIDCUL Haridwar
83.	Shri M.S. Kaushal	Kumar Oxygen Ltd, Rudrapur
84.	Shri S.K. Bharadwaj	M/s. Medicamen Biotech Ltd Sector 6 A, Plot 86 & 87 SIDCUL, Haridwar
85.	Shri Vipul Agrawal	M/s. Mil India Ltd, Plot no. 16-63 Sector -5 IIE, SIDCUL, Haridwar
86.	Shri S.N. Kumar	M/s. Bombay Trading Ltd. Sector-5, Plot 23-26 SIDCUL Rudrapur.
87.	Shri Dinesh & Shri B.S. Seherawat	M/s. ACME Tele Power Ltd, Sector-5, SIDCUL Pantnagar
88.	Shri Gurminder Pal Singh	M/s. Miter and Miter Engg. Pvt Ltd. Plot-H-21 Sec-2, Pantnagar, Rudrapur
89.	Shri Harindra Garg	Cello Houewares, Haridwar, Plot no.4, Sector 3 IIE, SIDCUL Haridwar.
90.	Shri Sarveen Sharma	M/s. S & S Pvt. Ltd.
91.	Shri Ajay Tewari	M/s. Shirdi India Ltd. Plot-1, Sector-9 SIDCUL Pantnagar
92.	Shri M.C.Joshi	M/s. La Opla R.G..Ltd B-108, SIDCUL Sitarganj
93.	Shri. P.C. Sinha	SIDCUL Enterprises welfare Society
94.	Shri Rajnish Kumar	M/s. Neel Mettal Product Ltd Haridwar
95.	Shri Sandeep Chhabra	M/s. Prefetti Van melle (I) Pvt. Ltd Plot no 14 B Sector -9 IIE Pantnagar U.S. Nagar
96.	Shri Pradeep Kumar Seni	M/s. Somany Foam Ltd. Plot no. 13 - 15 Sector 4, SIDCUL Haridwar

97.	Shri Rajeev Ghai	KGCCI, Uttarakhand, Chamber House, Industrial Estate Bazpur Road, Kashipur, U.S. Nagar Pin-244713
98.	Shri Darbara Singh	KGCCI, Uttarakhand, Chamber House, Industrial Estate Bazpur Road, Kashipur, U.S. Nagar Pin-244713
99.	Shri S.K. Sachan	M/s. Ridhi Sidhi Ltd., Rudrapur
100.	Shri Gurmeet Singh	M/s. Kissan M/c Tools, E-49, Industrial Area, Hardwar

Sample usage pattern of industries during period of restriction

(This data is only for illustrative purposes, actual load details and corresponding bills shall be based on MRI load survey to be annexed therewith)

S. No.	Name of consumer	Contracted Load	No of Days of Violation	Total no. of Time Slots of Violation	Average no. of slots of violation/day	Max load	Min load
		(kVA)				(%)	(%)
1.	Kashi Enterprises	1000.00	29	46	1.59	90.00	15.60
2.	Shri RamPolymer	290.00	13	32	2.46	52.97	15.72
3.	Jindal Lamps	220.00	4	8	2.00	88.36	18.00
4.	Galvaliya Ispat	18500.00	6	7	1.17	58.46	18.16
5.	Kashi Vishvanath Steel	12000.00	7	11	1.57	56.51	18.25
6.	Jai mata Di	100.00	42	272	6.48	65.26	32.68
7.	Cheema Paper Ltd	1200.00	9	93	10.33	58.33	21.88
8.	Dass Electronc	30.72	29	81	2.79	68.68	15.63
9.	Glass Bulb Pvt Ltd	30.72	9	12	1.33	38.09	16.93
10.	GBPL Industry	30.72	26	35	1.35	28.65	15.63
11.	Drive Line Spare	43.88	39	199	5.10	67.68	15.04
12.	Satya Industry	25.45	34	95	2.79	103.73	15.72
13.	Sahara India Mass.Com	325.00	46	417	9.07	53.17	15.51
14.	J.T.Engg.	50.00	37	255	6.89	35.69	15.20
15.	Bharat Electronic	1150.00	12	127	10.58	47.58	15.97
16.	Uttaranchal Iron and Ispat 2	3000.00	4	4	1.00	44.00	16.00
17.	J.N Ispat	400.00	1	1	1.00	15.78	15.78
18.	Puskar Steel	2000.00	1	1	1.00	60.00	60.00
19.	Himgiri Ispat	3000.00	1	1	1.00	34.33	34.33
20.	Sidhballi Steel	1850.00	3	3	1.00	23.68	18.05
21.	Sumo Steel	1900.00	1	1	1.00	40.84	40.84
22.	Poddar Alloys	2300.00	5	5	1.00	43.83	15.30
23.	Uttaranchal Iron and Ispat1	1750.00	10	13	1.30	81.60	15.09
24.	Shreya Life Science	3000.00	5	6	1.20	18.64	15.08
25.	Jublient Organics	2500.00	4	7	1.75	20.96	15.73
26.	Sagar paper Mil	800.00	9	21	2.33	84.42	15.19
27.	Excel Engg.	52.80	36	163	4.53	61.33	15.08
28.	Platinum Pharmaceuticals	150.00	11	40	3.64	27.68	15.04
29.	Lotus Beauty Care Product	500.00	34	343	10.09	42.56	15.25
30.	Pine & Packaging	700.00	34	369	10.85	51.03	15.19
31.	Tiger Steel	600.00	34	198	5.82	49.20	15.60
32.	Automatic Products	31.68	41	153	3.73	94.70	15.78
33.	G.B.Equipment	52.80	25	217	8.68	60.23	15.34
34.	Beam Flash Lighting	200.00	18	46	2.56	55.20	15.60
35.	Rhydberg Pharmaceuticals	150.00	30	108	3.60	47.64	15.23
36.	Marico Ltd	125.00	39	415	10.64	65.38	16.78
37.	Sunshine Industries	3000.00	32	58	1.81	95.85	15.13
38.	Tribhuban Ispat	3000.00	5	5	1.00	58.08	15.98
39.	Manokamana Steel	3000.00	26	33	1.27	97.17	15.17
40.	P.S.B Ltd	2000.00	15	159	10.60	82.00	24.00
41.	Shri Balaji Industries	50.16	10	18	1.80	52.63	15.15
42.	Padmawati Pharma	150	23	190	8.26	44.00	15.20
43.	Siddhi Plast India, Haridwar	88	22	126	5.73	42.62	15.76
44.	Kishan Mechanical	52.80	34	139	4.09	27.27	15.91
45.	Rishi Chemicals	45.00	35	246	7.03	72.00	16.44
46.	Indian Rubber Product	125.00	37	167	4.51	58.24	15.36
47.	M.V Enterprises	3400.00	5	21	4.20	30.47	15.59
48.	Sundram Fastners	1500	36	370	10.28	43.91	16.34