Before

UTTARAKHAND ELECTRICITY REGULATORY COMMISSION

Misc. Appl. No. 72 of 2026

In the Matter of:

Petition under Sections 42, 43, 86(1)(k) and 94(2) of the Electricity Act, 2003 read with Regulations 8(2) and 8(3) of the UERC (The Electricity Supply Code, Release of New Connections and Related Matters) Regulations, 2020, and Regulations 61 and 62 of the UERC (Conduct of Business) Regulations, 2014, seeking relaxation of Regulation 2.1(4) read with Table 2.1 of the said Regulations, 2020, for the interim release of an additional load of 8 MW over the existing contracted load of 8 MW, i.e. a total load of 16 MW, on the existing 33 kV supply pending release of its applied load of 20 MW at 132 kV.

And

In the Matter of:

M/s Metro Decorative Private Limited,
Khasra No. 89, Bakeda Mahua Kheda Ganj Road,
Village Kataiya, Kashipur (Udham Singh Nagar),
Uttarakhand – 244713 **…Petitioner**

&

In the Matter of:

(1) Uttarakhand Power Corporation Ltd. (UPCL),
VCV Gabar Singh Urja Bhawan,
Kanwali Road, Dehradun

And

(2) Power Transmission Corporation of Uttarakhand Ltd.,
'Vidyut Bhawan', Near ISBT, Majra,
Dehradun **…Respondents**

Coram

Shri M. L. Prasad	**Chairman**
Shri Anurag Sharma	**Member (Law)**
Shri Prabhat Kishor Dimri	**Member (Technical)**

Date of Hearing: November 03, 2026
Date of Order: November 03, 2026

ORDER

Heard the Petitioner and the Respondents on admissibility of the Petition. Petition be admitted.

Further, during the course of hearing, the Commission allowed the Petitioner and Respondents to make their submissions on merits. Accordingly, the Petitioner and Respondents made their submissions before the Commission.

During the hearing, the Commission observed that the Petitioner in its Petition has used the notation MW and MVA interchangeably and accordingly, the Petitioner is directed

to furnish its clarification under affidavit before the Commission latest by **16.11.2026** with a copy to Respondents on following points: -

(1) Petitioner's request for load enhancement in MVA over & above the existing load in MVA on 33 kV existing network.

(2) Timeframe required for completion of 132 kV switchyard and its associated works at its end.

Further, Respondent No. 1 is directed to furnish its reply under affidavit on following points before the Commission latest by **25.11.2026**: -

(1) Details of last one year monthly maximum demand in MW & MVA and monthly average power factor for M/s Metro Decorative Pvt. Ltd.

(2) Details of the 33 kV feeder to M/s Metro Decorative Pvt. Ltd. viz. conductor type, maximum current carrying capacity in Amp.

(3) Suitability of the existing 33 kV feeder to cater the enhanced load requirement as requested by M/s Metro Decorative Pvt. Ltd.

(Prabhat Kishor Dimri)	**(Anurag Sharma)**	**(M. L. Prasad)**
Member (Technical)	**Member (Law)**	**Chairman**