

QUOTATIONS NOTICE

MAHARASHTRA JUDICIAL ACADEMY AND INDIAN MEDIATION CENTRE AND TRAINING INSTITUTE, UTTAN – GORAI ROAD, UTTAN BHAYANDER (WEST), THANE – 401 106.

The Maharashtra Judicial Academy and Indian Mediation Centre and Training Institute, Uttan-Gorai Road, Uttan District – Thane – 401 106, a registered Society under the Societies Registration Act, 1860 bearing registration No.MH/2295/10/Thane, (hereinafter referred as “the Academy”)- Tender for Purchasing following articles:-

Description of Line Interactive UPS : BP Series (Model : BP 1200):-

Sr. No.	Specification	Description Line Interactive UPS : BP Series (Model : BP 1200)	Make	Model	Qty.
01	INPUT	Voltage (VAC) : 120~300VAC Frequency (Hz) : 50 / 60Hz ± 10Hz Auto Sensing	BP Series	BP 1200	45
02	OUTPUT	Voltage AVR Mode : 200~245V Voltage Battery Mode : 230VAC ± 10% Frequency (Hz) on Battery : 50/60Hz ± 0.1Hz Waveform : Simulated Sine Wave Transfer Time (ms) : 4-8 ms Typical			
03	BATTERY	Voltage : 12V DC			
		Internal Battery : Standard : 2x12V/7AH			
		Type : Sealed Maintenance Free Lead Acid VRLA			
		Recharge Time : 6-8 Hours to 90% After Complete Discharge			
04	BACKUP CHART	No. of PC Support (Recommended) : 1 No.			
		On 1 PC Load Standard Model : 35-40 Min. (Depends on PC Configuration)			
05	SYSTEM FEATURES	Audible Alarms :- Low Battery, Overload, Short Circuit and Fault Conditions.			
		LED Display :- AC Mode : Green Lighting, Battery Backup Mode : Orange Lighting, Fault Mode : Red Lighting.			
		Protection :- Battery Low, Overload, Short Circuit, AC Input Low/ High & Fault conditions			
		Degree of Protection : IP 20			
		Cold Start : Yes			
		Type of Enclosure : ABS			
06	PHYSICAL	Dimensions (wxDxH) mm : 145x400x160 Net Weight Standard Model (Kg) : 6.5 Nos. of Power Outlet : 4 (1 Printer+3 Battery)			

07	STANDARD	Quality : ISO 9000, ISO 14001, OHSAS 18001, ISO 27001, BIS and RoHS.			
		Safety : IEC/EN62040-1			
		EMC / Performance : IEC/EN62040-2, IEC/EN62040-3, Complying to CE			
08	ENVIRONMENT	Temperature : Operating: 0~45°C, Storage: -10°C ~ 55°C			
		Humidity / Altitude : 0~95% RH Non-condensing / <1500 M			
		Noise : Low Audible Noise Level			
09	COMMUNICATION	Communication Port : RS-232 / USB (Optional) Monitoring Software : View Power/ UPSilon 2000 (Optional)			
10	WARRANTY	1 Year On Site BATTERY Warranty 2 Year On Site UPS Warranty	SI/Company/ Vendor /	----	----

Interested Vendor / Bidder are requested to submit the quotation in sealed envelope only.

GENERAL INSTRUCTIONS / TERMS & CONDITIONS

1. The sealed quotations must be addressed to **“The Joint Director, Maharashtra Judicial Academy and Indian Mediation Centre and Training Institute, Uttan-Gorai Road, Uttan District–Thane–401106.”** The envelope shall be super scribed with :- **“Quotation for Line Interactive UPS : BP Series (Model : BP 1200)”** and it must reach on or before 07/02/2026 up to 05.00 pm.
2. Sealed quotation Tenders received after due date and time will not be entertained.
3. Local vendor will be preferred, in view of immediate requirement.
4. Product must be delivered within 3 or 4 days of receipt of P O.
5. The Period of Guarantee / Warranty of product or article will commence from the date of receipt products / articles or date of Installation or date of acceptance of Contract by the Academy.
6. Declaration of Warranty Confirmation and Technical Compliance should be given by the bidder.
7. Any item which is different than the description given in tender shall not be accepted.
8. Escalation Matrix is required for Technical support or register any types of complaint and any complaint shall be attended within 24 / 48 hours.
9. The Academy reserved itself the right of accepting the whole or any part of the quotation or portion of the quotation.

Date:01/03/2026.


Joint Director - 1.3.26

Maharashtra Judicial Academy
Uttan.

**Maharashtra Judicial Academy &
Indian Mediation Centre & Training Institute
Uttan-Gorai Road, Bhayander (W), Dist. Thane**