10KVA UPS Specifications	
Parameters.	Minimum Specifications
Capacity	10 KVA
Battery Backup	2 Hours
Operating Temperature	0° – 40° C
Input	AC Single Phase
Voltage Range	160 V AC to 270 V AC
Output	
Voltage	230V AC ±1 %, single phase
Battery Details	
Battery Type	Sealed Maintenance Free
Battery Features	Requested brand, manufactured in India
Battery recharge time (after complete discharge to 90% charge) & charg	Battery recharge time to 90% charge after 100% DoD should be within 8-10 hours and charge should be capable to charge battery on C20 rating
Battery Capacity	12V 65AH –(16 Batteries)
L.C.D. meter	To measure and monitor input voltage, output Voltage, output load level in % DC Voltage, input /output frequency
Indications	Mains on, Load on Battery, Inverter Load level, Inverter over load.
Audible Alarm	Over Temperature, Mail failure, Battery, low, Inverter Overload
Static & Manual Bypass with single phase input / Single phase output	Shall be provided
Product Certification	ISO 9001-2000 certified and RohS compliant
Comprehensive	Three(3) Years Onsite Comprehensive Warranty

PRINICPAL DISTRICT JUDGE
KURNOOL