PRINCIPAL DISTRICT AND SESSIONS JUDGE:: KURNOOL

Dis.No. 6513 /e-Courts/2025 Date: 22.11.2025

TENDER NOTICE

Sub: UPS – Supply and Installation of 2 No.of 3 KVA UPS for use of e-Sewa Kendras in Kurnool District.

Ref: Letter of the Hon'ble High Court of A.P., in ROC.No.2423/2023-CPS,Datd:16.10.2025

** ** **

Quotations are invited from the Authorized agencies for supply and installation of 2 No.of 3 KVA UPS for use of e-Sewa Kendras in Kurnool District. The intending authorized agencies should submit their quotations in a closed and sealed cover in the Office of the Prl.District and Sessions Judge,Kurnool on or before 2.12.2025 during the Office hours on all working days from 10.30 A.M to 5.00 P.M.

The Prl.District and Sessions Judge,Kurnool reserves the right to accept or reject any or all the quotations without assigning any reasons.

PRINCIPAL DISTRICT JUDGE
KURNOOL

TO
1.Notice Board of the Prl.District Court,Kurnool.
2.The District Collector Kurnool with a request to affix the same in the Notice Board for vide publicity.
3.Notice for uploading in the District court Website,Kurnool.

3 KVA UPS Specifications	
Parameters	Minimum Specifications
Capacity	3KVA
Battery Backup	2 Hours
Operating Temperature	0-40 C
Input:	AC Single Phase
Voltage Range	160 V AC to 270 V AC
Output:	
Voltage	230 V AC 1%, Single Phase
Battery Details	
Battery Type	Sealed Mainenance Free
Battery Feature	Requested brand, manufactured in India
Battery recharge time (after complete discharge to 90% charge	Battery recharge time to 90% charge after 100%DoD should be withn 8 -10 hours and charge should be capable to charge battery on C20 rating
Battery Capacity	12V 100 AH –(6 Batteries)
L.C.D.Meter	To measure and monitor input voltage,output voltage,output load level in %DC Voltage,input/output frequency
Indications	Mains on, load on Battery, Inverter Load level, Inverter overload
Audible Alarm	Over temperature, main failure, Battery low, Inverter overload
Static and Manual Bypass with single phase input/Single phase output	Shall be provided
Comprehensive	Three Years onsite comprehensive warranty

PRINCIPAL DISTRICT JUDG
KURNOOL