

**DISTRICT COURT, PALAKKAD**  
**Website: [www.ecourts.gov.in/kerala/palakkad](http://www.ecourts.gov.in/kerala/palakkad)**  
**Email: [dcourtpkd.ker@nic.in](mailto:dcourtpkd.ker@nic.in)**  
**Ph: 0491-2505272**

No. ECC-09/2021

Dated: 13-09-2021

**QUOTATION NOTICE**

Sealed Quotations are invited from Reputed/Authorized dealers for the supply of 20 no. s of 600VA LINE INTERACTIVE UPS to be installed at various Court Centers in the Judicial District of Palakkad.

The Quotations must show the lowest price with the following specifications.

The Details are as follows:

Item: 600VA LINE INTERACTIVE UPS FOR COMPUTERS

1	Capacity	600 VA LINE INTERACTIVE
2	Input Voltage & Frequency	140-270 V, 47 to 53 Hz.
3	Output Voltage & Frequency (On Mains)	220+/-8% with AVR (Automatic Voltage Regulation), 50 Hz+/-synchronized with Input Power Frequency
4	Output Voltage & Frequency (On Battery)	230 V+/- 3% with 50 Hz.
5	Backup Time	30 minutes on full load of 0.6 PF
6	Battery Type	Maintenance-free sealed Lead-Acid Battery with suspended electrolyte: leak proof. Batteries should be inbuilt in the UPS Cabinet.
7	Overload Capacity	110% for two minutes (On both Mains & Battery)
8	Efficiency	75% or more on Full Load
9	Output Wave Type	Quasi Sine Wave or Better
10	Transfer Time	<= 5 milliseconds
11	Load Power Factor	0.6 leading to unity
12	Other Features	Cold Start, Auto Start, Generator Compatible
13	Protection From	Surge, Short Circuit, Spikes, DC Undervoltage and Overload, Low Battery
14	Indicators	Mains On, Battery Charge, Overload
15	Alarms	Low Battery, Mains Off, Tripping
16	Operating Environment	0 – 40 Degree Celsius
17	Operating Relative Humidity	0 – 95%

18	Audible Noise at 1 meter from the surface of unit	Not more than 50.00 dB
19	Output Sockets	3 or more with 3 pins
20	OEM	Authorized Dealer
21	Warranty	5 years onsite warranty on UPS & 2 years on batteries

**The Acceptance:**

1. Quotations should reach this Office on or before 24-09-2021 at 3 PM and will be opened on 27-09-2021 at 3.30 PM.
2. Intending Quotationers may submit their quotations in their own letter head with copies of other required documents indicated in the Quotation document.
3. The Quotations should clearly show the Brand Name of the UPS, Battery, Specification, Price, Warranty Period etc.
4. The quotations should be addressed to the District Judge, Palakkad, in a sealed cover with the quotation number and name of item duly superscribed on the cover.
5. No quotation received after the specified date and time will be accepted on any account.
6. The quotation should contain the Annual Maintenance Contract rate after the expiry of warranty.
7. The maximum discount, that can be offered is to be noted separately.
8. The prices quoted should be inclusive of all taxes, duties, cesses etc.

By Order

Sheristadar

(Seal)

To,

The Notice Board, District Court, Palakkad.

The Website, District Court, Palakkad.

**List of Court Centers & the Quantity of item to be delivered**

Sl. No.	Name of Court Center	Qty of 600VA UPS
1	District Court, Palakkad	4
2	Sub Court, Palakkad	1
3	Munsiff's Court, Palakkad	1
4	Chief Judicial Magistrate Court, Palakkad	1
5	MACT, Palakkad	1
6	Family Court Palakkad	1
7	Addl. District and Sessions Court/MACT, Ottappalam	1
8	Sub Court, Ottappalam	1
9	Munsiff's Court, Ottapalam	1
10	JFCM, Ottapalam	1
11	Family Court, Ottapalam	1
12	Munsiff Magistrate's Court, Pattambi	1
13	JFCM Court, Pattambi	1
14	Munsiff's Court, Alathur	1
15	JFCM, Alathur	1
16	Munsiff's Court, Chittur	1
17	JFCM, Chittur	1

District Court  
Palakkad.