



**SWAMI VIVEKANAND NATIONAL INSTITUTE OF
REHABILITATION TRAINING AND RESEARCH**

(Ministry of Social Justice & Empowerment,
Department of Empowerment of Persons with Disabilities, Govt. of India)
OLATPUR, P.O: BAIROI, DIST: CUTTACK (ODISHA) Pin: 754010.
Tel. No: 0671-2805552, 2805 778, FAX: 0671 2805862.
Website: www.svnirtar.nic.in, E-mail: nirtar@nic.in & svnirtar@gmail.com

Tender No- AD7B21

Date: 15.05.2025

CORRIGENDUM

With reference to Tender Notice vide No. AD7B21 dated: 09.05.2025 for “Supplying and installation of Electrical panels including MCCB, busbar, DMC insulator etc. at Academic building & Rehab Services building of the Institute”, the description of items at sl.no. 1 & 2 of BOQ at Annexure-A may read as follows.

Item no. of BOQ	Description as mentioned in the BOQ at Annexure-A	To be read as
1	Electrical Panel Room (1 st floor mounting with Stand): I/C-400A 36KA TP MCCB-01 no. Extended Room-01 no. Spreader Links-01 no. Suitable Aluminum Busbar DMC insulator, Indicating Lamps with protecting fause-03 nos. O/G-100A 18KA TP MCCB-01 no. With complete wiring body-1.6 CRCA SHEET, colour powder coated including Stand, Freight, labour Commissioning, Erection, Testing etc.	P/F Floor/wall Mounted Cubical type Panel fabricated by CPRI approve panel manufacturer on the existing wall/floor made out of 14 swg MS sheet with detachable gland plate and suitable for fixing the following switchgears, accessories i/c supplying the same, making interconnection with suitable size Al/Cu flat cable with lugs, painting with powder coated paint (7 tank process) of even shade ,i/c sign writting ,earthing the body etc as required. Incomer: a. 400 amp 4 pole MCCB, 35 KA(ICU=ICS 100%) - 1 no Make- LK,Hager,Schneider,SS make Outgoing: a. 100 amp 4 pole MCCB,25 KA (ICU=ICS 100%)- 12 nos (Make- LK,Hager,Schneider,SS make) b.400 amp Al. 4 strip Busbar with heat shrinkable tube & post insulator with acralic sheet cover with all required accessories - 1set c. VAF meter - 1set d.Rorary handle as per requirement e. C.T 100/5 amps (Kappa make)- 3 nos f. Neon Indication Lamp (LED type)-3 nos g. 100 amp stud terminal as per requirement h-Danger plate - 1 no
2	Electrical Panel Room (Wall mounting type): I/C-400A 36KA TP MCCB-01 no. Extended Room-01 no. Spreader Links-01 no. Suitable Aluminum Busbar DMC insulator, Indicating Lamps with protecting fause-03 nos. O/G-100A 18KA TP MCCB-01 no. With complete wiring body-1.6 CRCA SHEET, colour powder coated including Stand, Freight, labour Commissioning, Erection, Testing etc.	SITC of 400 amp 35 ka MCCB with enclosure duly fixed on MS angle frame i/c connection of existing cable as per direction of engineer -in- charge etc as required.

Further, the last date of submission and opening of tender shall be read as 19.05.2025.
All the remaining conditions of earlier NIT will remain the same.

Sd/-
Asst. Engineer, Civil
Construction & Maintenance Division