

Telephone: 0891-281-5622/5624

Material Organisation
Eastern Naval Command
Kancharapalem: Post
Visakhapatnam – 530 008


Fire/310/KV-I dated 09 Jul 26

The Principal
PM Shri Kendriya Vidyalaya No 1
Sri Vijay Nagar
Visakhapatnam – 530 007

**CERTIFICATE OF INSPECTION AND SERVICEABILITY
FOR FIRST AID FIRE FIGHTING EXTINGUISHERS**

1. This is to certify that all first aid fire fighting extinguishers provided by MO(V) are in full compliance with relevant safety standards and manufacturer guidelines. The equipments are properly charged, standard pressure-tested and ready for use.
2. The following first aid firefighting equipments are being maintained and provided by this unit: -

S.No	Description	Qty
2.1	Fire Point Stands	05 No's
2.2	9 Ltr AFFF Extinguisher	10 No's
2.3	2 Kg CO ₂ Extinguisher	05 No's
2.4	10 Kg DCP Extinguisher	05 No's
2.5	Fire Bucket (Sand)	10 No's


(Vivek Gupta)
Lt Commander
Fire Fighting Officer