



OMEGA TEST HOUSE PVT. LTD.

An ISO Certified, FSSAI, MoEF & NABL Accredited Laboratory

Lab: J-889, Sitapura Industrial Area, Jaipur (Raj)-302022

Head Office: 2/60, Malviya Nagar, Jaipur (Raj.)-302017

Contact: 09414074020, 09829051363, 0141-2521969, Email: omegatesthouse@gmail.com



NABL SCOPE

TC-15122

Format No:- OTHPL/QC/RF/25

TEST REPORT

Sample Name	Drinking Water	Sample Code	26090010
Report No.	OTHPL/RN-202610106	Report Issue date	07/09/2026
ULR No.	TC151222600009425F	Page No.	01 OF 01
Reference to Sampling	SOP No.-OTHPL/QCO1008	Sample Collected By	Lab Representative

Customer Name & Address:		Sample Receiving Date:	01/09/2026
Kendriya Vidhalya No.1, Bajaj Nagar, Jaipur.		Date of Testing	02/09/2026
		Date of Completion	07/09/2026
		Sample Qty. & Condition	1 Ltr. & Ok
Environmental Conditions Under which test performed	Room Temperature	Registration No.	RAJ.1713/012971

Appearance: - Clear Colorless Liquid.

CHEMICAL ANALYSIS

S. No.	Parameters	Results	Test Method	Units	Limits IS : 10500/2012 Desirable Limit/ Rejection Limit
1.	Odour	Agreeable	IS : 3025 (P-5)	NA	Agreeable
2.	Turbidity	Nil	IS : 3025 (P-10)	NTU	1 Max./5 Max
3.	pH	7.29	IS : 3025 (P-11)	NA	6.5 to 8.5
4.	Total Dissolved Solids,	175	IS : 3025 (P-16)	mg/l.	500 Max. / 2000 Max.
5.	Total Hardness as CaCO ₃	99.09	IS : 3025 (P-21)	mg/l.	200 Max./ 600 Max.
6.	Calcium Hardness as Ca	20.63	IS : 3025 (P-40)	mg/l.	75 Max./ 200 Max.
7.	Magnesium Hardness as Mg	11.55	IS : 3025 (P-46)	mg/l.	30 Max./100 Max.
8.	Chloride as Cl,	20.90	IS : 3025 (P-32)	mg/l.	250 Max./ 1000 Max.
9.	Alkalinity to (P) as CaCO ₃	Nil	IS : 3025 (P-23)	mg/l.	-----
10.	Alkalinity to (M) as CaCO ₃	61.20	IS : 3025 (P-23)	mg/l.	200 Max./ 600 Max.
11.	Nitrate as NO ₃	22.89	IS : 3025 (P-34)	mg/l.	45 Max./No relaxation
12.	Sulphate as SO ₄	9.02	IS : 3025 (P-24)	mg/l.	200 Max./ 400 Max.
13.	Iron as Fe	BDL(<0.01)	IS : 3025 (P-53)	mg/l.	0.3 Max./ No relaxation
14.	Fluoride as F ⁻	BDL (<0.05)	IS : 3025 (P-60)	mg/l.	1.0 Max./ 1.5 Max.
15.	Sodium as Na	16.20	IS : 3025 (P-45)	mg/l.	150 Max

MICROBIOLOGICAL ANALYSIS

1.	E.coli/ 100ml	Absent/100 ml	IS : 15185-2016	Present or Absent/100 ml	Shall not be detectable In any 100 ml sample
2.	Coliform/ 100 ml	Absent/100 ml	IS : 15185-2016	Present or Absent/100 ml	Shall not be detectable In any 100 ml sample

Note: - 1. BDL- Below Detection Limit, NA- Not Applicable

2. The above parameters are analyzed as per IS: 3025 & Complies the IS 10500:2012 specification for drinking water.

3. The results relate only to items tested.

4. The information about the sample provided by customer.

END OF REPORT



Note:

- (1.) The result listed refer only to the tested samples and applicable parameters. Endorsement of this report is neither inferred nor implied
- (2.) Total Liability of our concern is limited to the invoiced amount.
- (3.) The report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing

PM SHRI KENDRIYA VIDYALAYA No. 1
Bajaj Nagar, Jaipur, Rajasthan-302015

ANNEXURE C / APPENDIX-XII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Date: - 17.09.2026

It is certified that an inspection team headed by Jn. Chemist (Name of Officers with designation) from Jaipur (Department/Office) inspected the **PM Shri Kendriya Vidyalaya No.1 Bajaj Nagar, Jaipur, Rajasthan-302015** (Name & Address of School) on 02.09.2026 (Date of Inspection) and on the basis of Water Test Report (Attached) bearing No.-OTHPL/RN-202610106 Dated-07.09.2026 from Omega Test House Pvt. Ltd., Jaipur, certified that the **PM Shri Kendriya Vidyalaya No.1 Bajaj Nagar, Jaipur, Rajasthan-302015**(Name of School) has safe drinking water facilities for the students and members of staff of the institution.


The school is also maintaining the hygienic sanitation condition in the school campus and the classrooms as per norms prescribed by the Central/State/U.T. Government.

This certificate is valid till: - **One Year**

Signature with Seal: _____

Name: D. S meena

Designation: PHT (Chemist)



To,

Name & Address of Office/Department:

PM Shri Kendriya Vidyalaya No.1 Bajaj Nagar, Jaipur, Rajasthan-302015

h
PRINCIPAL
PM SHRI KENDRIYA VIDYALAYA No. 1
Bajaj Nagar, Jaipur, Rajasthan-302015