All Field Laboratory

222, Akar Complex, Opp. Narol BRTS Stop, Narol Circle, Narol, A'bad.

TEST REPORT

Source of Sample: Aab Technologies, A'bad.
M. - 98257 80564.
Name of Sample : Water.
Party Reference : The Principal,
PM SHRI KV NO.- 1, Shahibaug, A'bad.
- Bore Water.
Sample Drawn By : Party.
Date of Receipt : 31.10.2026.
Date of Result : 03.11.2026.

Parameters	Results	Desirable Limits as per IS:10500	Permissible Limits as per IS:10500	Units
pH	8.10	6.5 - 8.5	6.5 - 8.5	-
Alkalinity of. M.O.	370	200	600	mg/l
Alkalinity of Pheno.	nil			mg/l
Chloride	192	250	1000	mg/l
Sulphate	54	200	400	mg/l
TDS	780	500	2000	mg/l
Total Hardness	161	200	600	mg/l
Temporary Hardness	161	-	-	mg/l
Permanent Hardness	nil	-	-	mg/l
Ca Hardness	98	-	-	mg/l
Mg Hardness	63	-	-	mg/l
BDL. = Below Detection Limit.				
——— End of the Report. ———				

This report is issued under the following terms and condition.

1. Content of this report are meant for your guidance and for internal use only.
2. Sample drawn and submitted by the party for analysis unless otherwise stated.
3. This report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law.
4. The report or part thereof must not be used for any legal matter.
5. All Field Laboratory maintains strict confidentiality of all the analysis and test results and customer supplied product and will not reveal this information to third party.
6. Subject to Ahmedabad Jurisdiction only.
7. The test sample(s) will be disposed off immediately after testing unless written request is given prior to testing.
8. Total liability of our institution is limited to the invoice amount/testing charges only.
9. Customer requested for the above test only.

ALL FIELD LABORATORY

Test Carried by :
Yashbhai.

For, All Field Laboratory :
P. I. Patel.