

Ref No.

CERTIFICATE

Date 23-08-2023

TO,

The Principal,
Kendriya Vidyalaya,
Pulgaon Camp,
Dist:- Wardha,
Maharashtra.

**This is To certify That We Have Carried Out Maintanance,
Servicing, Repairing, Refilling and Hydrolyic testing Of
Fire Extinguisher Of..**

1 DCP Type Cap 05 Kg Fire Ext. 08 Nos

This Fire Extiguishers Refilled on **23/08/2023** and the Due Date Of Refilling is **22/08/2025**

2 M/Foam Type Cap 09 Ltr Fire Ext. 01 Nos

This Fire Extiguishers Refilled on **23/08/2023** and the Due Date Of Refilling is **22/08/2025**.

3 CO2 Type Cap 02 Kg Fire Ext. 01 Nos

This Fire Extiguishers Refilled on **23/08/2023** and the Due Date Of Refilling is **22/08/2028**.

From,

MILITRON SERVICES & CONSULTANCY.



MILITRON SERVICES & CONSULTANCY

Add- Vijay Talkies Opp. Sarswati Bhawan, 2nd Floor, Ghat Road, Nagpur-18

Mob.: +91-9881055690, +91-9881512786

E-mail:militronservices11c@gmail.com