

**GOVERNMENT OF TELANGANA.
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT.**

From
S. Sandhanna,
District Fire Officer,
Adilabad.

To
The District Education Officer,
Adilabad.

Re.No.1090/A1/2015, dated: 23-09-2015



Sir,

Sub:- Telangana State Disaster Response and Fire Service Department –Central region – Adilabad District – Issuance of Renewal of “NO OBJECTION CERTIFICATE” for occupancy to the existing educational building of Kendriya Vidhya School, Dasnapur, Adilabad District - Regarding.

- Ref:-
- 1) Application of Correspondent, Kendriya Vidhya School , Dasnapur, Adilabad District on 04-08-2015.
 - 2) Section 13(2) of A.P. Fire Services Act, 1999 and Rule 15(2) of A.P. Fire and Emergency Operations and Levy of Fee Rule, 2006.
 - 3) Chief Office Memo. Rc.No. Instructions of 2305/B2/2007, dated: 28-02-2007 & dt. 12-09-2008.
 - 4) Inspection Report of the I/C Station Fire Officer, Adilabad on 23-09-2015

Vide reference 1st cited, the Correspondent, of Kendriya Vidhya School, Dasnapur, Adilabad district. Previously the management was obtained NOC for ground floor and first floor only vide reference 5th cited, after that second floor developed, and fire prevention fee and lapses penal interest also remitted, now applied for the renewal of license from this department, and requested to issue the certificate for the Renewal of No objection certificate for occupancy in terms of G.O. reference 2nd cited for the Kendriya Vidhya School, Dasnapur, Adilabad district.

Vide reference 4th cited, the inspection committee has inspected the building on 23-09-2015 and recommended for the issue of Renewal of “NO OBJECTION CERTIFICATE” for occupancy.

1}. i) Particulars of the Building :

I	Address of the Building	Kendriya Vidhya School, Dasnapur, Adilabad district
II	Height of the building	03.00 meters.
III	No. of blocks	One Block.
V	No. of Floors	Ground floor

ii) Open spaces

Direction	Required as per NBC	Provided	Deficit
North	06.00 mtrs	06.00 mtrs	Nil
East	06.00 mtrs	06.00 mtrs	Nil
South	06.00 mtrs	06.00 mtrs	Nil
West	06.00 mtrs	06.00 mtrs	Nil

2} Floor wise Particulars :-

Sl. No.	Floor	Floor area in Sq. meters	Type of Occupancy
1	Ground floor	236.94 Sq.Mtrs	Educational

The Management has remitted fire precaution fee Rs.2400/- (Rupees Two thousand four hundred only) vide Challan No.15382 Dt:-24-09-2015 at S.B.H Br. Adilabad.

(Contd..2)

3) Means of Escape (a):

Sl. No.	Details of Staircases	Provided		Location of the Staircases
		No's	Width in Mtrs	
1	Internal No.	01	-	-
2	External .. No.	01	-	--
			-	

(b) stair cases :

Highest No. of Students in a floor	Width of Stair cases required (No. of students divided by 50 Meters)	Aggregate width of Staircases provided	Deficit
			-

4) Fire Safety Measures:


Sl. No.	Fire Safety Measures	Required as per Table 23 of NBC of India, 2005	Provided	Deficiency
1	Fire Extinguishers& Buckets	04+4 Nos	04 +04 Nos	Nil
2	Hose Reel	-	-	Nil
3	Automatic Sprinkler system in basement if area of basement exceeds 200 Sq. meters	N.A	N.A	Nil
4	Terrace Tank	10,000 Ltrs	15,000 Ltrs	Nil
5	Down comer with landing valve	01 No	01 No	Nil
6	Manual calling points	03 No's	03 No's	Nil

5) The existing building of Kendriya Vidhya School, Dasnapur, Adilabad district has provided the Fire safety measures prescribed in Part 4, NBC-2005, G.O.Ms.No.154, M.A. & U.D Dept., dated 13-03-2007 and Memo. No. 4011/M1/2008, M.A. & U.D Dept., dt.19-05-2008.

6) The Fire safety systems were tested by the committee members during the inspection and performance found satisfactory. Therefore, this office has No Objection for Occupancy Clearance to the existing Educational Building of Kendriya Vidhya School, Dasnapur, Adilabad district subject to the following conditions.

7) This renewal of occupancy clearance is valid for a period of one year from the date of issue. The Management should apply for renewal certificate before 2 months expiry of above validity period.

Yours faithfully,


District Fire Officer,
Adilabad. 23/01/15

Copy to the I/C Station Fire Officer, Adilabad.

Copy to the Kendriya Vidhya School, Dasnapur, Adilabad district