

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 01

Dated: 13/04/2026

It is certified that an inspection team headed by Assistant Chemist (D. Chandrashekhar)

(Name of Officers with designation) from Assistant Chemist mission Bhagirathi  
Laboratory (Adilabad) PHED

inspected the KENDRIYA VIDYALAYA, BHAGMAT SINGH NAGAR ADILABAD

(Name & Address of the school) on 13/04/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 01 dated 13/04/26

of water quality monitoring lab Mission Bhagirathi  
(PHED Lab) certified that

the KENDRIYA VIDYALAYA ADILABAD (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6 Months

Signature with Seal: Shekhar Asst. Chemist  
Name: Mission Bhagirathi Intra Lab  
Designation: PHED ADILABAD  
Name & Address of the Office / Department: D. Chandrashekhar  
Asst. Chemist  
Mission Bhagirathi

To  
PRINCIPAL KV  
ADILABAD  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


GOVERNMENT OF TELANGANA  
WATER QUALITY MONITORING LABORATORY MISSION BHAGIRATHA ADILABAD  
REPORT ON CHEMICAL ANALYSIS OF DRINKING WATER

Name & Address of Sender : Shashikanth (KV ADILABAD) Mandal : Adilabad  
 Sample Collected by : Shashikanth Habitation : Adilabad  
 Date of Collected :13.04.2026  
 Date of Received :13.04.2026

Sl.No	Test				Source	PH Value	Total Dissolved Solids	Alkalinity (Methyl Orange)	Total Hardness	Chloride	Fluoride	Nitrate as NO <sub>3</sub>	Sulphate	Calcium	Iron	Remarks
	ACCEPTABLE LIMIT					6.5 to 8.5	500 (Mg/Lt)	200 (Mg/Lt)	300 (Mg/Lt)	250 (Mg/Lt)	1 (Mg/Lt)	45 (Mg/Lt)	200 (Mg/Lt)	75 (Mg/Lt)	0.3 (Mg/Lt)	
	PERMISSABLE LIMIT IN THE ABSENCE OF ALTERNATE SOURCE					No relaxation	2000 (Mg/Lt)	600 (Mg/Lt)	600 (Mg/Lt)	1000 (Mg/Lt)	1.5 (Mg/Lt)	No relaxation	400 (Mg/Lt)	200 (Mg/Lt)	1 (Mg/Lt)	
	Mandal	Gramapanchayat	village/ habitation	Code/Loction												
1	Adilabad	Adilabad	Adilabad	KGBV School Adilabad	R/o	7.48	101	40	36	16	0.17	3	12	20	0.00	

Note:Standards as per Burea of Indian Standards I.S.10500:2012

Remark:Water is potable. Fit For Drinking

  
Asst Chemist  
MB Intra Adilabad