Folio No

सेनादूरभाष

: 2309

Mil Tele फैक्सनं.

: 2309

Fax No

: 03712-295535

ई-मेल

: 03712-295535

e-Mail

: getezpur.north@gov.in

: getezpur.north@gov.in

Garrison Engineer (N) Tezpur

दुर्गअभियन्ता (उत्तरी) तेजपुर

पिन-901217

PIN-901217

मार्फत 99 सेनाडाककार्यालय

c/o 99 APO

2082/KV Tezpur/ 69 /E2

Mar 2024

The Principal Kendriya Vidyalaya No-01, Tezpur

REQUEST FOR THE ISSUE OF BUILDING SAFETY CERTIFICATE IN RESPECT OF KV NO 1

Dear Sir/ Madam,

- Ref your letter No 20/1498/112/KVT/2023-24/ dt 22 Mar 2024. 1.
- It is to inform that joint inspection has been carried out to the bldgs of KV School on 26 Mar 2024 and the feedback report are enumerated as follows:-
 - Part A Bldg (Main bldg) No visible structural cracks observed in the RCC Sections, concrete spalling taken place in one slab projection on GF. Construction joint crack/ Non structural cracks observed in the wall of the end of the corridor of the bldg. Generally the bldg is found to be safe.
 - Part C bldg (To be demolished). Reinforcement corroded, concrete sapling has taken place, in some columns, buckling has occurred, truss supported over the columns could not be inspected. The bldg is unsafe for occupation due to the failure of columns.
 - Part D bldg (To be demolished). Reinforcement corroded, concrete (c) spalling has taken place over the Slab. Initial failure has occurred in the Slabs. The bldg is unsafe for occupation.
 - Corridor connecting Part D bldg (To be demolished) & Part B bldg (Already demolished). Reinforcement corroded at the edges of the slab projection concrete spalling has occurred. No cracks observed in the Centre of the Slab
- This has regards to the water testing report it is to inform that water to KV 3. overhead tank is being supplied by pumphouse No 8, copy of the test report is enclosed herewith.

4. As the bldgs of KV are not being maintained by MES, sanitation certificate could not be provided as such from this office.

(एम विद्ययासारथी आई.डी.एस.ई)

(M Vidhyasarathy, IDSE) ई.ई. /EE

दुर्ग अभियन्ता

Garrison Engineer

Encls: (As above)