

Tele: 0891-2814018

Station Health Organisation  
Gandhigram PO  
Visakhapatnam- 530005

SHO/227/41 dt. 13 Oct 25

The Principal  
Kendriya Vidyalaya No.2  
Nausena Baugh  
Visakhapatnam- 530005

**SAFE DRINKING WATER & SANITARY CONDITION  
KENDRIYA VIDYALAYA NO.2, VISAKHAPATNAM**

1. Refer to your letter no. KV-2 (NSB) dated 18 Sep 25.
2. Certificates pertaining to safe drinking water and sanitary condition as sought by the school vide letter ibid are enclosed herewith.

*Jyoti Arya*

(Jyoti Arya)  
Major (AMC)  
Officer-in-Charge

**Encl:** - As above

**Copy to: -**

The Flag Officer Commanding-in-Chief  
{for Senior Staff Officer (Health)}  
Headquarters, Eastern Naval Command  
Visakhapatnam – 530 014

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. SHO/227/41

Dated: 13 Oct 25

It is certified that an inspection team headed by Major Jyoti Arya, MBBS, MD. (Community Medicine), Officer-in-Charge (Name of Officers with designation) from Station Health Organisation (Visakhapatnam) (Name of Department/ Office) inspected the Kendriya Vidyalaya No.2, Nausena Baugh, Visakhapatnam (Name & Address of the school) on 13 Oct 25 (date of inspection) and found that the Kendriya Vidyalaya No.2, Nausena Baugh (Name of school) has safe drinking water facilities for the students and member of staff of the institution and is maintaining the hygiene sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T Govt.

The above is valid for a period of: As on date

Signature with Seal :   
Name : Jyoti Arya  
Designation : Officer-in-Charge  
Name & Address of  
the Office / Department : .....

To  
The Flag Officer Commanding-in-Chief  
{for Senior Staff Officer (Education)-1}  
Headquarters, Eastern Naval Command  
Visakhapatnam - 530014

The Head Master  
Kendriya Vidyalaya No.2  
Nausena Baugh  
Visakhapatnam- 530005

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

O/o the Fire Prevention Wing,  
Greater Visakhapatnam  
Municipal Corporation,  
Visakhapatnam.

Rc.No.273/RFO/FPW/GVMC/2024

Dt:16/07/2024

**ENDORSEMENT**

Sub: GVMC – T.P. - Fire Prevention Wing - M/s.PM SHRI Kendriya Vidyalaya No.2, Nausenabagh, Visakhapatnam – Applied for Fire No Objection Certificate for Occupancy - Fire Protection system - Not installed – Endorsement - Issued - Reg.

Ref: Application Dt.15-07-2024 of M/s.PM SHRI Kendriya Vidyalaya No.2, Nausenabagh, Visakhapatnam for Fire No Objection Certificate for Occupancy.

\* \* \*

With reference to your application for Fire No Objection Certificate for Occupancy to the existing building of M/s.PM SHRI Kendriya Vidyalaya No.2, Nausenabagh, Visakhapatnam cited above, it is to inform that, during the inspection it is noticed that the Fire Fighting Equipment, is not installed which is required as per Table-7, Part-IV of National Building Code of India-2016 as follows:

1. Fire Extinguishers as per IS 2190 @ 01 No. for every 100 Sq.Mtrs built up area
2. Hose Reels @ 01 No. for each floor @ 1000 Sq.Mtrs built up area
3. Terrace water storage tank @ 10,000 ltrs.
4. Booster pump at terrace tank @ 450 LPM

Therefore, it is requested to provide the above said fire safety equipment and re-submit application for issuance of Fire No Objection Certificate for Occupancy from this office.

Y HANUMANTHA RAO, RFO(YHR)-RFO(TP)-GVMC, O/o REGIONAL FIRE OFFICER-TOWN PLANNING-GVMC

Regional Fire Officer

To,  
The Management,  
M/s.PM SHRI Kendriya Vidyalaya No.2, Nausenabagh, Visakhapatnam.



## ACTION TAKEN REPORT

To,  
The Principal,  
Kendriya Vidyalaya No. 2,  
Nausenabaugh

Date: 9th September 2025

Subject: Action Taken Report regarding Fire Safety Infrastructure and forthcoming inspection.

Ref: 1. Your Office Letter No: 2000/Year/2019/E3 Draft of 07/May/2025  
2. This Office Letter No: 30/2025-Sb/ Knowledge Management (ICD)

Sir,

With reference to the subject cited above, the following action has been taken and information is submitted for your kind perusal:

**Verification of Fire Safety Equipment:** The fire safety infrastructure has been verified as per the relevant version of the Fire Safety Infrastructure (RXI 10.7/2024). It is confirmed that we have 19 functional fire extinguishers on site, which are periodically inspected and maintained.

**Review of Layout Plans:** The existing layout and site plans for the Vidyalaya building (Ground Floor, First Floor, and Second Floor) have been thoroughly reviewed and are kept on record for reference during the safety audit.

**Upcoming Joint Inspection:** In compliance with the directives and to ensure full adherence to safety standards, a comprehensive joint inspection of the school's fire safety systems has been scheduled. This inspection will be conducted by a team comprising officials from the Fire Department and Military Engineer Services (MES).

**Provision of Fire Safety Certificate (RIC):** The aforementioned inspection team from the Fire Department and MES will conduct the audit and, upon satisfactory compliance, will provide the requisite Fire Safety Certificate (RIC) for the institution.

This is submitted for your kind information and further necessary action.

Thanking you,

Yours faithfully,

Boby Abraham  
TGT & AE (Fire Safety Incharge)  
Kendriya Vidyalaya No. 2,  
Nausenabaugh.



Office Received

9/10/2025



पी.एम.श्री. केन्द्रीय विद्यालय क्रमांक 2 नौसेनाबाग  
विशाखापत्तनम  
(शिक्षा मंत्रालय, स्कूल शिक्षा और साक्षरता विभाग, भारत सरकार)  
PMSHRI KENDRIYA VIDYALAYA No. 2 Nausenabaugh  
Visakhapatnam



🌐 : [https:// no2nausenabagh.kvs.ac.in](https://no2nausenabagh.kvs.ac.in)  
✉ : [kv2nausenabaugh@gmail.com](mailto:kv2nausenabaugh@gmail.com)

☎ : 0891-2958321  
☎ : 0891-2940354

SCHOOL CBSE No. : 59320

SCHOOL CODE:1537

CBSE AFFILIATION NO. : 100034

Ref. No. 30/2025-26/KV2NAUSENABAUGH/ 1696

Date: 16/09/2025

Gentle Reminder

To,  
The Garrison Engineer (U-II)  
Military Engineer Services  
104 Area, Industrial Estate Post  
Visakhapatnam- 530007.

Subject: Technical estimation for the installation of Fire Safety infrastructure in KV No 2 Nausenabaugh, Visakhapatnam - reg

Ref No. 2000/Gen/138/E2 Dated 05/May/2025

Sir,

With reference to the above cited subject that this vidyalaya has already sent the required information through letter no 30/2025-26/KV2NAUSENABAUGH/1644 Dt. 03-06-2025, it is once again requested with this letter and hereby forwarding the required information as follows:

a) The statement of case for fire safety infrastructure in detail of all requirement as per the Endorsement vide RC No. 273/RFO/FPW/GVMC/2024 DT 16.07.2024 fire safety unity of GVMC, VSKP -

1. As per 1S 2190@01 No for every 100 sq. mtrs. built up area, we have 19 nos of fire extinguishers for 4162 sq. Mtrs of building type is B', we need 23 more.
2. Hose Reels @ 01 pc. for each floor @1000 sq. mtrs. built up area, we need Hose Reels for 4,162 sq. mtrs. Area, 04 pc.
3. Terrace water storage tank @ 10,000 ltrs, we have 10,000 ltrs capacity terrace water storage tank already available.
4. We need 1 Booster pump at terrace tank @ 450 LMP.

b) Layout/ Site plan of existing Vidyalaya's building for ground floor, first floor and second floor was attached herewith.

c) Total strength of students= approx. 1300 and staff=62.

This is submitted for your kind information and waiting for your prompt action please.

Yours faithfully

(Sudhir Kumar Maingi)  
Principal Additional Incharge

Copy to:-

1-The Chairman, VMC, KV No. 2 Nausenabaugh, Visakhapatnam for information pls.