



पी.एम.श्री. केन्द्रीय विद्यालय क्रमांक 2 नौसेनाबाग विशाखापत्तनम
शिक्षा मंत्रालय, स्कूल शिक्षा और साक्षरता विभाग, भारत सरकार
PMSHRI KENDRIYA VIDYALAYA No. 2 Nausenabaugh
Visakhapatnam
(Ministry of Education, Deptt. of School Education & Literacy, Govt. of India)



Website : [https:// no2nausenabagh.kvs.ac.in](https://no2nausenabagh.kvs.ac.in)
Email : kv2nausenabagh@gmail.com

Phone : 0891-2958321
Fax : 0891-2940354

SCHOOL CBSE No. : 59320

SCHOOL CODE:1537

CBSE AFFILIATION NO. : 100034

Ref:1537/KV-2(NSB)/2026-27/

Date: 25.08.2026

ASSURANCE CERTIFICATE

This is to certify that PMSHRI KENDRIYA VIDYALAYA NO. 2, NAUSENABAUGH, Visakhapatnam, bearing School CBSE No. 59320, School Code 1537 and CBSE Affiliation No. 100034, has taken necessary steps towards maintaining the fire safety arrangements in the Vidyalaya premises.

The fire extinguishers available in the Vidyalaya have been **refilled and serviced** by M/s Safeguard Services, Visakhapatnam, vide Ref. No. SS/PMSKV2/RF/04/26-27 dated 06/08/2026.

As per the Re-filling Certificate issued by M/s Safeguard Services, the fire extinguishers were checked and refilled as per IS 2190 standard and were found **working fine and ready to operate**.

The certificate records the following fire extinguishers:


- **Total fire extinguishers refilled: 24 Nos.**
- **Refilled date: 06/08/2026**
- **Validity up to: 05/08/2027**
- **Result: OK**
- **Remarks: Refilling done satisfactory**

The Vidyalaya assures that the fire-fighting equipment will be maintained in proper working condition and necessary fire-safety measures will be continued and monitored regularly for the safety of the students, staff and other occupants of the Vidyalaya.

This Assurance Certificate is issued for **submission to the Central Board of Secondary Education (CBSE) for the purpose of Extension of Affiliation**.

Place: Visakhapatnam


Date: 28.08.2026


PRINCIPAL

PMSHRI Kendriya Vidyalaya No. 2, Nausenabaugh

Visakhapatnam – 530 005

प्र.धाय / PRINCIPAL
केन्द्रीय विद्यालय नं. 2 / KENDRIYA VIDYALAYA NO. 2
नौसेना बाग / NAUSENABAUGH
विशाखापत्तनम / VISAKHAPATNAM-530 005





SAFEGUARD SERVICES

A COMPLETE FIRE & SAFETY SOLUTIONS
GSTIN NO: 37JRJPK2251N1Z7
PAN NO. JRJPK2251N

D.No.31-32-71/8
Sunkara Satyanarayana Complex,
Beside SBI, Dabagardence,
Visakhapatnam - 530 020.
Mobile : 73828 64927, 73829 64927
E-mail : safeguard.services@gmail.com

REF. NO: SS/PMSKV2/RF/04/26-27

06/08/2026.

REFILLING CERTIFICATE

TO WHOMESOEVER IT MAY CONCERN

This is Certify that the FIRE EXTINGUISHERS have been received from M/S PM SHRI KENDRIYA VIDYALAYA NO-2 NAUSENABAUGH VISAKHAPATNAM. To our firm and we have checked and refilled the fire extinguishers as per IS2190 standard. They are working fine at present and ready to operate. Following cylinders are refilled and their description mentioned below in detail.

SL. NO	TYPE OF FE	CAP	FE SL.NO	REFILLED DATE	VALID UPTO	RESULT
1	ABC FIRE EXTINGUISHER	06 KGS	01	06-08-2026	05-08-2027	OK
2	ABC FIRE EXTINGUISHER	06 KGS	02	06-08-2026	05-08-2027	OK
3	ABC FIRE EXTINGUISHER	06 KGS	03	06-08-2026	05-08-2027	OK
4	ABC FIRE EXTINGUISHER	06 KGS	04	06-08-2026	05-08-2027	OK
5	ABC FIRE EXTINGUISHER	06 KGS	05	06-08-2026	05-08-2027	OK
6	ABC FIRE EXTINGUISHER	05 KGS	06	06-08-2026	05-08-2027	OK
7	ABC FIRE EXTINGUISHER	05 KGS	07	06-08-2026	05-08-2027	OK
8	ABC FIRE EXTINGUISHER	05 KGS	08	06-08-2026	05-08-2027	OK
9	ABC FIRE EXTINGUISHER	05 KGS	09	06-08-2026	05-08-2027	OK
10	ABC FIRE EXTINGUISHER	05 KGS	10	06-08-2026	05-08-2027	OK
11	ABC FIRE EXTINGUISHER	05 KGS	11	06-08-2026	05-08-2027	OK
12	ABC FIRE EXTINGUISHER	04 KGS	12	06-08-2026	05-08-2027	OK
13	ABC FIRE EXTINGUISHER	04 KGS	13	06-08-2026	05-08-2027	OK
14	ABC FIRE EXTINGUISHER	04 KGS	14	06-08-2026	05-08-2027	OK
15	ABC FIRE EXTINGUISHER	02 KGS	15	06-08-2026	05-08-2027	OK
16	ABC FIRE EXTINGUISHER	02 KGS	16	06-08-2026	05-08-2027	OK
17	ABC FIRE EXTINGUISHER	02 KGS	17	06-08-2026	05-08-2027	OK

• Supply, Refilling, Servicing and Hydro Pressure Testing of All types of the Extinguishers • Supply of all Safety Equipments
• Maintenance of Fire fighting Equipments • Fire Hydrant System • Fire Alaram System • Sprinkler System





SAFEGUARD SERVICES

A COMPLETE FIRE & SAFETY SOLUTIONS

GSTIN NO: 37JRJPK2251N1Z7

PAN NO. JRJPK2251N

D.No.31-32-71/8

Sunkara Satyanarayana Complex,

Beside SBI, Dabagardence,

Visakhapatnam - 530 020.

Mobile : 73828 64927, 73829 64927

E-mail : safeguard.services@ymail.com

SL NO	TYPE OF FE	CAP	FE SL.NO	REFILLED DATE	VALID UPTO	RESULT
18	ABC FIRE EXTINGUISHER	02 KGS	18	06-08-2026	05-08-2027	OK
19	ABC FIRE EXTINGUISHER	02 KGS	19	06-08-2026	05-08-2027	OK
20	CO2 FIRE EXTINGUISHER	4.5 KGS	20	06-08-2026	05-08-2027	OK
21	ABC FIRE EXTINGUISHER	4.5 KGS	21	06-08-2026	05-08-2027	OK
22	ABC FIRE EXTINGUISHER	4.5 KGS	22	06-08-2026	05-08-2027	OK
23	ABC FIRE EXTINGUISHER	4.5 KGS	23	06-08-2026	05-08-2027	OK
24	ABC FIRE EXTINGUISHER	4.5 KGS	24	06-08-2026	05-08-2027	OK

REMARKS: REFILLING DONE SATISFACTORY

Thanks and regards,

SAFEGUARD SERVICES



- Supply, Refilling, Servicing and Hydro Pressure Testing of All types of the Extinguishers • Supply of all Safety Equipments
• Maintenance of Fire fighting Equipments • Fire Hydrant System • Fire Alaram System • Sprinkler System





पी.एम.श्री. केन्द्रीय विद्यालय क्रमांक 2 नौसेनाबाग
विशाखापत्तनम
(शिक्षा मंत्रालय, स्कूल शिक्षा और साक्षरता विभाग, भारत सरकार)
PMSHRI KENDRIYA VIDYALAYA No. 2 Nausenabaugh
Visakhapatnam

75
Azadi Ka
Amrit Mahotsav



https:// no2nausenabagh.kvs.ac.in
kv2nausenabagh@gmail.com

0891-2958321
0891-2940354

SCHOOL CBSE No. : 59320

SCHOOL CODE: 1537

CBSE AFFILIATION NO. : 100034

Ref: F. 30/2025-26/KV2NAUSENABAUGH/ 1644

Date: 03/06/2025

To,
The Garrison Engineer (U-II)
Military Engineer Services
104 Area, Industrial Estate Post
Visakhapatnam-530007.

Speed Post

Subject: Technical estimation for the installation of Fire Safety infrastructure in KV No 2 Nausenabaugh- reg

Ref No. 2000/Gen/138/E2 Dated 05/May/2025

Sir,

With reference to the above cited subject that this vidyalaya is forwarding -

A) the statement of case for fire safety infrastructure in detail of all requirement as per the Endorsement vide RC No. 273/RFO/FPW/GVMC/2024 DT 16.07.2024 fire safety unity of GVMC, VSKP

1. As per 1S 2190@01 No for every 100 sq. mtrs. built up area, we have 19 nos of fire extinguishers for 4162 sq. Mtrs of building type is B', we need 23 more.
2. Hose Reels @ 01 pc. for each floor @1000 sq. mtrs. built up area, we need Hose Reels for 4,162 sq. mtrs. Area 04 pc.
3. Terrace water storage tank @ 10,000 ltrs, we have 10,000 ltrs capacity terrace water storage tank already available.
4. We need 1 Booster pump at terrace tank @ 450 LMP.

B) Layout/ Site plan of existing Vidyalaya's building for ground floor, first floor and second floor was attached herewith

C) Total strength of students= approx. 1300 and staff=62.

This is submitted for your kind information and necessary action.

Yours faithfully

(K Surya Prakasa Rao)

प्राचार्य / Principal

केन्द्रीय विद्यालय नं. 2 / KENDRIYA VIDYALAYA No.2

नौसेना बाग / NAUSENABAUGH

विशाखापत्तनम / VISAKHAPATNAM-530 005

Copy to:-

1-The Chairman, VMC, KV No. 2 Nausenabaugh, Visakhapatnam for information pls.

File No.GVMC-FNOC0EDN(OCP)/32/2024-JA(FS)-GVMC

O/o the Fire Prevention Wing,
Greater Visakhapatnam
Municipal Corporation,
Visakhapatnam.

Rc.No.273/RFO/FPW/GVMC/2024

Dt:16/07/2024

ENDORSEMENT

Sub: GVMC – T.P. - Fire Prevention Wing - **M/s.PM SHRI Kendriya Vidyalaya No.2, Nausenabagh, Visakhapatnam** – Applied for Fire No. **Objection Certificate for Occupancy - Fire Protection system - Not installed** – Endorsement - Issued - Reg.

Ref: Application Dt.15-07-2024 of M/s.PM SHRI Kendriya Vidyalaya No.2, Nausenabagh, Visakhapatnam for Fire No Objection Certificate for Occupancy.

With reference to your application for Fire No Objection Certificate for Occupancy to the existing building of M/s.PM SHRI Kendriya Vidyalaya No.2, Nausenabagh, Visakhapatnam cited above, it is to inform that, during the inspection it is noticed that the Fire Fighting Equipment, is not installed which is required as per Table-7, Part-IV of National Building Code of India-2016 as follows:

1. Fire Extinguishers as per IS 2190 @ 01 No. for every 100 Sq.Mtrs built up area
2. Hose Reels @ 01 No. for each floor @ 1000 Sq.Mtrs built up area
3. Terrace water storage tank @ 10,000 ltrs.
4. Booster pump at terrace tank @ 450 LPM

Therefore, it is requested to provide the above said fire safety equipment and re-submit application for issuance of Fire No Objection Certificate for Occupancy from this office.

Y HANUMANTHA RAO, RFO(YHR)-RFO(TP)-GVMC, O/o REGIONAL FIRE OFFICER-TOWN PLANNING-GVMC

Regional Fire Officer

To,
The Management,
M/s.PM SHRI Kendriya Vidyalaya No.2, Nausenabagh, Visakhapatnam.

